| | MPPKVI, CATD, INDOSE GRICE | | | | | | | | | | | | | |
|---------------------|----------------------------|---------------------|---|----------------------|-----------------|----------------------------|---|-------------|------------|--|--------------------------|--|----------------|--|
| S.No Name of NAME | OF Name of EHV S/s or | Line KV Capacity | Name of 33 KV / 11 KV | Group (for 33KV) / | Date of Planned | Duration of Planned Total | Reason for Planned Shutdown (Maintenance/Erection | Shutdown | Approval | Planned shu Alternate Supply Arrangements | Demand in MW affected | Areas affected | | |
| INDORE Sou | ON 33/11 KV S/s | (33 or 11) 11 kv | feeder Khatiwala tank | Category (for 11 KV) | Shutdown | From to Duration | work/ FSP / Safety purpose etc.) 11 kv feeder VCB not proper on/off checked by STM | Approved by | AE(Maint.) | are available or not (Yes/No) | due to Shutdown. 0.49 | Holkar collage, university quater chandra, bhawar kuva chouraha, asharam chouraha, | REMARK | |
| CITY Divis | on | 33 kv | | | | | | | | 110 | | | | |
| 2 CITY Divis | Sabji mandi | | Rajendra nagar | CHQ | 26.02.2019 | | 33 kv feeder VCB Not proper triped checked by STM | | AE(Maint.) | Yes | Nil | Nil | | |
| 3 CITY Divis | on Meimanic Magar | 33 kv | Rajendra nagar | CHQ | 26.02.2019 | | 33 kv feeder VCB Not proper triped checked by STM | SE CITY | AE(Maint.) | No | 0.29 | 11 kv aditya nagar + sidharth nagar | | |
| 4 City circle Divis | Mehhanic Nagar | 33 kv | Rajendra nagar O/G | CHQ | 26.02.2019 | 07:00:00 08:00:00 01:00:00 | Tree cutting work | SE CITY | AE(Maint.) | Yes | Nil | Nil | | |
| 5 INDORE Cent | al Silicon City | 11 kv | Feeder no 1 & 3 | CHQ | 26.02.2019 | 09:30:00 13:30:00 04:00:00 | Due to Tree Cutting & Line Maintenance Work | SE CITY | AE(Maint.) | No | 1 | Silicon City Colony & ETC | PAPER DECLARED | |
| 6 CITY Cent | al Gumasta nagar | 11 kv | IDA-2 | CHQ | 26.02.2019 | 07:00:00 07:30:00 00:30:00 | Due to CT Nut Red Hot Work | SE CITY | AE(Maint.) | No | 0.9 | HT.Conn. Dal Mill, Sch no 71, Govt. Hospital, HT Apna Palace, Hindusthan Petrolium & ETC | | |
| 7 INDORE Cent | al Annapurna | 11 kv | Dashara maidan | CHQ | 26.02.2019 | 15:00:00 15:30:00 00:30:00 | Due to Fail DTR Replacement Work | SE CITY | AE(Maint.) | No | 1 | Dashara maidan, Annapurna Main Road, Kantikaplani nagar, jai jagat Colony, & ETC | | |
| 8 INDORE Cent | al Rau | 11 kv | Royal Park | CHQ | 26.02.2019 | 16:30:00 17:00:00 00:30:00 | Due to Fail DTR Replacement Work | SE CITY | AE(Maint.) | No | 1 | Shiv Sagar Colony, Colour Graphix, Sheel Graphix, | | |
| 9 INDORE Nor | 33/11 KV SHILNATH | 11 KV | 11 KV KULKARNI BHATTA | CHQ | 26.02.2019 | 09:00:00 09:30:00 00:30:00 | FOR 5 % SUPERVISION WORK OF TRANSFORMER SHIFTING WORK JUMPER CUT | SE CITY | AE(Maint.) | NO | 0.8 | Kulkarni bhatta, Shankar ka bagicha, Subhash nagar, Bijasan mata | PAPER DECLARED | |
| 10 INDORE Nor | 33/11 KV SHII NATH | 11 KV | 11 KV KULKARNI BHATTA | CHQ | 26.02.2019 | 13:30:00 14:00:00 00:30:00 | AFTER WORK JUMPER CONNECTED | SE CITY | AE(Maint.) | NO | 0.8 | Kulkarni bhatta, Shankar ka bagicha, Subhash nagar, Bijasan mata | PAPER DECLARED | |
| 11 INDORE Nor | 33/11 KV BEST PRICE | 5 MVA | 5 MVA PTR | - | 26.02.2019 | 09:00:00 09:30:00 00:30:00 | FOR PTR MAINTENANCE WORK BY STM TEAM | SE CITY | AE(Maint.) | NO | 1 | BYPASS FEEDER & SCKON TEMPLE | | |
| 12 INDORE Nor | 33/11 KV OCEAN | 10 MVA | 10 MVA PTR | - | 26.02.2019 | 11:00:00 11:30:00 00:30:00 | FOR PTR MAINTENANCE WORK BY STM TEAM | SE CITY | AE(Maint.) | NO | 1 | 11 KV OCEAN PARK & BYPASS FEEDER | | |
| 13 INDORE Nor | 132 KV NORTH | 33 KV | 33 KV ZONAL 1ST | IX | 26.02.2019 | 17:00:00 17:30:00 00:30:00 | FOR NEW 11 KV HT CONSUMER WORK OF SAI KRIPA | SE CITY | AE(Maint.) | NO | 1.1 | ONLY HT CONSUMER | PAPER DECLARED | |
| 14 INDORE Nor | | 11 KV | 11 KV CHOUTHA SANSAR | CHQ | 26.02.2019 | 17:00:00 17:30:00 00:30:00 | DOUBLE CIRCUIT LINE SEAFTY PURPOSE | SE CITY | AE(Maint.) | NO | 0.85 | Sector F Industrial Area | PAPER DECLARED | |
| 15 INDORE Nor | 33/11 KV | 11 KV | 11 KV GOYAL EVENEU | CHQ | 26.02.2019 | 14:00:00 17:00:00 03:00:00 | FOR IPDS MAINTENANCE WORK | SE CITY | AE(Maint.) | NO | 0.9 | Areas affected | PAPER DECLARED | |
| 16 INDORE Nor | 22/11/2010/01/ | 11 KV | 11 KV LASUDIYA NAKA | CHQ | 26.02.2019 | 12:00:00 14:00:00 02:00:00 | FOR IPDS MAINTENANCE WORK | SE CITY | AE(Maint.) | NO | 1 | Electronic complex parisar | PAPER DECLARED | |
| 17 INDORE Nor | 33/11 KV | 11 KV | 11 KV NIPANIYA | CHQ | 26.02.2019 | 13:00:00 16:00:00 03:00:00 | FOR IPDS MAINTENANCE WORK | SE CITY | AE(Maint.) | NO | 0.5 | Areas affected | PAPER DECLARED | |
| 18 INDORE Nor | 122 171 | 33 KV | 33 KV NAGAR NIGAM | VIII | 26.02.2019 | 13:00:00 15:00:00 02:00:00 | FOR IPDS MAINTENANCE WORK | SE CITY | AE(Maint.) | NO | 1.5 | ONLY HT CONSUMER AND SHALIMAR SWAM & THRUMALA GRID | PAPER DECLARED | |
| 19 INDORE Nor | 23/11 VV VARIT | 11 KV | 11 KV BHANGARH | CHQ | 26.02.2019 | 13:00:00 16:00:00 03:00:00 | FOR IPDS MAINTENANCE WORK | SE CITY | AE(Maint.) | NO | 0.85 | Bhangarh village, Kabit khedi, | PAPER DECLARED | |
| 20 INDORE Nor | 33/11 KV MANGLIYA | 11 KV | 11 KV LT CONSUMER | CHQ | 26.02.2019 | 13:00:00 15:00:00 02:00:00 | FOR IPDS MAINTENANCE WORK | SE CITY | AE(Maint.) | NO | 0.5 | Areas affected | PAPER DECLARED | |
| 21 INDORE Nor | 132 KV NODTH | 33 KV | 33 KV SECTOR C | IX | 26.02.2019 | 07:00:00 07:30:00 00:30:00 | FOR CONNECTION (P.D) WORK OF HT CONSUMER Rombay scrap | SE CITY | AE(Maint.) | YES | Nil | | | |
| 22 INDORE Nor | n 33/11 kv SECTOR O | 11 KV | 11 KV CONTINENTAL FEEDER | CHQ | 26.02.2019 | 07:00:00 07:15:00 00:15:00 | FOR RED HOT WORK | SE CITY | AE(Maint.) | NO | 0.85 | Areas affected | | |
| 23 INDORE Nor | 33/11 kv SECTOR O | 11 KV | 11 KV ASHA FOOD | CHQ | 26.02.2019 | 07:15:00 07:30:00 00:15:00 | FOR RED HOT WORK | SE CITY | AE(Maint.) | NO | 1 | Areas affected | | |
| 24 INDORE Nor | 33/11 kv SCHEME NO 114 | 33 KV | 33 KV BUS CUPLER | CHQ | 26.02.2019 | 06:45:00 07:00:00 00:15:00 | FOR RED HOT WORK | SE CITY | AE(Maint.) | NO | 1 | 11 KV LAL BANGLOW & SANT NAGAR & AHILIYA NAGAR & RAJIV 1 & 2 LOHA MANDI & ARMY WELFARE & 114 | | |
| 25 INDORE Nor | 33/11 kv SCHEME NO. 114 | 33 KV | 11 KV MAIN NO. 3 | CHQ | 26.02.2019 | 07:00:00 07:15:00 00:15:00 | FOR RED HOT WORK | SE CITY | AE(Maint.) | NO | 2 | 11 KV RAJIV 1 & 2 & ARMY WELFARE | | |
| 26 INDORE Nor | 33/11 kv ELECTRONIC | 11 KV | 11 KV EC-2 | CHQ | 26.02.2019 | 07:45:00 08:00:00 00:15:00 | FOR RED HOT WORK | SE CITY | AE(Maint.) | NO | 0.45 | Areas affected | | |
| 27 INDORE WES | CITY CONTROL ROOM | 11KV | SANWER ROAD | CHQ | 26.02.2019 | 11:00:00 14:00:00 03:00:00 | FOR POLE WORK BY IPDS | SE CITY | AE(Maint.) | NO | 1 | First Bataliyan Kabiry Line, GuruDwara, Raghuwanshi Colony, Punjab Nation Bank, Sapnabar, Durga Nagar, Kumar Khadi, Jay Hind Nagar, Shiv Tempal, ShantiDeep Aport, Banganga Main Road, Laxmibai Station Road. | PAPER DECLARED | |
| 28 INDORE WES | CITY CONTROL ROOM | 11KV | MAIN NO.2(SANWER ROAD+SHIV VILAS) | CHQ | 26.02.2019 | 11:15:00 11:45:00 00:30:00 | FOR IN GRID 11KV MAIN NO.2 ISOLATOR CLAMPRED HOT POINT ATTEND WORK | SE CITY | AE(Maint.) | NO | 2 | GPH, FOC, Ram Bag Petrol Pump, Arardhna Agart, Blob Moballa, Smrati Tokij, Shastri Golovy, Ikwal Golovy, Gurunanak Oli Mya, Hungaritha, Ahilyaparta, Telephone Ex, Juna Risala, Chobir Pahun Police Line, Chhipa Baldhal - First Bataliyan Kahlyv Line, Gurunbara, Raghuwannis Golovy, Pumja Nakion Bank, Spannaka, Pumpa Nagar, Gumar Khadi, Hyi Hini Mgazar, Shiv Tempal, Shanatipe Agort, Banganga Main Road, Laurbhial Station Road. | | |
| 29 INDORE WES | CITY CONTROL ROOM | 11KV | TILAK PATH | CHQ | 26.02.2019 | 11:00:00 14:00:00 03:00:00 | FOR DTR WORK BY IPDS | SE CITY | AE(Maint.) | NO | 1.1 | | PAPER DECLARED | |
| 30 INDORE CITY WES | | 33 KV | PTR NO.1(SANGAM NAGAR+ SUBHASHMARG-I) | CHQ | 26.02.2019 | 17:00:00 17:15:00 00:15:00 | FOR IN GRID 33KV VCB WORK BY STM | SE CITY | AE(Maint.) | NO | 2 | Sangam Nagar, Riksha Stand. Laxmanpura, Gomti Nagar, Holmark School, IDL School. + Gadra Khedi, Palhar Nagar, Sahu Nagar, Ramchandra Nagar Chouraha, Sadhna Nagar, Ratlam Tower, Monika Iskrim, Snah Swits. | | |
| 31 INDORE EAS | SATYA SAI | 11KV | BHAGAT SINGH | CHQ | 26.02.2019 | 07:00:00 07:30:00 00:30:00 | 11KV FEEDER VCB REPLACEMAINT WORK | SE CITY | AE(Maint.) | NO | 0.95 | METRO TOWER, SATYA SAI SCHOOL, GUJARATI SCHOOL, TOTAL HELPS AND PRESTIGE INSTITUTE ETC. | | |
| 32 INDORE EAS | SATYA SAI | 11KV | MALVIYA NAGAR | CHQ | 26.02.2019 | 11:00:00 11:30:00 00:30:00 | FOR FAIL X-MER REPLACEMAINT WORK. | SE CITY | AE(Maint.) | NO | 1 | MALVIYA NAGAR GALI NO. 1,2, CHANDRA NAGAR, BARKHA SCHOOL AND KHATU SHYAM MANDIR ETC. | | |
| 33 INDORE EAS | VANDNA NGR. | 11KV | VANDNA NGR. | CHQ | 26.02.2019 | 12:00:00 12:00:00 00:00:00 | 200KVA FAIL X-MER REPLACEMAINT WORK. | SE CITY | AE(Maint) | NO | 0.65 | SWARN VATIKA, PARICHARIKA NAGAR, GEETA NAGAR, PADMAVATI COLON AND GIRDHAR NAGAR ETC. | | |
| 34 INDORE EAS | SHALIMAR TOWNSHIP | 33KV | SHALIMAR TOWNSHIP | CHQ | 26.02.2019 | 07:30:00 08:00:00 00:30:00 | 5MVA POWER X-MER REPLACEMAINT WORK BY STM. | SE CITY | AE(Maint.) | NO | 2.5 | SHALIMAR TOWNSHIP GIRD. | | |