

M.P.P.K.V.V. C.LTD. INDORE CIRCLE																		
S.No	Name of Circle	NAME OF DIVISION	Name of EHV S/s or 33/11 KV S/s	Line KV Capacity (33 or 11)	Name of 33 KV / 11 KV feeder	Planned shutdown		DATE-30.07.2019		Reason for Planned Shutdown (Maintenance/Erection work/ FSP / Safety purpose etc.)	Shutdown Approved by -	Approval Granted to-	Alternate Supply Arrangements are available or not (Yes/No)	It has been Reported on Whatsapp Group	Demand in MW affected due to Shutdown.	Remark(Are as affected)	Remark(Areas affected)	
						Group (for 33KV) / Category (for 11 KV)	Date of Planned Shutdown	Duration of Planned	Total Duration									
1	INDORE CITY	North	33/11 kv Sector C	11 kv	11 KV Asha food	CHQ	30.07.2019	06:30	11:00	04:30	line maintenance & tree cutting work	SE CITY	AE (HTM)	NO	YES	1.2	PAPER DECLEAD	Asha Udyog, Sector C
2	INDORE CITY	North	33/11 kv Sector C	11 kv	11 KV continental	CHQ	30.07.2019	06:30	11:00	04:30	line maintenance & tree cutting work	SE CITY	AE (HTM)	NO	YES	1.2	PAPER DECLEAD	Continental Refactory & Sector C Industrial Area,
3	INDORE CITY	North	33/11 kv electronic com	33 kv	33 kv Bhartitilinaate	VIII	30.07.2019	7:30:00	8:00:00	0:30:00	for ME & CT Red hot work of 33 kv Bhartitilinate	SE CITY	AE (HTM)	yes	YES	-		-
4	INDORE CITY	North	33/11 kv Niranjan pur	11 kv	11 kv Mother Teresa	CHQ	30.07.2019	6:45:00	7:00:00	0:15:00	for CT Clamp Red hot work	SE CITY	AE (HTM)	NO	YES	0.8		Mother Tereca colony
5	INDORE CITY	North	33/11 kv Loha mandi	33 kv	33 kv Mahalaxmi	VIII	30.07.2019	6:00:00	6:30:00	0:30:00	for B-phase O/g Isolator Red hot of 33 kv mahalaxmi	SE CITY	AE (HTM)	NO	YES	1		Area affected Releted to This Feeder
6	INDORE CITY	North	33/11 kv Loha mandi	11 kv	11 kv main	CHQ	30.07.2019	6:00:00	6:30:00	0:30:00	y-phase main isolator red hot work	SE CITY	AE (HTM)	NO	YES	0.9		Area affected Releted to This Feeder
7	INDORE CITY	North	33/11 kv Scheme no. 78	11 kv	11 kv Feeder no 3	CHQ	30.07.2019	17:45:00	18:00:00	0:15:00	for Isolator Red hot work	SE CITY	AE (HTM)	NO	YES	0.6		Area affected Releted to This Feeder
8	INDORE CITY	North	33/11 kv Scheme no. 136 1st	11 kv	11 kv Feeder no 3	CHQ	30.07.2019	17:00:00	17:30:00	0:30:00	Y-phase ME clamp red hot work	SE CITY	AE (HTM)	NO	YES	0.7		Area affected Releted to This Feeder
9	INDORE CITY	Central	Silicon City	11 kv	Feeder no 2	CHQ	30.07.2019	8:00:00	10:00:00	2:00:00	Due to 6 Span Guarding Work Silicon City Near nala & AB Switch Installation Work at Near Shiv City Under IPDS	SE CITY	AE (HTM)	NO	YES	0.8	PAPER DECLEAD	Area affected Releted to This Feeder
10	INDORE CITY	Central	Revenue nagar	11 kv	Usha nagar	CHQ	30.07.2019	8:00:00	10:00:00	2:00:00	Due to 02 no DTR Augmantation work at Near Usha nagar IPDS	SE CITY	AE (HTM)	NO	YES	0.7	PAPER DECLEAD	Area affected Releted to This Feeder
11	INDORE CITY	Central	Pragati nagar	11 kv	Main no 2	CHQ	30.07.2019	5:30:00	6:00:00	0:30:00	Due to Ct Clamp & Isolator Red Hot Work at grid	SE CITY	AE (HTM)	NO	YES	0.9		11 KV parmanu nagar, Pragati Nagar, Sudama Nagar, Buddha nagar, D-mart,Sch no 135 Affected
12	INDORE CITY	Central	Pragati nagar	11 kv	Main no 1	CHQ	30.07.2019	6:00:00	6:15:00	0:15:00	Due to CT Clamp Red Hot Work at Grid	SE CITY	AE (HTM)	NO	YES	0.7		11 KV Siddhipuram & Prabhu nagar Affected
13	INDORE CITY	Central	Gumasta nagar	11 kv	IDA-1	CHQ	30.07.2019	6:30:00	6:45:00	0:15:00	Due to Isolator Red Hot Work at Grid	SE CITY	AE (HTM)	no	YES	0.7		11 KV Siddhipuram & Prabhu nagar Affected
14	INDORE CITY	Central	Gumasta nagar	11 kv	Main no 3	CHQ	30.07.2019	6:45:00	7:00:00	0:15:00	Due to Isolator Red Hot Work at Grid	SE CITY	AE (HTM)	no	YES	1.2		11 KV Sirpur & Dwarkapuri affected
15	INDORE CITY	Central	Gumasta nagar	11 kv	Main no 1	CHQ	30.07.2019	7:00:00	7:15:00	0:15:00	Due to Isolator Red Hot Work at Grid	SE CITY	AE (HTM)	no	YES	1.1		11 Kv Dhar Road ,JDA-2,Dravin nagar Affected
16	INDORE CITY	Central	Gumasta nagar	11 kv	Main no 2	CHQ	30.07.2019	7:15:00	7:30:00	0:15:00	Due to Isolator Red Hot Work at Grid	SE CITY	AE (HTM)	no	YES	1.2		11 KV Gumasta nagar Affected
17	INDORE CITY	Central	Revenue nagar	11 kv	Madhuban	CHQ	30.07.2019	12:15:00	13:00:00	0:45:00	Due to 11 kv feeder ME Replacement Work work at s/s	SE CITY	AE (HTM)	no	YES	0.8		Area affected Releted to This Feeder
18	INDORE CITY	Central	bijalpur	11 kv	sanjay nagar	CHQ	30.07.2019	17:00:00	17:30:00	0:30:00	vcb testing by STM	SE CITY	AE (HTM)	NO	YES	0.8		sanjay nagar, bijalpur gram
19	INDORE CITY	Central	bijalpur	11 kv	mundi gao	CHQ	30.07.2019	17:30:00	18:00:00	0:30:00	vcb testing by STM	SE CITY	AE (HTM)	NO	YES	0.9		mundi ,new bijalpur, nihalpur
20	INDORE CITY	South Division	Navlakha	33 kv	Indira complex 1	VIII	30.07.2019	6:00:00	6:30:00	0:30:00	33 kv feeder ME R-phase Jumper clamp replacement work	SE CITY	AE (HTM)	Yes	YES	Nil		Nil
21	INDORE CITY	South Division	Daily College	11 kv	Main no. 3	CHQ	30.07.2019	9:00:00	11:00:00	2:00:00	For VCB Circuit & VCB checked by STM	SE CITY	AE (HTM)	Yes	YES	Nil		Nil
22	INDORE CITY	WEST	ZINSI HAT	11 kv	5MVA PTR NO.3 (LOHARPATTI-1&2)	-	30.07.2019	5:00:00	5:30:00	0:30:00	FOR 5MVA PTR NO.3 ISOLATOR Y PHASE CLAMP & 11KV LOHARPATTI-2 OUTGOING ISOLATOR Y PHASE CLAMP RED HOT WORK.	SE CITY	AE (HTM)	NO	YES	2		11 KV LOHARPATTI-1&2 FEEDER
23	INDORE CITY	WEST	SECTOR-A	11 kv	SECTOR-A	CHQ	30.07.2019	6:00:00	6:30:00	0:30:00	11 KV SEC. A FEEDER Y PH CT RED HOT WORK	SE CITY	AE (HTM)	NO	YES	0.9		All LT Consumer & Mungad Alu, Meta Tubey, Sciye Line, Indore Naitred, Quajer Eng., Ast Vinayak, Tirupati Printo Pek, Rajput Ind.
24	INDORE CITY	WEST	BAJAJ KANA	11 kv	11 MAIN (BAJAJ KHANA & MTC)	CHQ	30.07.2019	8:00:00	8:30:00	0:30:00	FOR 11 MAIN VCB Y PHASE & ISOLATOR R PHASE CLAMP RED WORK.	SE CITY	AE (HTM)	NO	YES	1		11 KV BAJAJ KHANA & MTC FEEDER
25	INDORE CITY	WEST	CITY CONTROL ROOM	11 kv	TILAKPATH	CHQ	30.07.2019	9:00:00	9:30:00	0:30:00	11 KV FEEDER FOR ME REPLACEMENT WORK.	SE CITY	AE (HTM)	NO	YES	0.6		Pends Medum, GPH Complex, Swadesh Press, Narayan Bagh, Malhar Aashram, Chandan Apart., Panth Vaidh Colony, Jatti Colony, Tapsya Apart., Etc.
26	INDORE CITY	WEST	ZINSI HAT	11 kv	KILA GATE	CHQ	30.07.2019	7:00:00	10:00:00	3:00:00	2 NO. DTR CHARGING WORK NEAR MAHESH GARD & GUTKESHWAR TEMPLE. Under IPDS	SE CITY	AE (HTM)	NO	YES	0.6	PAPER DECLEAD	ZINSI , SHANKAR JANG, MAHESH GARD LINE AND RELATED KSHETRA.
27	INDORE CITY	WEST	RAJMOHALLA	11 kv	FORT-1ST	CHQ	30.07.2019	7:00:00	10:00:00	3:00:00	FOR LINE MAITENANCE AND TREE CUTTING WORK.	SE CITY	AE (HTM)	NO	YES	0.7	PAPER DECLEAD	VIDHYANCHAL NAGAR, AIRPORT ROAD, TIRUPATI NAGAR AND RELATED KSHETRA.
28	INDORE CITY	WEST	AIRPORT	11 kv	HI LINK	CHQ	30.07.2019	11:00:00	11:30:00	0:30:00	FOR THE TREE CUTING WORK 100 KVA DTR NEAR CHOTA BANGARDA.	SE CITY	AE (HTM)	NO	YES	0.7		BABURAY COLONO,SHAKTI NAGAR, VASHNO DEVI NAGAR PATEL NAGAR
29	INDORE CITY	WEST	ZINSI HAT	11 kv	5MVA NO-1 ( GOVT PRESS & KILA GATE	-	30.07.2019	16:00:00	16:30:00	0:30:00	FOR I LAVEL AND HV AND LV RED HOT BY STM WORK.	SE CITY	AE (HTM)	NO	YES	1.2		11 KV GOVT PRESS & KILA GATE
30	INDORE CITY	EAST	VANDNA NGR.	11KV	SAKET NGR.	CHQ	30.07.2019	06:30:00	10:30:00	04:00:00	TREE CUTTING & MAINTENANCE WORK.	SE CITY	AE (HTM)	NO	YES	0.9	PAPER DECLEAD	SAI NATH COLONY, GOYAL NAGAR , MAN BHAVAN NAGAR, TELEPHONE EX.AND SHAKUNTALA HOSP ETC.
31	INDORE CITY	EAST	PRESS COMPLEX	11KV	ANOOP NAGAR	CHQ	30.07.2019	10:00:00	10:30:00	00:30:00	200KVA X-MER FAIL X-MER REPLACEMANT WORK	SE CITY	AE (HTM)	NO	YES	0.7		KAKAD, LIFE LINE HOSPITAL , KALINDI KUNJ AND PUSHP NAGAR ETC.
32	INDORE CITY	EAST	MANORAMAGANJ	11KV	TILAK NAGAR	CHQ	30.07.2019	11:00:00	11:30:00	00:30:00	200KVA X-MER FAIL X-MER REPLACEMANT WORK	SE CITY	AE (HTM)	NO	YES	0.6		SEVA SARDAR NAGAR, BADI GWAL TOLI , CHOKSI LAB AND SHANTI NAGAR ETC.
33	INDORE CITY	EAST	VANDNA NGR.	11KV	MAHADEV TOTLA	CHQ	30.07.2019	12:30:00	13:00:00	00:30:00	11KV MAIN NO.4 VCB ON & OFF PROBELM WORK BY STM.	SE CITY	AE (HTM)	NO	YES	0.8		RAM MANDIR SAINATH COLONY, MAHAVEER NAGAR , SAVIND NAGAR AND KANDIA MAIN ROAD ETC.