M.P.P.K.V.V.Co. Ltd. Indore City Circle																		
									Planne	d Shutd	own Date_02.07.2019							
S.No	Name of Circle	NAME OF DIVISION	Name of EHV S/s or 33/11 KV S/s	Line KV Capacity (33	Name of 33 KV / 11 KV feeder	Group (for 33KV) / Category (for 11	Date of Planned Shutdown	Duration of From	of Planned to	Total Duration	Reason for Planned Shutdown (Maintenance/Erection work/ FSP /	Shutdown Approved	Approval Granted to-	Alternate Supply Arrangements are available		Location where tree cutting is to	Areas affected	Remarks
1	Indore city	Central	Rau	11 KV	Main no 2	CHQ	02.07.2019	11:00	11:20	00:20	Due to Red Hot Work & Isolator Reparing Work at Grid	SE CITY	AE(Maint.)	NO	1		11 KV Rau-1 ,Pigdamber Rural & IP feeder Affected	
2	Indore city	Central	Gumasta nagar	11 KV	IDA-1	CHQ	02.07.2019	07:00	10:00	03:00	Due to Tree Cutting & line maintenance Work P/D Shutdown	SE CITY	AE(Maint.)	NO	0.98		Sch no 71, HT Verma Unioun Hospital,Hindusthan Petrolium, Bharat Petrolium, GNt market, Govt, Hospital	Paper Declared
3	Indore city	Central	Gumasta nagar	11 KV	Dravin Nagar	CHQ	02.07.2019	07:00	08:00	01:00	Due to Double CKT With IDA-1 For Sefty Perpose	SE CITY	AE(Maint.)	NO	0.85		Dravin nagar, nakoda Chook, Kut-Kut Bhawan, pashu Chikitsalaya, Ranjeet hanuman & ETC	
4	Indore city	Central	Rajendra Nagar	11 KV	Main no 1 & 2	CHQ	02.07.2019	09:30	10:50	01:20	Due to VCB not Trip on Fault	SE CITY	AE(Maint.)	NO	1		Area Affected Releted to This Feeder	
5	Indore city	Central	Rajmohalla	11 KV	Main no 1	CHQ	02.07.2019	06:30	07:00	00:30	For VCB ON-OFF Problem, repaire work by STM	SE CITY	AE(Maint.)	NO	1		Area Affected Releted to This Feeder	
6	Indore city	North	33/11 kv Electronic com	11 kv	11 kv nanda Nagar	CHQ	02.07.2019	06:00	10:00	04:00	line maintenance & tree cutting	SE CITY	AE(Maint.)	no	0.8		Poonam verma multy, Girnar garden, Old Bhandari hospital, Pardeshipura Petrol pump,	Paper Declared
7	Indore city	North	33/11 kv 114	11 kv	11 kv Lal banglow	CHQ	02.07.2019	16:00	16:30	00:30	for Burst ME replacement work js Industry	SE CITY	AE(Maint.)	no	0.75		Areas affected	
8	Indore city	North	33/11 kv sector C	11 KV	11 kv Continental	CHQ	02.07.2019	05:30	05:45	00:15	for CT red hot work	SE CITY	AE(Maint.)	NO	0.55		Industrial area	
9	Indore city	North	33/11 kv Lig	11 KV	11 kv Old palasiya	CHQ	02.07.2019	05:30	06:00	00:30	for isolator red hot work	SE CITY	AE(Maint.)	NO	0.62		Shopping complex, Industry house, Onam Plaza, Sanjivni nursingh home, Hotel Amaltas, RK Puram colony, sanjay upvan, Dev nagar,	
10	Indore city	North	33/11 kv Electronic com	11 kv	11 kv EC-1	Nil	02.07.2019	06:00	10:00	04:00	line maintenance & tree cutting	EE Sir North	AE SAAB	no	0.52		Nanda nagar, Ankosh system,	Paper Declared
11	Indore city	South	Daily College	11kv	Stadium	CHQ	02.07.2019	06:30	09:00	02:30	Tree cutting & line maintenance work	SE CITY	AE(Maint.)	No	2.42		,vaibhav chambers, 168 jaora cooundshivaji vatika,50 jaora compound, 33 indrasan complex, 12/5 ushaganj, 1/1 ushaganj chawni, my tempo stand	Paper Declared
12	Indore city	South	Sabji mandi	11 kv	main no. 1	CHQ	02.07.2019	06:00	06:30	00:30	11 kv Bas cuper Isolator Y-phase Clamp red hot work	SE CITY	AE(Maint.)	No	0.83		11 kv Rajendra nagar & Lokmanya feeder or related Areas	
13	Indore city	South	Sabji mandi	33 KV	Sabji mandi I/C	-	02.07.2019	06:30	06:45	00:15	33 kv Sabji mandi O/G feeder I/C Isolator clamp red hot work	SE CITY	AE(Maint.)	No	2.49		11 kv All feeder	
14	Indore city	South	Sadhu Vaswani	11 kv	Main no.1	CHQ	02.07.2019	06:45	07:15	00:30	11 kv Loha mandi feeder Y-phase I/C side Isolator clamp red hot work	SE CITY	AE(Maint.)	No	0.76		11 kv All feeder	
15	Indore city	South	Indira Complex	11 kv	Sambad Nagar	CHQ	02.07.2019	08:30	09:00	00:30	Due to VCB's pole problem	SE CITY	AE(Maint.)	No	0.76		11 kv All feeder	
16	Indore city	EAST	GOYAL NGR.	11KV	CHOUHAN NGR.	CHQ	02/07/2019	07:00:00	07:20:00	00:20	R PHASE CT RED HOT ATTEND WORK.	SE CITY	AE(Maint.)	NO.	0.68		PIPLIYA HANA, RAVI MASALA, DEEPAK NAGAR,DEEPAK NAGAR AND KOTHARI COLLAGE ETC.	
17	Indore city	EAST	GOYAL NGR.	11KV	GOYAL VIHAR.	CHQ	02/07/2019	07:30:00	07:50:00	00:20	R PHASE CT RED HOT ATTEND WORK.	SE CITY	AE(Maint.)	NO.	0.45		RADHA KRUSHAN COLONY, MAHARASHTRA BANK, SHAHNAI 2 AND PREM BANDHAN GARDEN ETC	
18	Indore city	WEST	HEMILTAN ROAD	11KV	11 MAIN.1 (HEMILTAN AND NANDALAPURA)	CHQ	02.07.2019	05:00:00	05:30:00	00:30	FOR IN GRID 11 MAIN ROAD CT AND 11KV HEMILTAN, NANDALALPURA ISOLATER RED HOT ATTEND.	SE CITY	AE(Maint.)	NO	0.56		Realated Area Affected	
19	Indore city	WEST	CITY CONTROL ROOM	11KV	RAJWADA AND IMLI BAZAR	CHQ	02.07.2019	06:30:00	07:00:00	00:30	FOR TREE CUTTING PIPAL NEAR SADAR BAJAR WATER TANKI.	SE CITY	AE(Maint.)	NO	0.68		Realated Area Affected	
20	Indore city	WEST	JINSI HAT	11KV	KILA GATE	CHQ	02.07.2019	07:05:00	07:30:00	00:25	FOR PIPAL TREE CUTTING IN VRANDAVAN COLONY KHASAGI KA BAGICHA NEAR DR. BANZAL	SE CITY	AE(Maint.)	NO	0.75		Realated Area Affected	
21	Indore city	WEST	GANDHI NAGAR	11KV	11 MAIN 1ST (11 GANDHINAGAR + DEVDHARAM + 11 BANGARDA + 11 DENTAL	CHQ	02.07.2019	07:30:00		00:30	FOR 11MAIN 1 ROAD CT RED HOT AND 11 GANDHINAGAR ISOLATER MAINTENANCE WORK.	SE CITY	AE(Maint.)	NO	0.65		Realated Area Affected	
22	Indore city	WEST	Sangam Nagar	11KV	main no. 1	CHQ	02.07.2019	07:20:00	07:50:00	00:30	For VCB not trip on Fault	SE CITY	AE(Maint.)	NO NO	0.65	L	Realated Area Affected	