

Electrical Safety Check – Report

This electrical safety check is for electrical safety purposes only and is in accordance with the requirements of the Residential Tenancies Regulations 2021 and is prepared in accordance with section 2 of the Australian/New Zealand Standard AS/NZS 3019, Electrical installations— Periodic verification to confirm that the installation is not damaged or has not deteriorated so as to impair electrical safety; and to identify installation defects and departures from the requirements that may give rise to danger.

A. INSTALLATION ADDRESS

Address :	123 Geelong road
Date of previous Safety Check: (if any)	

B. EXTENT OF THE INSTALLATION AND LIMITATIONS OF THE INSPECTION AND TESTING

Details of those parts of the installation and limitations of the safety check covered by this certificate Tick those parts of the installation included in the safety check – strike out those parts of the installation if not applicable – mark NI if not included in the safety check – add additional information if required.		
Main switchboard Main earthing system Kitchen Bathroom (main) Other bathrooms/ensuites Bedroom (main) Other bedrooms Living room	Other living areas Laundry Garage Solar/battery system Electric water heater Dishwasher Electric room/space heaters Swimming pool equipment	

C. SAFETY CHECK – VISUAL INSPECTION

As far as practicable a VISUAL INSPECTION of the following items has been carried out per the requirements of section 3 and 4 of the Australian/New Zealand Standard AS/NZS 3019:2007 Electrical installations—Periodic Verification : strike out those parts of the installation if not applicable – mark NI if not included in the safety check – add additional information if required.		
Consumers mains Switchboards Exposed earth electrode Metallic water pipe bond RCDs (Safety switches) Circuit protection (circuit breakers / fuses) Socket-outlets Light fittings Electric water heater Air conditioners	Space heaters Cooking equipment Dishwasher Exhaust fans Celling fans Washing machine/dryer Installation wiring Solar and other renewable systems Swimming pool equipment Vehicle chargers	

D. SAFETY CHECK - VERIFIED BY TESTING

As far as practicable TESTING of the following items has been carried out per the requirements of **4 of the Australian/New Zealand Standard AS/NZS 3019:2007 Electrical installations—Periodic Verification**: strike out those parts of the installation if not applicable – mark NI if not included in the safety check – add additional information if required.

- Polarity and correct connections testing

Consumers mains Circuit protection (circuit breakers / fuses) RCDs (Safety switches) Socket-outlets Light fittings	Electric water heater Air conditioners Cooking equipment Dishwasher Solar and other renewable systems Swimming pool equipment Vehicle chargers	
--	--	--

- Earth continuity testing

Mains earth conductor Switchboards enclosure Metallic water pipe bond Socket-outlets Light fittings Exhaust fans Ceiling fans	Electric water heater Air conditioners Cooking equipment Dishwasher Solar and other renewable systems Swimming pool equipment Vehicle chargers	
---	--	--

D. SAFETY CHECK – VERIFIED BY TESTING

RCD (residual-current device /safety switch) testing

Circuit protected	Push button test (pass / fail)	Time test (pass / fail)
Power outlets	Pass	Fail
Power outlets	Pass	Pass
Power outlets	Pass	Pass
Lighting	Pass	Pass
Lighting	Pass	Pass
Other	Pass	Pass

E. SMOKE ALARMS

All smoke alarm are correctly installed and in working condition; and have been tested according to the manufacturers instructions. Yes No	Next smoke alarm check due by :	2026-02-11
	All smoke alarms must be tested according to the manufacturers instructions at least once every 12 months	

F. OBSERVATIONS AND RECOMMENDATIONS

The following observations and recommendations are made:

F.Electrical Safety Check Certification

Electrical Safety check completed by :	Brandon Ferry	Licence / Registration number :	35346
		Inspection date :	2026-02-11
		Next inspection due by :	2027-02-11
I the above named licenced electrician have carried out an electrical safety check of this residential tenancies per the requirements of the Residential Tenancies Regulations 2021 and set out in the Australian/New Zealand Standard AS/NZS 3019, "Electrical installations—Periodic verification, and have recorded my observations and recommendations.			
Sign : Brandon Ferry		Date : 2026-02-11	