

Joint Working Group, FieldComm Group, ODVA, OPC Foundation, PROFIBUS
& PROFINET International

SECURE DEPLOYMENT OF INDUSTRIAL COMMUNICATION PROTOCOLS: A RISK-BASED APPROACH



Disclaimer

Prepared by Joint Working Group Device Tool Security for Ethernet and non-Ethernet-based Communication, consisting of the Standards Developing Organizations (SDOs) (alphabetic order):

- FieldComm Group
- ODVA, Inc.
- OPC Foundation
- PI (PROFIBUS & PROFINET International)

Core group members contributing (alphabetic order):

Adam Schneider (Emerson), Alexander Meurer (BASF), Allgaier, Florian (Vega), Andreas Gutscher (Balluff), Anis Ahmad (Emerson), Arne Felber (CodeWrights), Benjamin Reibold (Pepperl+Fuchs), Bhavik Zala (Emerson), Christoph Spiegel (Krohne), Christopher Saile (Pepperl+Fuchs), Dilara Madinger (Emerson), Dmitry Gringauz (Banner Engineering), Dorenburg (Knick), Dominic De-kerf (Cargill), Edwin van Hoeven (Yokogawa), Felix Reichert (SEW-Eurodrive), Florian Allgaier (Vega), Florian Sieber (Festo), Francesco Rovelli (Endress+Hauser), Frank Fengler (ABB), Gunnar Lessmann (Phoenix Contact), Harald Müller (Endress+Hauser), Jack Visoky (Rockwell Automation), Joakim Wiberg (ODVA), Josh Harmon (Delta Motion), Kai Hackenstrass (ifm), Kpolzer (Polzer Automation Solutions), Matthias Reiter (Festo), Matthias Schmidt (ifm), Mathias Monse (Sipos), Mirko Brcic (Endress+Hauser), Noah Paulat (Vega), Olliver Lundmattsson (Emerson), Pascal Sarrazin (Markem-Imaje), Philipp Ketterer (Vega), Randy Armstrong (OPC Foundation), Rob Umfreville (Rotork), Roberth Asplund (Emerson), Sebastian Broschei (Softing), Sebastian Heidepriem (SICK), Sean J. Vincent (FieldComm Group), Stefan Schaefermeyer (ifm), Stephen Mitschke (FieldComm Group), Sven Giesecke (CodeWrights), Ulrich Raithel (Sipos), Varsha Shinde (Emerson), Werner Laengin (AUMA), W. Kuipers (Krohne), Yasuki Yoda (Omron), Dominik Ziegler (Siemens)

Comments to be submitted to working group editor: simon.merklin@endress.com

This whitepaper exclusively describes the capabilities of industrial communication protocols and does not guarantee compliance with legal requirements, like the Cyber Resilience Act.

WHILE THE INFORMATION IN THIS PUBLICATION IS BELIEVED TO BE ACCURATE, THE STANDARDS DEVELOPING ORGANIZATIONS MAKE NO WARRANTY OF ANY KIND, EXPRESS OR IMPLIED, WITH REGARD TO THIS MATERIAL INCLUDING, BUT NOT LIMITED TO ANY WARRANTY OF TITLE OR OWNERSHIP, IMPLIED WARRANTY OF MERCHANTABILITY OR WARRANTY OF FITNESS FOR PARTICULAR PURPOSE OR USE.

In no event shall the SDOs be liable for errors contained herein or for indirect, incidental, special, consequential, reliance or cover damages, including loss of profits, revenue, data or use, incurred by any user or any third party. Compliance with this publication does not absolve manufacturers of equipment, from the requirements of safety and regulatory agencies (TÜV, BIA, UL, CSA, etc.).

Contents

Intended audience	4
Executive summary	4
Motivation and scope	4
Methodology: Risk-based approach	5
International Cybersecurity Standard IEC 62443	6
Industrial communication protocol context.....	6
Intended purpose and functions.....	7
Operational environment and architecture overview	8
Location in the network.....	8
Deployment recommendations and examples	9
Physical security / secure zone concept.....	10
Example #1 Complete Isolation (Ethernet and Non-Ethernet Industrial Protocol).....	12
Example #2 Gateway Protection (Ethernet and non-Ethernet Industrial Protocol).....	13
Example #3 Secure Protocol (Ethernet-based Industrial Protocol)	14
User description	15
User profile.....	15
Competence level	15
Regulatory context	15
Expected behaviour	15
Risk assessment.....	15
Conclusion and outlook.....	17
Possible topics for next version of this document	17
Annex A - Additional deployment examples.....	18
Example #4 Firewall/DPI Protections (Ethernet Industrial Protocol).....	18
Example #5 Security Appliances (Ethernet Industrial Protocol)	19
Example #6 Network Infrastructure Protections (Ethernet Industrial Protocol)	20
Definitions, abbreviations, references, version history.....	21

Intended audience

System integrators and product suppliers interested in learning how to deploy industrial communication protocols in a secure way based on a risk-based approach.

Assessors to provide base protocol security capabilities, general risk assessment and possible counter measures.

End users of industrial communication protocols, such as plant operators, who want to deepen their understanding of how to use these protocols securely.

Executive summary

Industrial communication protocols are a foundational element of modern process and factory automation, enabling interoperability, real-time control, and efficient device integration. However, many widely deployed protocols were not originally designed with cybersecurity as a primary objective. Although standards development organizations have been steadily adding security functionality to these protocols, there are still many deployments of legacy protocols that lack built-in security mechanisms such as authentication, authorization, integrity, and confidentiality.

To address this challenge, FieldComm Group, ODVA, OPC Foundation, and PROFIBUS & PROFINET International have collaborated to establish a shared operational environment and architecture overview for industrial communication protocols in alignment with EN 40000-1-2 [1]. This publication applies a structured risk-based methodology to assess cybersecurity risks associated with commonly used industrial communication protocols and to define appropriate mitigation strategies.

The assessment confirms, that in many cases, the use of industrial protocols relies heavily on additional compensating controls provided by the operational environment. Even as Ethernet-based protocols such as EtherNet/IP, PROFINET, OPC UA, and HART-IP offer enhanced security profiles, their usage depends on the risk assessment and operational environment of the end user.

This document provides security analysis for plant environments using industrial protocols with a variety of controls and additional compensating controls, helping manufacturers, system integrators, and end users make informed decisions on protocol usage. The key conclusion is that cybersecurity for industrial communication protocols must be addressed holistically, combining protocol-level security capabilities with robust operational environment controls to achieve resilient and compliant industrial automation systems.

Motivation and scope

The four Standards Development Organizations (SDO), FieldComm Group, ODVA, OPC Foundation, and PROFIBUS&PROFINET International, have joined forces to strengthen cyber resilience in industrial automation and control systems. Note that for industrial protocols which are not maintained by these four SDOs this whitepaper makes no explicit claim, but the information here is likely generalizable to other industrial communication protocols.

This whitepaper aims to define a shared product operational environment and architecture overview for industrial communication protocols in alignment with the EN 40000-1-2 [1].

By establishing a common understanding of how to securely deploy and use industrial protocols, this document helps:

- Manufacturers can better understand the security risks associated with using industrial protocols.
- Assessors to rely common understanding of communication technology feasibilities.

- System integrators and end-users implement protocols in a way that ensures operational security and regulatory compliance.

The recommendations presented here combine protocol-specific security features with additional compensating controls in the operational environment, forming a holistic approach to mitigating cybersecurity risks.

This whitepaper also aims to address how these protocols are expected to be developed and used considering the **Annex I requirements of the Cyber Resilience Act**. There are many requirements in Annex I, however, the focus for this paper is on requirements regarding authentication and protection of data in transit, as industrial protocols are directly implicated in these. Other requirements, such as logging, may also be relevant depending on the protocol, however, that is not addressed in this paper. The CRA applies to products, not the protocols themselves. Consequently, many CRA requirements are product-specific and remain mandatory regardless of which communication protocols a product implements. Furthermore, the usage of a communication protocol may vary from product to product which could affect the risk; therefore, the analysis done in this paper is necessarily generic and further analysis is necessary for any given product.

Industrial communication protocols in scope of this paper:

- EtherNet/IP
- PROFINET
- OPC UA
- HART-IP
- WirelessHART
- FOUNDATION Fieldbus
- PROFIBUS PA
- IO-Link
- HART 4-20mA
- DeviceNet

Methodology: Risk-based approach

The cybersecurity principles and risk-based approach of the EN 40000-1-2 [1] is followed for the usage of the industrial communication protocols in scope. According to the EN 40000-1-2 the risk-based approach includes:

- Establishing the product context
- Risk assessment
- Risk treatment
- Risk communication
- Risk monitoring and review

In the following sections the main results of the risk-based approach to industrial communication protocols are documented. For clarity, the term "product" (as defined in EN 40000) has been

replaced with "industrial communication protocol". Additionally, the "magnitude of potential loss" is referred to as "impact".

International Cybersecurity Standard IEC 62443

IEC 62443 is the international standard series that provides a complete framework for cybersecurity of Industrial Automation and Control Systems (IACS). IEC 62443 is deliberately **risk-based** and **lifecycle-oriented**. It requires a structured risk assessment to determine the appropriate Security Level (SL 1–4) for each zone and conduit, then applies only the controls necessary to achieve that level using the seven Foundational Requirements (Identification & Authentication Control, Use Control, System Integrity, Data Confidentiality, Restricted Data Flow, Timely Response to Events, and Resource Availability).

IEC 62443 is not a standard that applies only to asset owners or operators—it is explicitly designed as an **encompassing ecosystem of responsibilities shared across the entire supply chain as shown in Figure 1**. Different parts of the standard series are targeted at different roles:

- **IEC 62443-2-x** → Policies, processes, and requirements for **asset owners and operators**
- **IEC 62443-3-x** → System-level requirements for **integrators and solution providers**
- **IEC 62443-4-x** → Component-level requirements (including secure development lifecycle) for **product suppliers and manufacturers**

This deliberate partitioning ensures that **every party**—owner-operator, service provider, system integrator, and product supplier—has clear, mandatory obligations. Security is treated as a shared responsibility from product design through decommissioning.

Zone Conduit Model

The cornerstone of IEC 62443 system-level security is the Zones and Conduits model (defined in IEC 62443-3-3 and IEC 62443-1-1). A Zone is a logical or physical grouping of assets that share common security requirements, trust level, and risk exposure. A Conduit is a secure communication path that connects zones (or assets within a zone) while enforcing the required security policies for that connection. The model forces explicit identification of trust boundaries: assets inside the same zone are assumed to trust each other to the degree required by the zone's Security Level, while every conduit must implement controls sufficient to protect against threats crossing that boundary.

Industrial communication protocol context

For industrial communication protocols the intended purpose is connecting field devices with control systems in process and factory automation. While they share the common goal of enabling configuration, diagnostics, and data exchange, they differ from a technological side:

- **Ethernet-based industrial communication protocols** leverage standard Ethernet and TCP/IP for control and motion applications. Industrial protocols in this category are:
 - EtherNet/IP
 - OPC UA
 - PROFINET
 - HART-IP
- **Non-Ethernet based industrial communication protocols** can include point-to-point communication that combines analog 4-20 mA or binary signals with digital signals with digital communication or fieldbuses that use proprietary transportation and protocol layers for fully digital bus communication. Industrial protocols in this category are:

- HART
- IO-Link
- FOUNDATION Fieldbus
- PROFIBUS
- DeviceNet

Note that in many cases there will be Second Channel Protocols that allow operations such as configuration, diagnostics, etc. An example of this is a field device which implements HART but also has a Bluetooth interface for configuration. Second Channel Protocols carry their own unique risks which need to be assessed and appropriately mitigated, per a risk assessment. However, Second Channel Protocols are not within the scope of this paper.

Together, these protocols form the backbone of modern industrial automation, ensuring interoperability, real-time data exchange, and efficient device integration across diverse environments.

Intended purpose and functions

These industrial communication protocols are in a wide variety of environments and applications. They are commonly used in industries such as but not limited to these:

- Water/wastewater
- Food/beverage
- Power/energy
- Life sciences
- Chemical
- Oil/gas
- Primaries/metals
- Packaging
- Tooling machines
- Robots
- Automotive manufacturing

Given the wide variety of industries in which these protocols are used with the intended purpose for different environments and applications the protocols typically have similar use cases such as:

- Control of motion of physical systems such as motors and robotic arms
- Transmission of safety relevant data
- Configuration of industrial equipment for a particular machine or application
- Exposure of diagnostic information
- Cyclic real time data exchange that reflects (input) or impart (output) some physical characteristic on a system like temperature, pressure, etc.

Misuse to Avoid:

The following actions are considered misuse and may lead to hazards:

- Operating the product for purposes other than those intended.
- Ignoring safety warnings or removing protective components.
- Using the product in extreme conditions beyond those specified.
- Install the product in operational environment that aren't protected by physical access controls.

Industrial communication protocols are deployed in a wide variety of systems and industries. Those communication protocols are typically used at levels 0–2 of the Purdue model, and occasionally at higher levels. Their use spans communication within a machine, between

Copyright © 2026 FieldComm Group., ODVA,
OPC Foundation and PROFIBUS Nutzerorganisation e.V. All rights reserved.

machines, and throughout process industry plants. Typical use cases are controlling physical motion or processes in plants, e.g., a motor controlling a press. An interconnected system could have anywhere from two nodes up to hundreds of nodes with routable communication.

Operational environment and architecture overview

In this section the operational environment of industrial communication protocols is described and examples are given. This includes the reasonable usage regarding the location of industrial communication protocols in the architectures such as the Purdue model and an Industrial Internet of Things (IIoT) model, and assumptions regarding available protection mechanisms within the plant installation (e.g., firewalls or physical access restrictions).

Location in the network

Industrial protocols can exist in many locations within a network. One widely used method is to follow the Purdue Model, where there is strict segmentation of various levels, with the field devices being placed at the lowest level. This is discussed in various documents such as IEC 62443-1-1 [12], the NAMUR NA 169 [13], and the hierarchical classification of an IACS in accordance with 62443-1-1 [12]. In these approaches, networks are organized according to the levels of the Purdue Model. In most cases industrial protocols, especially the non-Ethernet ones, used in layers one and two within the Purdue Model. However, Ethernet-based industrial protocols are often used at higher levels, in some cases even including cloud connectivity.

Besides the Purdue Model, some industrial environments are organized in more of an IIoT scheme where industrial devices have wider connectivity, especially through the use of Ethernet-based industrial protocols. In this scheme, Ethernet routing is used to allow connectivity to PLCs, field devices, and other industrial nodes.

Most large installations don't strictly adhere to a given model; typical use is to have isolation and segmentation applied to some parts of the environment and connectivity applied to others. As such these models shouldn't be seen as strict categories but rather methodologies that can be mixed and applied as necessary for the end user, of course with an analysis of the risk trade-offs for usage of any model.

To this point, it can be instructive to think of industrial protocol usage not in the context of strict adherence to one model, but rather in the context of use cases that can be applied in either model. To that end, several use cases are presented in this paper. Note that these use cases are illustrative examples, rather than exhaustive lists of possibilities. Use cases may be combined, and the details can vary significantly with regard to the technologies used. The use cases are high-level and focus on showing a specific technical control for mitigating industrial protocol risk, therefore there are necessarily technical details about the deployment or environment left out of the use cases. However, it is the hope that these use cases provide some information on reasonable use of industrial protocols and the security properties thereof.




Figure 1 Typical industrial communication protocol architecture according Purdue Model

For more detailed industrial communication protocol architectures, please refer to the secure deployment guidelines of the respective industrial communication protocol.

Deployment recommendations and examples

Applications where industrial protocols are used can vary widely. However, each usage needs to consider the risk of the communication and apply appropriate additional compensating controls, specifically considering authentication and protection of data in transit. The Ethernet-based industrial protocols provide advanced security features directly within the protocol that can mitigate these risks directly and are recommended to be used when available. However,

environmental additional compensating controls can also be used to protect the data transmitted in these protocols, as shown in the examples. Non-Ethernet-based industrial protocols have different risk factors due to their nature, and it is recommended that these protocols are isolated to as small a network as feasible. If data is needed from these protocols in other networks, additional compensating controls like a secure gateway need to be applied to ensure protection of that data. In the future the SDOs will provide more detailed secure deployment guidelines for their industrial communication protocols.

Although each deployment of industrial protocols needs a threat model/risk assessment to be performed, the essential recommendations of this paper can be succinctly summarized as follows:

- For Ethernet-based industrial protocols, enable the built in security features per the risk assessment
- For non-Ethernet based industrial protocols, ensure that the network is sufficiently isolated to reduce risk to an acceptable level
- For a combined environment, enable built in security features on any gateway/bridge device that goes between Ethernet and non-Ethernet protocols so as to keep the non-Ethernet based industrial protocols sufficiently protected

Physical security / secure cell concept and examples for deployment are described below as well additional deployment examples in Annex A - Additional deployment examples.

Physical security / secure zone concept

All deployments of industrial protocols depend on physical security of the plant to be successful. It is not feasible for industrial devices to defend against a direct physical attack, and it is expected even under reasonably foreseeable use that the physical environment is secured against unfettered access by would-be attackers. The exact physical additional compensating controls will vary depending on the risk assessed by the user, but all deployments need minimally some physical barriers to accessing the industrial devices to prevent unfettered access. Even with significant security measures applied to the protocols themselves (e.g. CIP Security, OPC UA Security, PROFINET Class 2 and 3, etc.), physical security is still a risk that needs to be mitigated by environmental controls. As such it is assumed that only individually authenticated and authorized personnel of the end-user can access the operational environment and the third-party personnel can only access the plant with strict oversight of trained operator's end-user personnel.

	Physically secured plant environment
Measures and processes that prohibit the access of non-authorized personnel to an operational environment	Only individually authenticated and authorized personnel of the end-user can access the operational environment
Conduits: Conduits are controlled communication channels that connect different security zones. When implemented as an external counter measure, conduits ensure that data exchange between zones occurs in a secure and monitored manner	In place
Physical access to communications (e.g. physical access to the wires)	Restricted via physical boundaries
Components that support industrial protocols are physically protected e.g., locking doors/cabinets, surveillance, etc.	Yes

Table 1 Examples of physical counter measures for operational environments

Example #1 Complete Isolation (Ethernet and Non-Ethernet Industrial Protocol)




Figure 2 Complete Isolation (Ethernet and Non-Ethernet Industrial Protocol)

In this example the industrial network is completely isolated from any other network. In many cases this provides significant risk reduction, especially if the network is sufficiently small. The example given in the diagram shows several devices connected by a non-Ethernet-based industrial protocol. There is a connection to a gateway device, and through that gateway a connection to a PLC over an Ethernet-based industrial protocol. This network is quite limited (5 devices, a gateway and a PLC) without any connectivity to a larger network. Of course this is just one conception of an isolated industrial network, several variations would exist. However, it is important to keep in mind that a scheme like this depends heavily on the properties of the environment. That is, physical access must be restricted such that it is sufficiently difficult for an attacker to physically connect to the network as to render these attacks low risk. This can be achieved via protections such as security guards, badge access-controlled rooms, gates, monitoring systems, etc. Furthermore, the larger this network is made both in the sense of number of devices and physical distances of the network the more difficult it is to control access. Therefore, special care needs to be taken to ensure this technique is applied in an informed, risk-based manner. However, when it is used in this way it does provide significant risk reduction for authentication and data confidentiality and data integrity. That is, if an attacker cannot reach the network nor the devices on it then the attacker cannot launch attacks on the data or devices within the network.

Example #2 Gateway Protection (Ethernet and non-Ethernet Industrial Protocol)




Figure 3 Gateway Protection (Ethernet and non-Ethernet Industrial Protocol)

This example is like Example #1, but now data from the non-Ethernet industrial protocol network is exposed to a larger network via a gateway and routed/switched network. In this case the non-Ethernet industrial protocol network is still isolated as is with Example #1, but here the gateway is providing security functionality for access to the data on the non-Ethernet network. Note that the gateway can be implemented in a dedicated gateway device, or within a multipurpose device like a PLC; both of these are shown in the example in Figure #3. The gateway provides protections via a secure industrial protocol with a technology like TLS, using certificates as authenticators and applying data confidentiality and data integrity to any data transmitted on the Ethernet network. Again, this is simply an example, many variations of this scheme exist. However, the main idea here is that a gateway exists to provide security functionality on behalf of the non-Ethernet industrial protocol devices, allowing their data to be exposed on a larger network with sufficient protections.

Example #3 Secure Protocol (Ethernet-based Industrial Protocol)




Figure 4 Secure Protocol (Ethernet-based Industrial Protocol)

In this example the industrial devices are set up to use an Ethernet-based industrial protocol with the built-in protocol security measures enabled. This might be OPC UA security, EtherNet/IP with CIP Security, PROFINET with Class 2 or 3 security or HART-IP with security. The exact configuration options for any one of these given technologies will vary based on the specific use case, but they in this example they have been enabled to provide authentication for the industrial protocol, as well as protection of the data in transit. This provides very significant risk reduction and can be applied to a nearly any network design, as the industrial devices are self-defending and can operate in networks with varying levels of trust and additional compensating controls. Zones of trust can be set up however a user wishes, as each device has the capability to enforce trust per the user's design. For Ethernet-routed industrial communication, this use case represents the best case of device defence and can easily work in a zero-trust enabled environment.

User description

User profile

- User Type: Professional personnel for process and factory automation
- Environment: Process and factory automation
- Tasks: Installation, operation, maintenance, and decommissioning

Competence level

- Expertise: Trained in his/ her field of operation, e.g., in process control, safety regulations, and regulatory standards

Regulatory context

- Compliance: Strict adherence to internal guidelines

Expected behaviour

- Always acts according to internal guidelines
- Complies with safety and compliance requirements

Based on the user description, it is expected that industrial protocols are deployed securely according to the deployment recommendations of the SDOs.

Risk assessment

The threat risk assessments were executed based on the STRIDE [15] and DREAD [14] methodologies and can be requested for review for the industrial communication protocols at the respective SDO that hosts the technology. (see contacts at the end of this document).

The STRIDE methodology is a widely used framework for identifying and categorising threats during the risk assessment process. STRIDE stands for Spoofing, Tampering, Repudiation, Information Disclosure, Denial of Service, and Elevation of Privilege. Each category represents a different type of security threat, guiding the process of a comprehensive enumeration of threats.

The DREAD scoring system is used to score security threats. DREAD stands for Damage potential, Reproducibility, Exploitability, Affected users, and Discoverability. Each category is assigned a score, which are used to calculate the impact and likelihood of each identified threat.

The impact and likelihood scores assigned to each identified threat are subsequently used to determine the associated risk through a risk matrix.

Table 2 risk matrix

		Impact				
		Severe	High	Moderate	Low	None
Likelihood	Almost certain	Very high	Very high	High	Medium	Very low

Likely	Very high	High	Medium	Low	Very low
Possible	High	Medium	Medium	Low	Very low
Unlikely	Medium	Low	Low	Very low	Very low
None	Very low	Very low	Very low	Very low	Very low

Multiple risks scores are evaluated for each threat to investigate the mitigating effect of different measures.

All of the non-Ethernet-based industrial communication protocols lack basic security capabilities such as authentication, authorization, integrity, or confidentiality protection. Conversely, all of the Ethernet-based industrial communication protocols have robust security protections defined that include authentication, authorization, integrity, and confidentiality.

Non-Ethernet-based industrial protocols expected use is within an environment that is not routable or reachable by higher layers of the plant and therefore are isolated to a secured network. If data from these protocols is made accessible to larger networks with different security properties and risks, it is done through a product with gateway/network translation functionality, at which security controls can be implemented. Furthermore, Clause 55 of the Cyber Resilience Act [11] discusses how certain CRA requirements are not applicable to some products for the purpose of interoperability. These non-Ethernet-based industrial protocols rely on functionality without state-of-the-art security features like authentication or encryption for interoperability purposes. Therefore, the threat risk assessment counter measures for non-Ethernet-based industrial protocols relies heavily on other means than security measures implemented directly in these technologies. Additional compensating controls, like limiting the industrial communication protocol to trusted environments is described within the examples of this document.

Ethernet-based industrial communication protocols have specified security profiles that meet or exceed widely recognized mechanisms for product protection.

Examples are:

- EtherNet/IP with its security functionalities
- PROFINET with its security functionalities
- OPC UA with its security functionalities
- HART-IP with its security functionalities

The security protections of the Ethernet-based industrial protocols allow them to be used in a wide variety of environments with varying levels of risk. That is, why they can be used in environments with a significant number of additional compensating controls, or they can be used in environments with few additional compensating controls since they include security protections for the protocols themselves. Of course, it will be a decision of the plant owner/operator based on risk assessment what additional compensating controls to deploy and what protocol security functionality to configure.

The specification, implementation and market adoption of industrial ethernet security functionalities is not yet finished. Therefore, we recommend end users to treat industrial ethernet protocols without security functionalities the same way as non-Ethernet-based industrial protocols.

Conclusion and outlook

Industrial communication protocols form the backbone of modern automation systems, yet most of them were not originally designed with cybersecurity in mind. The risk assessments conducted in conjunction with this whitepaper confirm that many protocols lack inherent security features such as authentication, authorization, and data integrity protection.

While Ethernet-based protocols like EtherNet/IP, PROFINET, OPC UA, and HART-IP offer enhanced security profiles, legacy and fieldbus technologies remain vulnerable and require even more compensating measures than the Ethernet-based protocols at the operational environment level.

The key takeaway is that protocol security cannot be considered in isolation. A holistic approach combining protocol-specific security features with robust physical, technical, and organizational measures in the plant environment is essential. Concepts such as perimeter protection and zero-trust architectures will play a critical role in mitigating risks, especially for protocols without native security capabilities.

Looking ahead, the following developments are expected to shape the secure use of industrial protocols:

- **Alignment with regulatory frameworks:** The Cyber Resilience Act will drive harmonization of security requirements across Europe. Future guidelines will need to integrate CRA principles with IEC 62443 practices.
- **Evolution of protocol standards:** Standards Development Organizations are actively working on extending security functionalities for existing ethernet protocols and defining best practices for deployment.
- **Increased adoption of secure profiles:** Ethernet-based protocols with advanced security features will become more relevant in critical environments, reducing reliance on external additional compensating controls.
- **Operational environment hardening:** Plant operators will increasingly implement layered defense in depth strategies, including network segmentation, strict access control, and continuous monitoring.
- **Collaboration and knowledge sharing:** Continuous cooperation between SDOs, manufacturers, integrators, and end-users will be vital to ensure interoperability and maintain security across heterogeneous systems.

In conclusion, achieving secure industrial communication requires a shared responsibility model between protocol developers and plant operators. Future work will focus on refining security guidelines, developing reference architectures, and supporting industry stakeholders in implementing resilient solutions.

Possible topics for next version of this document

The Joint Working Group will follow up its work on this paper for a next version of this document.

Possible topics to work on are:

- Inclusion of the NAMUR Open Architecture concept
- Mapping of the Industrial Communication Protocols to Annex 1. ESSENTIAL CYBERSECURITY REQUIREMENTS of the Cyber Resilience Act

Annex A - Additional deployment examples

Example #4 Firewall/DPI Protections (Ethernet Industrial Protocol)




Figure 5 Firewall/Deep Packet Inspection Protections (Ethernet Industrial Protocol)

Another example of additional compensating controls includes an intelligent firewall that blocks traffic from entering a network with industrial protocol devices. This is again a variation on the idea of isolating the network, as the firewall provides isolation. Here the firewall does allow some traffic to traverse, but only pre-defined traffic deemed to be sufficiently low risk. An example of this might be only diagnostic data is allowed to traverse the firewall, but control and configuration data is blocked. In the diagram the industrial devices are using an Ethernet-based industrial protocol, but because of the security functionality and isolation provided by the firewall that usage is low risk, as it is infeasible for an attacker to reach these devices unless the firewall was defeated/removed.

Example #5 Security Appliances (Ethernet Industrial Protocol)




Figure 6 Security Appliances (Ethernet Industrial Protocol)

It is also possible for industrial protocols, especially the Ethernet-based ones, to be protected by an external device that provides the necessary security protocols functionality. As an example, a device like this might wrap the industrial protocol in a protective technology like IPsec or MACsec (note these technologies have different security properties and risk profiles). These devices fully protect the communication, covering authentication and protection of data in transit, for example via Certificates and data encryption/data integrity. This is a similar concept to the Gateway discussed in example #2, although in this example the security appliance provides functionality on behalf of a single industrial device. This can be extended to more than one industrial device, which is more similar to example #2, although in this case applied to Ethernet-based industrial protocols. For this example, the security appliance applies authentication and data in transit protection for the industrial protocol via wrapping it in IPsec, although as mentioned other technologies could be used. Again, it is important to ensure physical security of these devices, as an attacker with physical access could potentially re-wire the network to exclude the security appliances. However, with these protections the industrial protocol risk is significantly reduced.

Example #6 Network Infrastructure Protections (Ethernet Industrial Protocol)




Figure 7 Network Infrastructure Protections (Ethernet Industrial Protocol)

This example also relies on isolation, but in this case, there are additional compensating controls applied directly in the networking infrastructure itself. Here the switch provides functionality to isolate traffic via VLAN and also authenticates connections via 802.1X, although note that other technologies can achieve this same sort of protective scheme, these are just given as examples. That authentication might be tied to an identity management platform that the plant owner/operator controls. In this case the network with the Ethernet-based industrial protocol is again isolated and protected by additional compensating controls, here through the switch(es) itself. All ports and communication paths are either disabled or authenticated. This reduces the risk of the industrial communication, especially around authentication and protection of data in transit.

Old Examples before simplification

Definitions, abbreviations, references, version history

Term	Description
intended purpose	‘intended purpose’ means the use for which a product with digital elements is intended by the manufacturer, including the specific context and conditions of use, as specified in the information supplied by the manufacturer in the instructions for use, promotional or sales materials and statements, as well as in the technical documentation
reasonably foreseeable use	‘reasonably foreseeable use’ means use that is not necessarily the intended purpose supplied by the manufacturer in the instructions for use, promotional or sales materials and statements, as well as in the technical documentation, but which is likely to result from reasonably foreseeable human behavior or technical operations or interactions
Device, IACS Product	Defined within Class ABA751-Transmitter, ABD340-Final control element , ABN977-Infrastructure device, ABP397-Process analyser (and underlying products with digital elements) as described under IEC - Common Data Dictionary (CDD) Characterization.

Abbreviations

Term	Description
IACS	Industrial automation and control system
SDO	Standards Development Organization
PI	Profibus and Profinet International
OT	Operational Technology
SIS	Safety instrumented system
PLC	Programmable logic controller
DREAD	Damage, Reproducibility, Exploitability, Affected Users, Discoverability

References

-
- [1] EN 40000-1-2:2025-11 – Draft
Cybersecurity requirements for products with digital elements - Part 1-2: Principles for cyber resilience; English version prEN 40000-1-2:2025
Autor: Technical Committee CEN/CLC/JTC 13
Link: <https://www.dinmedia.de/en/draft-standard/din-en-40000-1-2/396310071>
-
- [2] Cyber security in the oil and gas industry based on IEC 62443
Autor: DNV GL
-
- [3] Whitepaper Anforderungen an sichere Steuerungs- und Telekommunikationssysteme
Autor: BDEW Bundesverband der Energie- und Wasserwirtschaft e.V.
-
- [4] Secure Architecture for Industrial Control Systems
Autor: SANS Institute
Link: <https://sansorg.egnyte.com/dl/6df6HbVkJFWcx>

[5]	IT-Sicherheitsleitfaden; Web-Applikation zum DWA-M 1060 Autor: DWA
[6]	Regulatory Guide - CYBER SECURITY PROGRAMS FOR NUCLEAR FACILITIES Autor: U.S. Nuclear Regulatory Commission
[7]	Practical Security Recommendations for building OPC UA Applications Author: OPC Foundation
[8]	Security Extensions for PROFINET – PI White Paper for PROFINET Autor: PNO
[9]	THE CIP NETWORKS LIBRARY Autor: ODVA, Inc.
[10]	OT-Security für Ethernet-APL – Architektur und Feldgeräte für den sicheren Betrieb Link: https://www.researchgate.net/publication/394838616_OT-Security_fur_Ethernet-APL_Architektur_und_Feldgerate_fur_den_sicheren_Betrieb Meurer, A.; Hout, F.; Merklin, S.; Floeck, M.
[11]	Cyber Resilience Act Autor: European Union Regulation - 2024/2847 - EN - EUR-Lex
[12]	Security for industrial automation and control systems – Part 1-1: Terminology, concepts and models Author: International Electrotechnical Commission Link: https://webstore.iec.ch/en/publication/7029
[13]	Automation Security Management in the Process Industry Autor: NAMUR
[14]	DREAD Threat Modeling: An Introduction to Qualitative Risk Analysis Author: EC Council Link: https://www.eccouncil.org/cybersecurity-exchange/threat-intelligence/dread-threat-modeling-intro/
[15]	The threats to our products Author: L. Kohnfelder and P. Garg Microsoft Interface, April 1999

Version history

Version	Date	Changes
Version 00.01	18.11.2025	Creation of the document
Version 00.02	08.12.2025 – 08.01.2026	Review by JWG members
Version 00.03	26.01.2026 -	Review by SDO members

FieldComm Group

www.fieldcommgroup.org

ODVA

www.odva.org

OPC Foundation

www.opcfoundation.org

Profibus and Profinet International (PI)

www.profibus.com

