A Configuration-Driven Architecture for Multi-Scene Industrial-Agent Integration

***Abstract*—Industrial-agent deployments must connect different agent engines to production scenes with distinct signals, protocols, and operating rules. A recurring integration challenge is to provide current process context while keeping device writes bounded and traceable. This paper presents a configuration-driven architecture for collaborative industrial agents. A harness registry decouples agent execution from named operations; scene configuration binds semantic acquisition and control nodes to protocol drivers, recipes, targets, limits, and guards. The runtime assembles the active line–product–recipe–run context at each turn, and write handlers apply shared dispatch checks, route-specific admission limits, conditional approval, and context revalidation. Device receipts and subsequent process observations remain separate records. Evaluation covered five simulator protocol families, a scene-onboarding replay, six registered-harness tasks, one OMP/Qwen trial on a Modbus thermal twin, mock approval tests, and four direct-node missions. Results show that independent device reads confirmed all three setpoints and a separate approved step was followed by a 2.71-degree Celsius rise in 40 seconds; the agent retrieved the matching platform sample. Both changes were in one run, so their contributions cannot be isolated. All four mission endpoints were within their target bands; all six separate harness probes remained below target. The architecture supports collaboration among registered agents, while these tests exercise single-agent paths. The evidence supports selected simulator integrations, not cross-engine generality, repeatability, causal process benefit, or physical-plant performance.**

***Index Terms*—Industrial agents, multi-agent systems, industrial automation, production context, industrial communication.**

I. Introduction

INDUSTRIAL-AGENT deployments must connect a changing process context to heterogeneous equipment without giving a language model unrestricted access to control points. A line-speed proposal, for example, depends on the active product, recipe, run, engineering limits, and node that represents the control. It must also reach the correct device through a configured protocol, and its receipt must not be confused with a later process response. When these elements are implemented separately for each agent and production scene, integrating a new engine or line requires repeating substantial interface and context work.

Recent research addresses end-to-end automation, control-sequence generation, modular factory skills, and robotic-line control [1]–[4]. Other studies examine agent-based supervision, programmable logic controller (PLC) code generation, context-aware control, resource discovery, shop-floor coordination, digital-twin fault handling, and natural-language machine access [5]–[10], [14]. Recent platforms also ground approved actions in Asset Administration Shell (AAS) models, verify proposals against process and instrumentation diagrams (P&IDs), or organize sensor–manufacturing execution system (MES)–enterprise resource planning (ERP) evidence streams [11]–[13]. Together, these works advance agent reasoning, industrial interfaces, action constraints, and production data integration.

The deployment problem addressed here is the connection between these layers: how to integrate multiple agent engines and roles with distinct industrial scenes, provide the active operating context to each task, and translate a proposal into a bounded, traceable device operation. We present a configuration-driven integration architecture rather than a new control law or optimization algorithm. Its central design choice is to keep agent execution, scene-specific signal and driver mappings, and device-write governance modular while connecting them through named industrial operations.

The contributions are threefold:

1) A scene-integration model binds production context (line–product–recipe–run), semantic acquisition and control nodes, protocol drivers, objectives, and engineering guards. Distinct processes can therefore be represented through configuration and a common operation interface, while protocol-specific access remains in drivers.
2) A collaboration runtime registers harness adapters for different agent engines, assembles current production context at each agent turn, and scopes the available operations to channel policy and resource bindings. Task-based execution and direct-operation entry are connected to the same dispatch design; the paper distinguishes this implemented architecture from the narrower routes exercised in the experiments.
3) A governed write path combines shared dispatch checks with route-specific admission, conditional human approval, post-approval context revalidation, and device-side receipt grading. Owning services retain command receipts separately from later process observations.

Fig. 2 presents the architecture and its module boundaries; Fig. 1 follows one task proposal through operation dispatch, device access, and evidence capture. Evaluation covers five simulator protocol families, a scene-onboarding replay, one agent-mediated Modbus TCP trial on a thermal process twin, six registered-harness tasks, a mock-driver approval-context test, and four separate deterministic missions spanning molding, film, annealing, and wastewater. These checks address different claims and are not pooled as repeated trials. The agent-mediated test establishes one supervised integration chain; the four missions show selected scene-specific operation paths. Neither validates all agent–scene combinations or establishes physical-plant performance.

Section II reviews related work. Section III presents the system architecture and execution flow. Section IV explains

agent context, scene integration, and governed device access. Section V reports the protocol, onboarding, agent-task, approval, and process-mission evidence. Sections VI and VII discuss the findings and conclude the paper.

II. Related Work

Table I summarizes reported mechanisms and evaluation settings for selected plant-facing systems. It supports positioning rather than a matched performance comparison or an exhaustive implementation survey.

A. Industrial Agents and Plant Integration

Industrial-agent systems address control at several levels. A large language model (LLM) framework for end-to-end automation [1] and control generation for industrial cyber-physical systems [2] complement agent-based supervision [14], PLC code generation, and human–LLM control [5], [6]. Manufacturing studies also explore resource capabilities [7], shop-floor coordination [8], and digital-twin fault handling [9]. Natural-language machine access [10] and real-time LLM control of a robot-operated line [4] extend this work to operator interfaces and robotic-line control.

Xia et al. connect cognitive, digital-twin, and physical-automation layers and organize twin information as state snapshots, event messages, and plan sequences [15]. Other nearby designs expose factory-module operations through the Model Context Protocol (MCP) with state-based tool filtering, constrain manufacturing plans, or compose semantic recipes from OPC Unified Architecture (OPC UA) skills [3], [16], [17]. Several recent systems also combine agent execution with approval, industrial data, or audit records. Graul et al. ground proposals in the Asset Administration Shell (AAS) and route approved actions through OPC UA Methods, with signed approvals and audit logging [11]. Schall separates advisory language-model agents from process and instrumentation diagram (P&ID)-grounded verification and execution, and evaluates structural checks across five simulated process scenarios [12]; its context includes supervisory control and data acquisition (SCADA) and standard operating procedure (SOP) information. Lin and Chen build a governed sensor–MES–ERP digital thread for closed-loop monitoring and control on real manufacturing records [13]. These systems address complementary parts of industrial-agent deployment, including process reasoning, asset grounding, action validation, and evidence organization. This paper focuses on the composition problem between those parts: connecting a collaborative task runtime and replaceable agent harnesses to scene-specific process context, semantic I/O mappings, and governed device operations. Its contribution is an integration architecture and implementation, not a new process-control law. Table I positions the reported mechanisms and evaluation settings; it is not a matched feature or performance comparison.

The operation checks complement safety-aware decision support [18] and operate alongside the plant's configured process protection.




Fig. 1. Task execution path from context to device and observation. The agent uses available acquisition and MES context to propose a named operation. Shared dispatch checks precede route guards and any required approval and context revalidation. Configured drivers provide device access; command receipts and later process observations are retained separately.

B. Production Context, Agent Interfaces, and Automation

Industrial integration also depends on abstractions that are not specific to agent architectures. The Model Context Protocol (MCP) specifies interoperable tool discovery and call mechanisms [19]. The platform dispatcher's operation-level scope, policy, grant, and binding checks are distinct from MCP transport authorization. In parallel, ISA-88 and ISA-95 describe recipes and production operations [20], [21]. Run-to-run methods connect process observations to successive production runs [22]. Human–automation research also formalizes the allocation of information acquisition, analysis, decisions, and actions between people and automation [23]. At the agent level, AgentSpec and CaMeL address tool behavior and capability-based information flow [24], [25]. These standards and mechanisms describe interfaces for production context, tool interaction, and information flow. The platform combines them in one deployment path: production context is supplied to the agent runtime, while semantic operations and device drivers remain scene-configured and write authority is checked at execution. The evaluation examines selected parts of that integration under simulator and mock-driver conditions.

III. System Design

The architecture connects two configurable sides of an industrial deployment: an agent collaboration runtime and a production-scene configuration. The runtime supplies task context and scoped operations; scene configuration maps process

TABLE I
REPORTED OPERATION MECHANISMS AND EVALUATIONS IN SELECTED PLANT-FACING STUDIES. EVALUATION SETTINGS AND OUTCOMES ARE SOURCE-SPECIFIC; THIS TABLE DOES NOT COMPARE PERFORMANCE ACROSS STUDIES.

System	Reported operation and evidence structure	Reported evaluation
Xia et al. [15]	Cognitive, twin, and physical layers; twin snapshots, event messages, and plan sequences	Robotic automation and process-simulation cases
Köhle et al. [3]	Injected live state and state-based filtering; MCP-to-OPC UA operations and Message Queuing Telemetry Transport (MQTT) coordination	Nine simulated production challenges
Vieira da Silva et al. [16]	Constrained multi-step plans over MCP manufacturing functions	Laboratory multi-step process
Köhle et al. [17]	Semantic recipes composed from OPC UA skills; virtual commissioning	Unity assembly-workstation proof of concept
Graul et al. [11]	AAS-grounded proposals, signed human approval, PLC-validated OPC UA Methods, and immutable audit log	Two laboratory PoCs; single scripted runs
Schall [12]	P&ID-, SCADA-, and SOP-grounded proposal verification with gated execution	Five simulated scenarios; 43 proposals and 50 LLM runs
Lin and Chen [13]	Governed sensor–MES–ERP digital thread with SOP-, risk-, and capability-aware action gating	25,275 real records; operational metrics
This work	Harness-independent collaboration runtime; scene-bound context and DAQ/DCW mappings; bounded named operations; separate command and observation records	Five-protocol simulator matrix; one agent-in-the-loop Modbus twin; six harness tasks; four single-trajectory missions




Fig. 2. Architecture and record ownership. Task/chat routes enter the collaboration runtime; direct REST and stdio-MCP calls enter shared dispatch checks without creating a task. One dashed link marks configuration. Write routes apply interval admission and, when configured, approval; recipe dispatch omits the previous-recipe window. The shared dispatcher always checks scope and channel policy, with grant and resource-binding checks applied when required by the operation. Owning services retain distinct records; plant controllers and safety systems retain equipment interlocks.

semantics to acquisition and control nodes, drivers, targets, and guards. Named operations connect these sides to shared dispatch and governed device access. The design separates task execution from operation dispatch and keeps command receipts distinct from measured process responses.

A. Design Rationale and Requirements

Five requirements shape the design: scene variability, harness variability, operation authority, outcome observability, and extensibility. Scene configuration binds production records and semantic DAQ/DCW nodes to drivers, objectives, and process guards. Harness adapters isolate agent-engine interfaces from named operations. Shared dispatch checks and

route-specific write limits govern authority, while service-owned task, receipt, and observation records preserve outcomes. Registered interfaces allow additional agent engines and device drivers to be integrated without changing the operation contract. Tool visibility alone does not authorize a write; all actuator writes pass through the DCW admission point.

Commissioning associates the line with products, recipes, active-run rules, signal meanings, units, driver mappings, and admissible limits. At runtime, the context builder assembles the active line–product–recipe–run state and relevant process summaries for each agent turn. An operation handler resolves live state again before dispatch, so the prompt context informs a proposal but does not substitute for current authorization or admission checks. Direct operations resolve the current context at invocation without creating a task.

B. Layered Architecture

Fig. 2 summarizes the access routes, shared dispatch path, production services, semantic I/O, configured drivers, and service ownership of records. Task and chat routes enter the collaboration runtime, which contains workspaces, channels, task queues, shared memory, mailboxes, task templates, and harness adapters. A *task route* is an execution path through this runtime; a *harness adapter* connects an agent engine to its task interface. Multiple registered agents can participate through shared tasks and channel context, with each agent's available tools constrained by its binding and channel policy. Direct REST tool calls and the stdio MCP operation bridge bypass task execution in that band (the upper-right direct-operation entry in Fig. 2) and enter the shared governance block without creating a task or starting a harness turn; MCP management and task methods remain on their service routes. Direct calls resolve current route state at invocation, without an agent-turn prompt or a task record. The governance block projects the operation catalog and applies the per-call checks. Write handlers apply admission limits and request approval when the operation and its configuration require it. The context block supplies the active line–product–recipe–run tuple to the gate and scene maps, objectives, and guards to the handlers. The dashed link from that block in Fig. 2 marks this configuration relationship; the runtime assembles prompt-time context from the same records. The service band, behind a route-handler interface that selects an adapter, provides acquisition, write control, analysis, retrieval, and optional model services. Field I/O resolves semantic nodes to built-in or plugin drivers for a plant or simulator. Services retain task, command, observation, and configuration records separately, linked to actor and production context.

C. Cross-Module Execution Flow

Fig. 3 summarizes a task turn from entry through operation execution, with route-specific evidence retained by owning services. Registered harness adapters receive a scoped tool catalog during setup and supported registry refreshes; the runtime assembles prompt-time production context from current records for each agent turn. For each returned tool call, the shared dispatcher rechecks invocation scope, channel policy, and applicable grant and binding conditions before handler selection. The selected handler then applies route-specific guards, active-run checks, approval revalidation, and device-I/O steps as applicable. Command receipts and later process observations remain distinct records.

For an industrial operation u by agent a in channel c, define the shared dispatch condition as

$$\mathcal{A}(a, c, u) = \bigwedge_{X \in \mathcal{C}(u)} X(a, c, u), \tag{1}$$

where S, P, G, and B denote invocation scope, current channel policy, applicable industrial grant, and the agent's binding to referenced resources, respectively. $\mathcal{C}(u) \subseteq \{S, P, G, B\}$ is the set of predicates declared for operation u; it always contains S and P. The grant predicate G is included when the resolved channel, target line, and owner/grant policy require it; explicit exemptions omit it. The binding predicate B is included when the operation declares resource references. A declared no-reference operation omits B. Each included check must pass before handler selection. The policy predicate includes channel tool selection, profile, and duty-separation checks where configured. Once these predicates pass, the selected route applies its guards, active-run checks, admission limits, and any required approval. When approval is required, the handler revalidates its context before device dispatch.

For direct REST invocation, the service establishes a and c before applying these checks: an agent token must match the requested agent identifier, or an authenticated user must be the channel owner or an administrator. The manager loads the channel-agent record and rechecks scope and policy; applicable grant and binding checks follow. Handlers resolve live production state from request identifiers and owning services.

Fig. 4 gives reference pseudocode summarizing the registered-harness task path. Direct REST tool invocation bypasses the task runtime and harness but enters the same shared dispatcher. Route-specific timing, approval, and evidence rules are detailed in Section IV.

IV. Module Functions and Integration

The architecture in Section III assembles task context, dispatches operations, and connects device access to separate records of commands and observations. The following subsections explain the handoffs between these functions.

A. Task, Harness, and Context

Task and chat entry points create or join a workspace channel. The task runtime manages membership, roles, task state, and shared execution context; a harness registry adapts agent engines to a common execution interface. This separation lets agents collaborate through shared tasks and channel resources without coupling their engine-specific turn protocol to a production scene. At each turn, the prompt builder assembles the task, active scene description, line–product–recipe–run state, channel profile, agent binding, and retrieved memory. The resulting context supports process-aware proposals, while the




Fig. 3. Registered-harness task flow. The runtime invokes the adapter with a scoped catalog. Scope and channel policy are checked for every call; grant applies to non-exempt industrial operations, and binding applies when resource references are declared. Failed checks return tool errors. The read path retrieves data. The write path applies route guards, conditional approval and its context revalidation, DCW admission, and receipt grading; a later process observation is separate. Results return to the harness. Device-level interlocks remain with the configured plant-control layer.

Require: task q, channel c, bound agent a, registered scoped catalog T
Ensure: task result; any retained evidence remains with its owning service
$x_t \leftarrow \textsc{ResolvePromptContext}(c, q)$
$m \leftarrow \textsc{RetrieveMemory}(q)$
$p \leftarrow \textsc{AssemblePrompt}(q, x_t, m)$
$h \leftarrow \textsc{InvokeRegisteredHarness}(a, p, T)$
for all tool request u returned by h **do**
  $g \leftarrow \textsc{CheckScopeAndChannelPolicy}(a, c, u)$
  if not g **then**
    $\textsc{EmitToolErrorToHarness}$(h,u); **continue**
  end if
  if u is an industrial operation **then**
    $v \leftarrow \textsc{CheckApplicableGrantBinding}(a, u)$
    if not v **then**
      $\textsc{EmitToolErrorToHarness}$(h,u)
      continue
    end if
  end if
  $k \leftarrow \textsc{SelectHandler}(u)$
  $r \leftarrow \textsc{ExecuteRouteHandler}(k, a, c, u)$ ▷ handler resolves live state and may persist route-specific records
  $\textsc{EmitDeclaredToolResultToHarness}$(h,r)
end for
return task state and tool results

Fig. 4. Reference pseudocode for the registered-harness task path. Direct operation calls use the shared dispatcher from their own entry point. Each route persists records through its owning service and returns its declared response to its caller; task-route results return to the harness.

dispatcher independently checks authority and the operation handler resolves current state before a write.

Direct REST and selected stdio-MCP operation calls reach the same dispatcher without a task or harness turn. REST authentication and identity resolution follow Section III-C; each handler reads live route state at invocation. Handlers receive the resolved actor, channel, and operation arguments through the same interface for either entry route; records are keyed by the identifiers supplied in each request. A registered task additionally receives prompt context and a scoped tool catalog. Catalog visibility alone does not grant write authority: the dispatcher checks authority at invocation.

B. Shared Dispatch and Device Admission

The dispatcher is the shared operation boundary. As specified by (1), it checks invocation scope and channel policy for every call, with grant and binding checks applied when required. These checks precede handler selection; handlers revalidate route-specific state at execution time. Scene configuration maps semantic signals and controls to drivers and specifies process objectives and guards. Capability profiles and tool policies narrow available operations, while resource bindings constrain accessible nodes, controls, and recipes. Optional DAQ, MES, analysis, retrieval, optimization, and digital-twin services are invoked through registered handlers. The application supplies its optimization strategy; the framework coordinates context, operation access, and execution.

The target band describes a desired process outcome. It is not the admissible write interval: the latter is computed from engineering, product, recipe, and route-specific limits below. A candidate can therefore satisfy all write constraints yet fail to move the measured process value into its target band.

Actuator writes converge on the shared DCW admission point. For an online node write, the admissible value interval is

$$\mathcal{I}_n^{\text{online}}(t) = \mathcal{H}_n \cap \mathcal{L}_n^{\text{base}} \cap \mathcal{L}_n^{\text{prod}}(t) \cap \mathcal{L}_n^{\text{rec}}(t), \qquad (2)$$

where $\mathcal{H}_n$ is the hard engineering range and $\mathcal{L}_n^{\text{base}}$, $\mathcal{L}_n^{\text{prod}}$, and $\mathcal{L}_n^{\text{rec}}$ are the baseline, active-product, and active-recipe limits; the $\mathcal{L}$ limits here are deliberately named apart from the policy and binding predicates of (1). Missing optional limits impose no restriction; an empty intersection rejects the request and identifies the excluding layer. Recipe dispatch validates the replacement recipe against the hard, baseline, and product limits rather than the previous recipe window. Step, interval, and hold-window checks apply as configured for each route. These application-level checks bound commands alongside independent programmable-logic-controller and safety-instrumented protection. They do not replace equipment interlocks or certify the safety of a plant deployment.

C. Approval, Execution, and Evidence

Routes add timing checks and, when required by operation and configuration, approval checks. Outside benchmark mode, online agent and manual node writes enforce a 60 s minimum interval between successful writes. Recipe trials use a per-line cadence (300 s by default), and recipe intervals are anchored to approval. Manual approval binds an actor and proposed operation to candidate values, applicable limits, expiry, and the active line–product–recipe–run tuple. After approval, the handler rechecks authority and compares the current tuple with the approved tuple before entering DCW dispatch. Single-parameter waits expire after 180 s by default; recipe-dispatch approvals use a 30-minute window. A changed recipe definition requires a new `recipe_apply` proposal.

Fig. 5(a) illustrates the four-layer interval in Eq. (2) using rotational-speed limits from a separate archived admission drill. Panel (b) shows the decision and rechecks when approval is required.

A `recipe_trial` illustrates the operation sequence: the handler checks the bound recipe, active run, candidate parameters, and route timing; if required, it requests approval; after revalidation, it submits a bounded batch through the configured driver and returns a per-parameter receipt. The caller can obtain later DAQ observations separately and may then update, apply, or roll back a recipe. A trial neither saves nor applies a recipe version. The driver registry maps semantic controls to configured protocol drivers, keeping protocol details out of agent operation arguments.

For a concrete illustration, consider a simulated coating line whose semantic line-speed control is mapped to a Modbus TCP write node. A request to change the setpoint from 37 to 39 m/min is inside a 28–48 m/min recipe window; the remaining applicable limits and timing checks must also pass. If the configured policy requires approval, the proposal binds the candidate and active production context, and the handler rechecks that context before dispatch. The driver then returns a graded receipt. A later acquisition sample is stored separately and can be associated with the operation when the route provides the necessary context and timestamps. This example illustrates the handoffs, not a recorded human decision or a particular process response; the simulator onboarding replay in Section V used test-only automatic approval.

Receipts and observations answer different questions. A command result is graded as readback-verified, transport-acknowledged, or unverified; a readback mismatch can trigger up to three reads at 2 s intervals. Recipe batches retain per-parameter verification outcomes. A readback-verified result records that the returned value matched the request; a transport acknowledgement alone does not establish that the device applied it, and an unverified result does not establish a matching readback. DAQ stores subsequent timestamped process observations, while recipe history, approvals, and task records remain with their owning services. Identifiers and timestamps can link these records when available, but a later observation alone does not prove that the command caused the measured change. Section V evaluates selected parts of this evidence chain under the stated test conditions.

V. Experimental Evaluation

The evaluation asks whether the architecture can connect configured industrial scenes and agent runtimes to protocol-level device operations while retaining evidence of authorization, writes, and process observations. Four evidence streams address different parts of this question: protocol and onboarding checks; one agent-mediated Modbus TCP run on a thermal twin; six registered-task trials and a separate approval-context test; and four direct-node missions in different process simulators. They are reported separately because they use different configurations and do not form a common benchmark.

A. Test Design and Evidence Rules

All process runs used local simulators rather than physical equipment. The agent-mediated thermal test used an actual Modbus TCP stack connected to a separate gray-box process simulator. The simulator represented first-order thermal inertia and delay; it was not calibrated to a production line. An independent Modbus client read the simulated device registers, providing a device-side check separate from the platform's own records. The run used one OMP harness with a local Qwen model in a manual-approval channel. The retained task and tool-call records do not include the model provider's raw request and response, so they support the execution sequence but not an independent audit of the model's reasoning.

The four process missions used deterministic, scenario-specific routines with a fixed seed and the direct-node interface; no language model selected their setpoints. Each mission contributes one trajectory. Its initial observation is a within-trajectory reference, not an independent control. A requested setpoint is an action, not a device readback, and a later process value is an observation rather than proof that a preceding action caused the change. The registered-harness tests used one engine across two simulator scenes; their three tasks per scene shared a simulator instance. Their post-trial samples were explicit driver probes stored through a local SQLite fallback because the isolated online queue and time-series service were




Fig. 5. Admission and approval boundaries. (a) Illustrative rotational-speed limits from a separate archived drill. The hard-limit track spans 50–200 rpm; the lower axis expands its 140–160 rpm segment. Online writes use the intersection in Eq. (2); recipe dispatch omits the previous recipe window. (b) When approval is required, a decline prevents dispatch; approval is followed by authority, context, and limit rechecks.

unavailable. Full runtime snapshots were not retained for these tests or the four missions.

The protocol matrix, agent-mediated twin, registered-harness tasks, mock-driver test, and process missions use separate configurations. Each result is interpreted within its own test boundary; no outcomes are pooled.

B. Protocol Integration and Scene Onboarding

The protocol matrix connected simulator endpoints through Modbus TCP, Modbus RTU, OPC UA, MQTT, and HTTP. The platform acquired data from five acquisition nodes and exposed four control nodes. Each protocol produced between 15 and 29 samples that matched simulator-side values within the recorded tolerances. Batch-write checks over four protocol families were confirmed by device-side and platform readback. Values outside an engineering range and single-step limit were rejected without changing the simulated device. An OPC UA disconnection produced a failed connection and write result; after service recovery, a write completed with verified readback. These checks used simulated endpoints with real protocol drivers and do not validate a physical controller or production security configuration.

A separate onboarding replay configured a simulated Modbus TCP device with four control and seven acquisition nodes, plus scalar, vector, table, and image forms from an MES simulator. All seven acquisition nodes yielded samples, four invalid writes were rejected, and four legal writes were confirmed by readback. The replay passed 23 verifier checks; its image data used a local-storage fallback. In a separate BOPET configuration, nine devices exposed 49 signals (30 setpoints and 19 measurements), and four requests addressed three control nodes. These examples show the configuration work needed to map a scene into the common interface; they do not establish zero-effort onboarding.

C. Agent-Mediated Modbus Trial on a Thermal Twin

The end-to-end test configured one acquisition node and three control nodes over Modbus TCP against an isolated extrusion/casting thermal twin. The agent queried the node inventory, active line context, and process data, then submitted a three-zone recipe trial. Its proposed setpoints changed from 198 to 200 °C; after manual approval, the external Modbus client confirmed all three device registers at 200 °C, matching the platform receipt. The task trace includes an initial acquisition request with an invalid time bound; a later request succeeded. The system therefore completed the governed write path despite a recoverable tool-call error.

A distinct, manually approved follow-on batch changed all three setpoints from 200 to 205 °C. Independent register reads and platform readback confirmed all three values. In the 40 s observation window after this change, the twin's process value rose from 198.02 to 200.73 °C. The platform's corresponding acquisition samples changed from 198.41 to 200.49 °C, and the agent later retrieved 200.49 °C, matching the platform record. The agent-proposed and manually approved changes occurred in one continuous thermal run without an isolated baseline between them. The record therefore cannot separate residual contributions from the 198-to-200 °C trial and the later 200-to-205 °C step. The report records 21 of 21 assertions passing, but this is one simulator run without repeated trials, a matched controller, or a calibrated process model.

D. Registered-Harness Tasks and Approval Context

A separate registered harness, configured with `glm-5.3-flash`, executed six sequential tasks across two simulated scenes. Each task supplied a current control read, a process measurement, a target band, and three candidate settings prevalidated against the configured engineering range and step. In the film scene, candidates were 125, 130, and 135 rpm; in annealing, they were 735,




Fig. 6. Pre-task observations and single post-trial probes for six registered-harness tasks in two simulated scenes. Shading denotes the target band; task numbers indicate order within each scene. Dashed connectors pair observations within a task, and vertical offsets separate markers without changing measured values. The connectors are not a time series. The runner waited 20 s after receipt and readback before each probe. Tasks in each scene shared one simulator instance; synthetic approval and a local SQLite fallback were used.

TABLE II
SEPARATE ACTIONS AND OBSERVATIONS IN THE AGENT-MEDIATED THERMAL-TWIN TEST.

Stage	Device-side evidence	Process and data evidence
Agent trial	Three zones: 198 to 200 °C; manual approval; 3/3 register readbacks	Agent queried context and DAQ; trial receipt retained
Follow-on step	Separate manual approval; three zones: 200 to 205 °C; 3/3 register readbacks	Twin value: 198.02 to 200.73 °C in 40 s; platform and agent sample: 198.41 to 200.49 °C. Both changes were in one run; residual effects cannot be separated.

TABLE III
PRIMARY PROCESS VALUES IN FOUR SEPARATE SIMULATED MISSIONS. EACH ROW IS ONE TRAJECTORY; THE FINAL VALUE IS THE MISSION-REPORTED VALUE.

Scene	Target band	Initial → final
Injection	Part weight: 32.15–32.85 g	31.296 → 32.36 g
Film	Thickness: 24.3–25.7 μm	28.03 → 25.30 μm
Annealing	Hardness: 89–101 HV	134.9 → 99.5 HV
Wastewater	Dissolved oxygen: 2.8–4.0 mg/L	0.194 → 3.54 mg/L

740, and 745 °C. The target bands were not pre-verified. With synthetic administrator approval, each task retained an approved proposal, recipe-trial record, 1/1 verified device receipt, and run-tagged sample. The runner waited 20 s after receipt and readback before probing the driver. Fig. 6 pairs each task's pre-task measurement with its single post-trial probe. All six probes were below their target bands: the three film values were 45.69, 46.69, and 45.69 μm against 48–52 μm; the three annealing values were 679.60, 677.70, and 678.10 °C against 700–760 °C. The records show successful task and write handling, not successful process optimization. Independent model-provider logs were not retained.

Separate fixed-call checks exercised a registered task and a direct REST operation in each scene, each in an isolated environment with synthetic approval. Both returned verified trial receipts and run-tagged samples. The task route also retained a task–approval–receipt–sample link, but task completion was not asserted. The checks did not trace both calls through the same handler and therefore do not establish route equivalence.

An independent component test used simulated approval decisions and a mock driver. For recipe application, trial, and rollback, it changed each of the line, product, recipe, and active-run fields after proposal; all stale contexts were refused before mock writes. A further change between authorization revalidation and the final context check was also refused. An unchanged context produced the expected mock writes, while a declined proposal produced none. In a test-only ablation that removed tuple comparison, six product or run changes reached the mock driver and each produced two writes; line and recipe changes remained blocked by other checks. This isolates the tested product/run protection within the component setup, not operator effectiveness or physical safety.

E. Direct-Node Missions Across Four Process Scenes

Table III reports the primary process value from each of the four deterministic missions. Each mission used a distinct simulated process and one trajectory; the agent-mediated test and harness tasks above used different setups and are neither controls nor repetitions of these missions.

The injection-molding routine targeted 32.5 ± 0.35 g. Holding pressure changed from 45 to 57.73 bar and holding time from 6 to 10.56 s; after a further pressure request to 62 bar, part weight reached 32.36 g. The single sequence does not isolate either parameter's effect. In BOPET, four requests changed casting speed, fast-roll speed, rail width, and casting speed again; thickness moved from 28.03 to 25.30 μm against a 25.0 ± 0.7 μm target. Reported melt temperatures remained within the 268–300 °C window.

The annealing routine targeted 95 ± 6 HV. A zone-2 temperature request from 710 to 850 °C and a speed change

from 140 to 152 m/min preceded observations of 99.18 and 99.74 HV. A 164 m/min candidate was reverted after event text reported 101.0 HV; the mission summary gave final hardness of 99.5 HV and retained speed of 152 m/min, not a measured throughput gain. Final tensile-strength and surface-defect measurements were not archived. In wastewater, five blower increases from 26 to 34.1 Hz accompanied the rise in the structured DO sequence from 0.194 to 3.567 mg/L; subsequent dosing was followed by total-phosphorus readings of 0.5507, 0.4607, and 0.413 mg/L, from 0.662 mg/L. The summary reported final DO of 3.54 mg/L and a simulator-defined cost index of 180.2, down from 182.6; it is not a measured operating cost. The final effluent vector was not archived.

F. Evidence Synthesis

The protocol matrix and onboarding replay demonstrate configured access to heterogeneous simulator interfaces. The thermal-twin test joins agent context retrieval, approval, a bounded Modbus write, independent device readback, and subsequent acquisition in one supervised run. Separately, six registered-task trials retained verified receipts but all single probes remained below target; the four direct-node missions each reported one primary endpoint within its target band. The approval ablation isolates a specific stale-context check. Together, these results support the feasibility of the implemented integration paths and scene configurations. They do not establish cross-agent or cross-scene performance, repeatability, causal benefit of individual control actions, operator effectiveness, or transfer to a physical plant.

VI. Discussion

A. Interpretation

The principal contribution is the integration architecture: scene-specific industrial context and I/O mappings connect to a collaboration runtime through named operations, while write authority and evidence capture remain explicit at execution. The protocol matrix and onboarding replay show that configured drivers can expose heterogeneous simulator endpoints through this interface. They do not show that arbitrary equipment can be added without engineering or that different production scenes require no adaptation.

The agent-mediated thermal-twin run supplies the most complete execution trace. The agent accessed current line and process context and proposed a bounded recipe trial; manual approval preceded device writes, and independent register reads matched the recorded setpoints. A later, separately approved step was followed by a process-value change that returned through acquisition and was retrieved by the agent. This supports integration of context, authorization, device access, and observation in one supervised configuration. The 2.71 °C change was recorded after the later manual step, but both parameter changes occurred in one continuous run without an isolated baseline. Their residual contributions cannot be separated, and the single gray-box simulation does not establish a control law's effect or industrial process fidelity.

The other process evidence answers different questions. Six registered-task trials retained verified write receipts, but each single probe remained below its target band. Four direct-node missions in distinct simulators reported primary endpoints within their respective bands. These outcomes are neither pooled nor comparable: they used different scenes, interfaces, routines, and measurements. In particular, the mission endpoints do not serve as a baseline for the harness probes, and none of the single trajectories identifies the effect of an individual parameter change.

The harness registry and scene configuration provide extension points for multiple engines and production settings. Tests exercised one agent at a time and did not cover all agent–scene combinations, concurrent cross-line coordination, or commissioning effort; no reuse or scalability benefit is measured.

B. Scope and Limitations

All process evidence comes from local simulators. The thermal twin is a gray-box model with first-order inertia and delay, not a validated physical process model. The four process missions each provide one deterministic trajectory without independent replications or a matched controller. They cannot establish statistical repeatability, comparative benefit, or causal effects of individual actions. The full runtime snapshots and continuous raw device trajectories were not retained for every run; the agent log also lacks independent model-provider request and response records. The retained evidence therefore supports selected integration events and summary measurements, not complete replay of all experiments.

The process missions do not test model-generated setpoint selection. The registered-harness checks use synthetic approval; the thermal-twin run uses a manual approval path but only one configuration. The mock-driver approval test examines stale-context rejection, not operator decision quality, human-review effectiveness, or behavior under all network and device faults [26], [27]. Final tensile-strength and surface-defect readings for annealing and the full final wastewater effluent vector were not archived, so those records cannot verify every quality or discharge constraint. Software checks are not a complete security or safety assessment; site-specific protocol security, credentials, device protection, and independent PLC or safety-instrumented interlocks remain necessary [28]–[31].

Further evaluation should repeat the process missions across initial conditions, retain full device and model traces, compare matched controllers and entry routes, and test multiple agent engines and scene configurations under operator oversight on appropriate industrial equipment. Until then, the results support integration feasibility under the tested configurations, not field performance, reduced commissioning cost, or autonomous operation.

VII. Conclusion

This paper presented a configuration-driven architecture that connects collaborative agent runtimes and per-turn production context to scene-specific acquisition and control mappings.

Named operations pass through shared dispatch and route-specific write limits; applicable approvals are followed by context revalidation, and device receipts remain distinct from later process observations.

Evaluation covered five simulator protocol families, scene onboarding, a supervised Modbus-twin trial, six registered-harness tasks, mock-driver approval checks, and one direct-node mission in each of four process simulators. Independent reads verified the twin's setpoints; a later process observation was retrieved by the agent, although the single continuous run cannot isolate the two sequential actions' residual effects. All six harness probes remained below target, while each mission reported one endpoint within its target band. The evidence supports selected integration paths, not repeatable process benefit, multi-agent generality, human-review effectiveness, or physical-plant performance.

Data Availability: Historical Supplementary File S1 contains earlier route and integration records and an onboarding replay, but not the current four-mission source trajectories. A separate evidence bundle contains pseudonymized mission logs and selected harness records. Supplementary File S2 summarizes the agent–twin run; it is not a full replay package. The manuscript source and vector figures accompany the submission package. No physical-plant data are included.

REFERENCES

[1] Y. Xia, N. Jazdi, J. Zhang, C. Shah, and M. Weyrich, "Control industrial automation system with large language model agents," in *Proc. IEEE 30th Int. Conf. on Emerging Technologies and Factory Automation (ETFA)*, 2025, pp. 1–8, doi: 10.1109/ETFA65518.2025.11205539.

[2] K.-C. Huang, H.-T. Lin, C.-H. Lin, and M.-T. Huang, "Large language model integration in industrial cyber-physical systems: A multi-modal architecture for automated control generation," in *Proc. Int. Conf. on Control, Automation and Diagnosis (ICCAD)*, 2026, pp. 1–6, doi: 10.1109/ICCAD69956.2026.11643124.

[3] K. Köhle, D. Anicic, T. A. Runkler, and R. Graf, "LLM-driven multi-agent control for skill-based smart manufacturing," in *Proc. IEEE 31st Int. Conf. on Emerging Technologies and Factory Automation (ETFA)*, 2026, pp. 1–8, doi: 10.1109/ETFA68377.2026.11725257.

[4] M. Waseem, K. Bhatta, C. Li, and Q. Chang, "Pretrained LLMs as real-time controllers for robot operated serial production line," *Mach. Learn.: Eng.*, vol. 2, no. 1, 2026, art. no. 015006; doi: 10.1088/3049-4761/ae4ee8.

[5] Z. Liu *et al.*, "Agents4PLC: Automating closed-loop PLC code generation and verification in industrial control systems using LLM-based agents," *IEEE Trans. Softw. Eng.*, vol. 52, no. 5, pp. 1672–1687, 2026, doi: 10.1109/TSE.2026.3667895.

[6] R. Wu, J. Ai, and T. Li, "InstructMPC: A human-LLM-in-the-loop framework for context-aware control," in *Proc. IEEE 64th Conf. on Decision and Control (CDC)*, 2025, pp. 172–179, doi: 10.1109/CDC57313.2025.11312156.

[7] J. Lim and I. Kovalenko, "A large language model-enabled control architecture for dynamic resource capability exploration in multi-agent manufacturing systems," in *Proc. IEEE 21st Int. Conf. on Automation Science and Engineering (CASE)*, 2025, pp. 2088–2095, doi: 10.1109/CASE58245.2025.11163802.

[8] Z. Zhao *et al.*, "A large language model-based multi-agent manufacturing system for intelligent shopfloors," *Adv. Eng. Inform.*, vol. 69, 2026, art. no. 103888; doi: 10.1016/j.aei.2025.103888.

[9] M. S. Gill, J. Vyas, A. Markaj, F. Gehlhoff, and M. Mercangöz, "Leveraging LLM agents and digital twins for fault handling in process plants," in *Proc. IEEE ETFA*, 2025, pp. 1–8, doi: 10.1109/ETFA65518.2025.11205597.

[10] B. Hofmann, N. Piechulek, S. Kreitlein, J. Franke, and P. Bruendl, "Beyond touch-based human-machine interface: Control your machines in natural language by utilizing large language models and OPC UA," *arXiv preprint arXiv:2510.11300*, 2025. [Online]. Available: https://arxiv.org/abs/2510.11300v2

[11] C. Graul, W. Żarski, D. Mikołajewski, and I. Rojek, "Ai agents in industry 4.0: AAS–OPC UA–LLM architecture as the foundation of intelligent manufacturing systems in the context of industrial enterprise implementation," *Applied Sciences*, vol. 16, no. 11, p. 5428, 2026, doi: 10.3390/app16115428.

[12] D. Schall, "Safe integration of large language models into industrial process control: A multi-agent architecture with P&ID-grounded validation," *Autonomous Intelligent Systems*, vol. 6, 2026, article no. 14; doi: 10.1007/s43684-026-00136-1.

[13] S.-C. Lin and C.-Y. Chen, "An integrated framework featuring policy-governed agentic AI for closed-loop manufacturing control with multi-source sensor–MES–ERP," *The International Journal of Advanced Manufacturing Technology*, vol. 143, pp. 6405–6428, 2026, doi: 10.1007/s00170-026-17806-2.

[14] A. Biskupovic, A. Villalonga, F. Castaño, R. E. Haber, and F. Núñez, "Agent-based supervision for service-oriented industrial cyber–physical systems," *IEEE Trans. Ind. Inform.*, vol. 21, no. 3, pp. 2719–2728, 2025, doi: 10.1109/TII.2024.3514178.

[15] Y. Xia, N. Jazdi, and M. Weyrich, "An architecture for integrating large language models with digital twins and automation systems," in *Proc. IEEE 30th Int. Conf. on Emerging Technologies and Factory Automation (ETFA)*, 2025, pp. 1–8, doi: 10.1109/ETFA65518.2025.11205636.

[16] L. M. Vieira da Silva, A. Köcher, and F. Gehlhoff, "Beyond formal semantics for capabilities and skills: Model context protocol in manufacturing," in *Proc. IEEE 30th Int. Conf. on Emerging Technologies and Factory Automation (ETFA)*, 2025, pp. 1–4, doi: 10.1109/ETFA65518.2025.11205601.

[17] K. Köhle, D. Anicic, T. A. Runkler, K. Dorofeev, A. S. Thuluva, and R. Graf, "Virtually commissioned semantic recipes based on OPC UA skills," in *Proc. IEEE 8th Int. Conf. on Industrial Cyber-Physical Systems (ICPS)*, 2025, pp. 1–6, doi: 10.1109/ICPS65515.2025.11087832.

[18] X. Jiang *et al.*, "Agentic AI for safety-aware process monitoring and fault diagnosis: A review," *Processes*, vol. 14, no. 13, 2026, art. no. 2112; doi: 10.3390/pr14132112.

[19] Model Context Protocol contributors, "Model Context Protocol: Tools," Specification, 2026, accessed: Oct. 20, 2026. [Online]. Available: https://modelcontextprotocol.io/specification/2026-07-28/server/tools

[20] ISA, "ISA-88.00.01-2010: Batch control—part 1: Models and terminology," International Standard, 2010.

[21] ——, "ANSI/ISA-95.00.01-2025 (IEC 62264-1 mod): Enterprise-control system integration—part 1: Models and terminology," International Standard, 2025.

[22] J. Moyne, E. del Castillo, and A. M. Hurwitz, Eds., *Run-to-Run Control in Semiconductor Manufacturing*, 1st ed. Boca Raton, FL: CRC Press, 2000.

[23] R. Parasuraman, T. B. Sheridan, and C. D. Wickens, "A model for types and levels of human interaction with automation," *IEEE Trans. Syst., Man, Cybern., Part A*, vol. 30, no. 3, pp. 286–297, 2000, doi: 10.1109/3468.844354.

[24] H. Wang, C. M. Poskitt, and J. Sun, "AgentSpec: Customizable runtime enforcement for safe and reliable LLM agents," in *Proc. IEEE/ACM 48th Int. Conf. on Software Engineering (ICSE)*, 2026, pp. 2938–2950, doi: 10.1145/3744916.3764546.

[25] E. Debenedetti *et al.*, "Defeating prompt injections by design," 2025, arXiv preprint arXiv:2503.18813. [Online]. Available: https://arxiv.org/abs/2503.18813

[26] R. Parasuraman and D. H. Manzey, "Complacency and bias in human use of automation: An attentional integration," *Hum. Factors*, vol. 52, no. 3, pp. 381–410, 2010, doi: 10.1177/0018720810376055.

[27] L. Bainbridge, "Ironies of automation," *Automatica*, vol. 19, no. 6, pp. 775–779, 1983, doi: 10.1016/0005-1098(83)90046-8.

[28] K. Greshake, S. Abdelnabi, S. Mishra, C. Endres, T. Holz, and M. Fritz, "Not what you've signed up for: Compromising real-world LLM-integrated applications with indirect prompt injection," in *Proc. 16th ACM Workshop on Artificial Intelligence and Security*, 2023, pp. 79–90, doi: 10.1145/3605764.3623985.

[29] Y. Liu, Y. Jia, R. Geng, J. Jia, and N. Z. Gong, "Formalizing and benchmarking prompt injection attacks and defenses," in *Proc. 33rd USENIX Security Symposium (USENIX Security 24)*, 2024, pp. 1831–1847. [Online]. Available: https://www.usenix.org/conference/usenixsecurity24/presentation/liu-yupei

[30] IEC, "IEC 62443-3-3:2013: Industrial communication networks—network and system security—part 3-3: System security requirements and security levels," Standard, 2013.

[31] ——, "IEC 61511-1:2016: Functional safety—safety instrumented systems for the process industry sector," International Standard, 2016.