Supplementary File S2: Agent-Mediated Thermal-Twin Integration Test

This file summarizes one supervised agent-to-device test reported in the manuscript, based on an archived event summary. The run-level assertion package and continuous process trace are not available for independent replay. This summary preserves the reported order of context retrieval, approval, device operations, and subsequent acquisition; it is not a complete runtime replay package.

1 Configuration

One acquisition node and three setpoint nodes connected over Modbus TCP to an isolated gray-box extrusion/casting thermal simulator with first-order inertia and delay. The simulator was not calibrated against a production line. An independent Modbus client read its registers. One OMP harness with a local Qwen model used a manual-approval channel.

2 Recorded Sequence

Table 1: Distinct actions and their associated device and process evidence.

Stage	Action and device-side record	Process and acquisition record
Context retrieval	The agent queried its bound nodes, the active line context, and the acquisition service.	The agent retrieved the active process-value summary from the platform.
Agent-proposed trial	The agent submitted a three-zone recipe trial from 198 to 200 °C. Manual approval preceded dispatch. The platform receipt and independent Modbus reads confirmed all three setpoints.	The archived summary links the task, approval, trial receipt, and register values. No separate response interval was defined for this step.
Follow-on approved step	A separate manually approved operation changed the three setpoints from 200 to 205 °C. Independent register reads and platform readback confirmed all three values.	Over the following 40 s, the simulated process value changed from 198.02 to 200.73 °C. Platform samples changed from 198.41 to 200.49 °C; the agent later retrieved 200.49 °C, matching the platform sample. Both actions occurred in one continuous run, so the observation does not isolate their contributions.

3 Interpretation and Limits

The archived summary documents one supervised path from production-context and acquisition queries through an agent-issued recipe trial, manual approval, Modbus device writes, independent register checks, and subsequent acquisition. The 2.71 °C change was measured in the 40 s window after the separate 200-to-205 °C step. Because both actions occurred in one continuous run without an isolated baseline, their residual contributions cannot be separated. This single test lacks a calibrated process model, replication, a matched controller, raw model-provider requests and responses, and a complete environment snapshot; it does not establish process-control benefit, model reasoning quality, or physical-plant performance.