

Which mechanism catches which attack class

out-of-constraint probes executed, per class and per ablation arm (3 probes per cell)

		Full	No interlock	No readback	Both disabled
hard range	below hard range				
	above hard range				
	below recipe window		 3/3		 3/3
	above recipe window		 3/3		 3/3
window	extreme value				
	negative value				

 rejected at admission  executed and journaled

Four of six attack classes are rejected in every arm: the hard-range guard is structural. Only the two recipe-window classes execute, and only when the window interlock is bypassed.