

	FaultExplainer GPT-4o	FaultExplainer o1-preview	PCA detectable	IDD (this work) no candidates
IDV1 A/C feed-ratio step	wrong	correct	yes	Top-1 (0.79)
IDV3 D-feed temperature step (hard)	unscored	unscored	no	capped CS (0.60)
IDV4 reactor cooling-water step	unscored	unscored	no	Top-1 (0.75)
IDV7 C-header pressure loss	correct	correct	yes	Top-1 (0.82)
IDV11 cooling-water random	correct	correct	yes	Top-1 (0.80)
IDV14 cooling-valve stiction	correct	correct	yes	Top-1 (0.89)