

Virtec

Virtec Instruments Inc.

User Manual



ULTRASONIC HEAT METER

VIR-832 Series-Installation & User Guide

The documentation is only complete when used in combination with the relevant documentation for the signal converter.

Virtec Instruments, USA

Ultrasonic Flowmeter – Installation & Operating Manual

Edition: 2021/Part-B

Welcome Note

Thank you for choosing Virtec Instruments, USA — a trusted name in advanced metering technology. This manual provides comprehensive guidance on the installation, commissioning, operation, and maintenance of our Ultrasonic Flowmeter range.

Our flowmeters are engineered for accuracy, durability, and performance, designed to meet the needs of both utility and industrial applications.

Important Notice

The following pages include detailed instructions on:

- Introduction to Virtec Instruments.
- Product overview and specifications.
- Installation requirements and best practices.
- Configuration and commissioning procedures.

Please read the entire manual before beginning installation or operation to ensure correct handling and optimal performance of the device.

For further assistance, contact our technical support team at sales@virtec.us.

Introduction

Virtec Instruments is a trusted name in precision measurement and smart metering technologies, specializing in high-performance flow and thermal energy solutions. With a commitment to innovation, quality, and customer satisfaction, Virtec delivers advanced instrumentation that meets the demanding needs of water, HVAC, industrial, and energy management sectors.

Ultrasonic Flowmeters

Designed for accuracy and reliability, Virtec ultrasonic flowmeters offer non-intrusive, maintenance-free flow measurement for a wide range of conductive and non-conductive fluids. Utilizing transit-time and Doppler technologies, these meters provide high-resolution data with minimal pressure drop, ideal for water distribution, building automation, and industrial process monitoring.

Ultrasonic Heat Meters

Virtec ultrasonic heat meters are engineered to deliver precise thermal energy measurements in heating and cooling systems. These meters are compliant with MID EN1434 standards and provide long-term stability, low starting flow, and robust data communication capabilities—making them an essential component in smart energy management for residential, commercial, and district energy systems.

Working Principles

Ultrasonic flowmeters operate based on the transit-time difference principle. Two ultrasonic sensors are placed at an angle to the flow path—one upstream and one downstream. As fluid flows through the pipe, it causes a time difference between the upstream and downstream signals. This time difference is directly proportional to the flow velocity of the fluid. Since there are no moving parts and no direct contact with the fluid, these meters are highly durable and well-suited for clean liquid applications with minimal maintenance.

Alternatively, in some conditions, Doppler-based ultrasonic flowmeters are used, especially when the fluid contains suspended particles or gas bubbles. In this method, an ultrasonic signal is transmitted into the flow, and the frequency shift (Doppler effect) of the reflected signal is used to calculate the flow velocity. This technique enables reliable flow measurement in partially contaminated or aerated liquids.

Why Virtec Instruments?

- Proven technology with high measurement accuracy
- Durable, low-maintenance designs suited for diverse environments.
- Integration-ready with MODBUS, BACnet, M-Bus, and other protocols
- Backed by technical support, calibration services, and application expertise.

With a growing footprint across Asia, Europe, and the Middle East, Virtec Instruments is committed to driving smarter, more sustainable flow and energy measurement solutions. Partner with us to experience performance you can measure-and trust.

Virtec Energy Meter Instruction Manual

This instruction manual provides essential information for the use and operation of your flow meter. It is important to read the reference manual carefully before beginning any operations to ensure optimal performance of your portable ultrasonic flow meter.

Operation and Precautions

Improper operation can affect the normal functioning of the flow meter, reduce its service life, or cause malfunctions. Following the guidelines in this manual will help maintain the device's longevity and reliability.

Manual Overview

This manual presents step-by-step instructions for using the flow meter. It begins with details on the product components, then covers installation, wiring, quick settings, and more, making the operation process straightforward and accessible.

Advanced Settings and Functions

By exploring the menu settings, users can access the powerful functional options and output features of the flow meter, enabling the device to meet higher application requirements.

Inspection Before Installation

Inspection should be made before installing the flow meter. Check to see if the spare parts are in accordance with the packing list. Make sure there is no potential damage to the enclosure due to a loose screw or loose wire that may have occurred during transportation. If you have any questions, please contact your representative as soon as possible.

General Safety Precautions

- Always follow the manufacturer's installation and operation manual.
- Ensure that only qualified personnel handle the installation, maintenance, or troubleshooting of the flow meter.
- Disconnect electrical power and isolate hydraulic lines before performing any installation or service.
- Wear personal protective equipment (PPE) such as gloves, safety goggles, and protective footwear.

Compliance Standards

- ISO 4064 / EN 1434: For volumetric and thermal energy measurement.
- ASHRAE Guidelines: For HVAC metering standards and performance evaluation.
- CE / UL Certification: Ensure flow meters meet relevant electrical and safety certifications.
- BIS / IS Standards (India-specific): Adhere to Bureau of Indian Standards norms for flow metering and instrumentation.

Handling and Lifting Precautions

- Always lift the meter using the designated lifting lugs or brackets.
- Avoid using the sensor cables or pipe connections as lifting points.
- Use appropriate lifting equipment (slings, chains, hoists) rated for the weight of the flow meter.
- Ensure that the meter is balanced during lifting to avoid tipping or damage.

Installation Precautions

- Straight Pipe Lengths: Ensure minimum straight pipe lengths upstream and downstream (usually 10–20 times the pipe diameter) for accurate readings.
- Flow Direction: Follow the arrow marking on the meter to match the direction of water flow.
- Vibration Control: Mount the flow meter away from sources of excessive vibration and use anti-vibration supports if necessary.
- Positioning: Install the flow meter in a horizontal or vertical pipe run based on manufacturer recommendations. Avoid air pockets and cavitation areas.
- Isolation Valves: Install shut-off valves upstream and downstream of the meter for maintenance without system shutdown.
- Grounding: Properly ground the flow meter to protect against electrical interference.
- Environmental Protection: If installed outdoors, ensure proper housing or weatherproof enclosures.

Post-Installation Checks

- Check for leaks at all joints and flanges.
- Verify that the meter display or output is functioning correctly.
- Calibrate the meter if required before commissioning.
- Ensure compliance documentation is complete and retained for audits.

Product Series Information

Transmitters in the VIR-832 series operate on 230V AC, while the VIR-832-M series operates on 24V DC. All functionality and features remain the same across both series.

Flow Transducer	Sensor Body	Transmitter	Model	Measuring Range	Temperature
Clamp on		VIR-832 / VIR 832M	TS-2 (small)	DN25-100	-30 ~ 900C
			TM-1 (medium)	DN50-700	
			TL-1 (large)	DN300-6000	
Insertion		VIR-832 / VIR 832M	VIR-UF- INSRT-UF	DN50-6000	-30 ~ 1600C
In-line		VIR-832 / VIR 832M	VIR-850	DN15-1000	-30 ~ 160
Temperature Sensor	Construction	Model	Measuring range	Temperature	Cutoff water
Clamp on		CT-1(PT-100)	DN50-6000	-40 ~ 160	No need
Insertion		TCT-1(PT-100)	DN50-6000	-40 ~ 160	Need
Insertion for Pressurised Pipeline		PCT-1(PT-100)	DN50-6000	-40 ~ 160	No need

Electronic Flow Transmitter: VIR 832M/VIR 832



Product Data Sheet

VIR 832/VIR 832 M- Ultrasonic Clamp-On Type: Flow & Heat Meter		
Main Unit	Accuracy	± 1% , ± 0.5% ± 0.2% ± 0.025 ft/s (0.008 m/s)
	Repeatability	Better than 0.2%
	Principle	Transit-time measuring principle
	Measurement Period	500ms
	Display	LCD with backlight, display accumulated flow/heat, instantaneous flow/heat, velocity, time etc.
	Output	Analog output: 4-20mA or 0-20mA current output. Impedance 0.1kw. Accuracy 0.1%
		OCT output: Frequency signal (1-9999HZ)
		Relay output: Programmable (no signal, reverse flow etc.)
		RS 485 serial port
	Input	Three analog input
	RTD For Heat Meter only	Two 2-wire, 3-wire Pt100/Pt1000/Pt 500 RTD 12-bit inputs; Range of -40...200° C; Clamp-on resistorkits available
	Other functions	Automatically record the totaliser data up to 5 years and 16 years Option
	Energy total (Heat Meters)	British Thermal Unit (Btu), MWH KWH
	Heat/cooling rate (Heat Meters)	Btu/hour, Kilowatts, Megawatts,
	Temperature (Heat Meters)	Fahrenheit, Celsius
	Power loss mode	The power-on time and corresponding flow rate of the last 64 power on and off events. Allow manual or automatic flow loss compensation
Pipe	Material	Steel, Stainless steel, Cast iron, Cement pipe, Copper, PVC, Aluminium, FRP etc. Liner is allowed
	Size	15-6000mm
	Straight pipe section	In the upstream it must be beyond 10D, in the downstream it must be beyond 5D.In the upstream the length must be beyond 30D from the access of the pump. (D Stands for pipe diameter)
Liquid	Types	Water, sea water, industrial sewage, acid and alkali liquid, alcohol, beer, all kinds of oils which can transmit ultrasonic single uniform liquid
	Temperature	Standard : -10° C - 160° C
	Turbidity	Less than 10000ppm, with a little bubble
	Flow Direction	Bi-directional measuring, net flow/heat measuring
Environment	Ambient Temperature	Main Unit: -4...140° F (-20...60° C)
	Altitude Restriction	Up to 2000 m (6561 ft)
	Humidity	Main Units:0...85%, non-condensing
		Transducer : water-immersible, water depth less than 3m
Cable	Twisted pair line, standard length of 20m, can be extended to 500m (not recommended); Contact the manufacturer for longer cable requirement. RS-485 interface, transmission distance up to 1000m	
Power Supply	VIR-832 AC220V AND VIR-832-M (REMOTE TYPE) DC24V	
Power	Less than 1.5W	
Protocols	MODBUS-RTU Protocol Standard. Option of BACnet MS/TP -IP with MC-603 Kamstrup Make Calculator available.	



Transducer Installation Guidelines

Preparing the Pipe Surface

Before installing transducers, ensure the pipe surface is thoroughly cleaned. Remove any rust, scale, or loose paint to create a smooth area for mounting.

Selecting and Preparing the Installation Site

Choose a section of the pipe suitable for sound conduction. Apply a generous band of sonic coupling compound to the centre of each transducer face and to the prepared pipe surface.

Attaching the Transducers

Mount the transducers using the provided racks, securing them tightly to the pipe. The transducers should be installed at the pipe's centre line on horizontal pipelines, and their installation direction must remain parallel to the flow.

Installation Considerations

Ensure no air bubbles or particles are present between the transducer and the pipe surface. For horizontal pipes, install the transducers at the 3 o'clock and 9 o'clock positions to avoid air bubbles accumulating at the top. If symmetrical horizontal installation is not possible, install the transducers at a location where the pipe remains full of liquid.

Transducer Spacing


After entering all required parameters, reference the standard spacing between the tops of the two transducers, as indicated in the "Setup Menu - Pipe parameter." Reserve this spacing during installation.

Transducer Mounting Methods

There are four available mounting methods: V,Z & N details as under

V Method

Transducers A Transducers B



TF : Time in flow direction

TR : Time in reverse flow direction

V

The V method is considered as the standard method. It usually gives a more accurate reading and is used on pipe diameters ranging from 25mm to 400mm (1 ~ 16") approximately. Also, it is convenient to use, but still requires proper installation of the transducer, contact on the pipe at the pipe's centerline and equal spacing on either side of the centerline.

Z Method

Transducers A

Transducers B

Flow →

TF : Time in flow direction

TR : Time in reverse flow direction

Z

The signal transmitted in a Z method installation has less attenuation than a signal transmitted with the V method.

This is because the Z method utilizes a directly transmitted (rather than reflected) signal which transverses the liquid only once.

The Z method is able to measure on pipe diameters ranging from 100mm to 3000mm(4"~120")

N Method

Transducers A

Transducers B

Flow →

TF : Time in flow direction

TR : Time in reverse flow direction

N

With the N method, the sound waves traverse the fluid twice and bounce three times off the pipe walls. It is suitable for small pipe diameter measurement. The measurement accuracy can be improved by extending the transit distance with the N method (uncommonly used)

Clamp-On Transducer Installation

Pre-Installation Checklist

Before installation, confirm the pipeline and liquid parameters to ensure accurate setup.




Step-by-Step Installation Procedure

- Select the appropriate installation method.
- Input the required measurement parameters.
- Clean the surface of the pipe thoroughly.
- Install the transducers securely.
- Verify and check the installation for accuracy.

Choosing the Installation Method

There are two primary methods for mounting clamp-on transducers: the V-method and the Z-method.

- V-method: Recommended for pipe sizes ranging from DN15 to DN700. In this configuration, the pair of transducers should be aligned horizontally, with their central lines running parallel to the axis of the pipeline.
- Ensure pair of transducers in A & B point has horizontal alignment, the central line in parallel with the pipeline axis and equal to distance shown the VIR-832 transmitter menu



Mark the Distance. Polish the surface removing any extra layer on pipe. Apply Silicone gel supplied along with detectors and place on pipe on the marked point. Use a steel belt or rope and tighten the detectors

Insertion Type Installation Guidelines

Mounting Position and Preparation

Select the desired mounting position on the pipe and weld a mounting seat at that location. Next, create an appropriate hole using drill tools. Once prepared, insert the wetted transducer into the mounting hole and tighten it securely.

Installation Notes for Transducers.

The two transducers should be installed at the pipe's centreline when working with a horizontal pipeline. Ensure that the installation direction of each transducer is parallel to the direction of flow. On horizontal pipes, install the transducers in the 3 o'clock and 9 o'clock positions along the pipe section. This placement helps to avoid air bubbles accumulating in the pipe's upper section.

If symmetrical horizontal installation is not possible due to site limitations, select a location that ensures the pipe remains completely full of liquid.

Tools and Accessories (for Insertion type transducer)

During installation, appropriate mounting tools are required. HD35-specific drill tools can be used for pressure positioning and drilling. For carbon steel pipes, direct welding is possible. For stainless steel pipes, order a stainless-steel mounting seat and perform suitable welding.

For cast iron, fiberglass, PVC, and cement pipes, special saddles must be ordered for installation. Accurate measurement of the pipe's outer diameter is essential to prevent leakage.

Transducer Spacing

Ensure correct spacing between transducers as specified for optimal operation. Pl refer to Menu /parameters for details.

Transducer Installation Procedure (Horizontal Pipe, V Method)


Step 1: Marking Installation Points

- Based on the transducer spacing recommended by the flow meter, identify the optimal installation locations at the 3 o'clock and 9 o'clock positions on the pipe.
- Prepare a piece of rectangular tape, marking an “indicator line” approximately 100 mm from one edge. This serves as a reference for alignment. Ensure straight line requirement.




Step 2: Aligning with Pipe Axis

- Wrap the tape around the pipe so the edges meet cleanly, ensuring the indicator line remains parallel to the pipe's axis. Use the extended indicator line to mark a straight reference along the pipe surface.




Step 3: Transferring and Extending Reference Marks

- Remove the tape and use the extended indicator line as a guide to transfer a straight line in the reverse direction along the pipe.
- According to the specified transducer spacing, mark two points (A and B) along this line. These marks represent the centre points for the welding mounts.



Step 4: Welding and Valve Installation

Engage qualified welding personnel to weld the mounting base onto the pipe. Once secure, install the brass ball valve onto the welded base. Open the ball valve and insert the HD35 hole drill as illustrated. The HD35 hole drill is designed for use with standard impact or electric drills equipped with round-head handles. After drilling completely through the pipe wall, remove the drill, close the ball valve, and detach the HD35 drill. This completes the pressurized opening procedure.



①	Pipeline
②	Ball valve base
③	Special ball valve
④	Drill
⑤	Super hole cutter
⑥	Seal cover
⑦	Drill rod
⑧	Electric hand drill


Step 5: Transducer Installation and Depth Adjustment

With the base prepared, install the transducer. Adjust its insertion depth based on the calculated pipe wall thickness to determine the correct "h value" (see diagram for reference). The transducer should indicate the direction to the outside, as shown in the corresponding illustration.

Note: The transducer indicates the direction to the outside, as shown below.

Positioning of parallel insertion transducer need to meet the 3 factors as follow:

- Installation distance = Vertical distance of two transducers along the pipe axis direction
- Make sure two transducers are in the same horizontal line,
- Insertion depth = 1/3 inner diameter



Insertion Depth Adjustment:

Adjust the depth scale according to pipe wall thickness and completely push in the transducer rod. Adjust the proper insertion depth and transmit direction to get good ultrasound signal.

Installation Check-Clamp On & Insertion Transducers

To guarantee reliable operation, the flow meter is equipped with diagnostic functions to evaluate signal strength, signal quality, and transmission timing.

Signal Strength and Quality (M90)

Displayed on a scale from 00.0 (no signal) to 99.9 (maximum signal). For proper functioning, a value above 60.0 is recommended. - Signal Quality (Q value): Indicated from 00 (worst) to 99 (best). A Q value above 60 ensures the flow meter can operate accurately.

During installation, adjust the transducers to maximize both signal strength and quality. Achieving higher values in these metrics helps ensure long-term stability and precise measurement.

Signal strength and Q value	Installation Judgement
< 60	Can not work
60~75	Bad
75~80	Good
>80	Excellent

Common checking for Clamp on and Insertion type Transducers-Transmission Time Ratio (M91)

The transmission time ratio compares the theoretical transmission time with the measured value and is displayed as a percentage. - This ratio should fall between 97% and 103%. Values outside this range suggest discrepancies between the entered parameters and the actual transducer installation distance.

If the ratio is not within the specified limits, verify the settings and the physical positioning of the transducers to resolve inconsistencies. By following these verification steps and making necessary adjustments, you can ensure accurate readings and maintain the optimal performance of your flow meter.

Quick Setup of Measurement Parameters

Accurate setup of measurement parameters is crucial for achieving reliable and precise results. It is recommended to use an ultrasonic thickness gauge to measure the actual pipe wall thickness and circumference.

Parameter Input Sequence

Essential Parameters to Enter Before Measurement:

- Outer Diameter (unit: mm)
- Pipe Wall Thickness (unit: mm)
- Pipe Material
- Lining Information (thickness and sound velocity, if lining is present)
- Liquid Type
- Transducer Type
- Transducer Mounting Type

Display and Operation

Display is 2x20 characters LCD with backlight, available to set backlight time and contrast.


[0] - [9] and [.] are used for inputting numbers or menu numbers.

[◀] is used for back left or delete the left character.


[▲/+] and [▼/-] are used for entering into the last and next menu. Also can be used as ± sign when inputting numbers.

[MENU] is used for accessing the menu. Press this key first, then type the number keys to enter into the matched menu.

[ENT] is the [ENTER] key, used for confirming the contents you input or choose.



Keyboard - VIR-832-M



VIR-832-M

- **[MENU]**: used for entering into menus.
- **[▲]** :used for menu up or choosing 0-9, +, -
- **[▶]** : used for menu down or moving the cursor to next.
- **[ENT]**: used for finishing menu inputting or entering into submenu.

Operation:

The user interface of this flow meter comprises about 100 different menu windows that are numbered by M00, M01, M02 ... M99.

Method to enter Menu: Press **[MENU]** first and follow the two-digit number keys. Take M35 as an example, the correct key sequence is **MENU35**

To move between the adjacent menus, press **[▲/+]** and **[▼/-]** for 16-key keyboard; press **[▲]** and **[▶]** for 4-key keyboard.

Menu Details

Quick setup of measured parameters

Accurate measured parameters can have a great influence on measuring precision and reliability. It is suggested to measure the practical perimeter and wall thickness of the pipeline. Ultrasonic thickness gauge can be used to measure the pipe thickness.

Measured parameters setup is from Menu10 to Menu29. Please complete one by one.

Above parameters setup generally follow the steps below:

- Press keys **[MENU]1 1** to enter M11 window to input the pipe outer diameter, and then press **[ENT]** key.
- Press key **[▼/-]** to enter M12 window to input the pipe outer diameter and then press **[ENT]** key.
- Press key **[▼/-]** to enter M14 window, and press **ENT** key to enter the option selection mode.
- Use keys **[▲/+]** and **[▼/-]** to select the pipe material, and then press **ENT** key.
- Press key **[▼]** to enter M16 window, press **[ENT]** key to enter the option selection mode. Use keys **[▲/+]** and **[▼/-]** to select the liner material, and then press **[ENT]** key. Select “No Liner”, if there is no liner.


- Press key **[▼/-]** to enter M20 window, press **[ENT]** key to enter the option selection mode. Use keys **[▲/+]** and **[▼/-]** to select the proper liquid, and then press **[ENT]** key.
- Press key **[▼/-]** to enter M23 window, press **[ENT]** key to enter the option selection mode. Use keys **[▲/+]** and **[▼/-]** to select the proper transducer type, and then press ENT key.
- Press key **[▼/-]** to enter M24 window, press **[ENT]** key to enter the option selection mode. Use keys **[▲/+]** and **[▼/-]** to select the proper transducer mounting method, and then press **[ENT]** key.
- Press key **[▼/-]** to enter M25 window and get the transducer installation distance.
- Press **MENU 2 6** to store the parameters setup.

Choose installation points


Proper installation point is a key for transducer installation. Following factors must be considered: Full filled pipeline, shaking, steady flow, scaling, temperature, pressure, EMI, instrument well.

Full filled pipeline

Following situations can be full filled of liquid:



Vertical
upward



Obliquely
upward



Lowest
point

Vibration

There cannot be obvious vibration on the installation point, otherwise it needs to be tightened.

Steady flow

Steady flow is helpful for ensuring measurement accuracy.

Standard requests for steady flow are:

- The pipe should be far away from pump outlet and half-open valve.

Scaling

The inside scaling would have bad effect on ultrasonic signal transmission and would decrease the inner diameter as well. As a result, the measurement accuracy cannot be guaranteed. Please try to avoid choosing the installation point with inside scaling.

Temperature

The liquid temperature on installation point should be in the working range of transducers. Please try to choose the point with lower temperature. Avoid choosing points like the outlet of boiler water and heat exchanger. Return water pipe would be better.

Temperature range of standard clamp on and insertion transducers:
-30 ~ 90°C

Temperature range of high temperature clamp on and insertion transducers:
-30 ~ 160°C

Pressure

The maximum pressure for standard insertion and inline transducer is 1.6MPa
Out of this range need customized.

Installation Guidelines- Flanged Flow Meter-VIR 850 Series

1. Delivery and Acceptance

When receiving deliveries that include more than one meter, it is essential to verify that each sensor is correctly matched with its corresponding converter. This can be confirmed by checking the system rating plates.

2. Meter Handling

- Always lift the meter by its flanges or transport eyelets — never by the connecting box or sensors.
- Recommended lifting method: Use textile slings only. Avoid chains or steel cables, as they can cause physical damage.
- Do not place any auxiliary components inside the sensor during transport, as this may cause irreversible damage.
- Whenever possible, transport the flowmeter to the installation site in its original packaging to ensure protection.

3. Storage Before Installation

- Before installation, observe the following storage requirements:
- Maintain the recommended ambient temperature and relative humidity.
- Keep the meter away from direct sunlight to prevent display damage.
- Store the meter in its original packaging. Remove any protective covering or casing only just before installation.

4. Installation Conditions

General Assembly Rules

During the mechanical installation of the meter, follow these essential guidelines:

- Remove the protective wrapping and casing immediately before installation.
- Ensure the arrow on the sensor body points in the direction of fluid flow.
- When installing the meter in a vertical pipeline, fluid must flow upwards.
- The pipe flanges should be aligned and strictly parallel.
- The internal diameters of the pipeline and sealing components must match the diameter of the meter sensor.




Modular-24v

Specifications:

VIR-850 series Flanged In-Line Type Flow/Heat meter with Integrated transmitter or VIR-832-M remote Transmitter

Main Unit	Accuracy	Class 2 -EN 1434 Standard
	Repeatability	Better than 1%
	Principle	Transit-time measuring principle
	Measurement Period	500ms
	Display	LCD with backlight, display accumulated flow/heat, instantaneous flow/heat, velocity, time etc.
	Output	Analog output: 4-20mA or 0-20mA current output. Impedance 0.1kw. Accuracy 0.1% OCT output: Frequency signal (1-9999Hz) Relay output: Programmable (no signal, reverse flow etc.) RS-485 serial port
	Input	1 analog input
	RTD For Heat Meter	Two 2-wire, 3-wire Pt100/Pt1000/Pt 500 RTD 12-bit inputs; Range of -40°C...200°C; Clamp-on resistor kits available
	Other functions	Automatically record the totaliser data upto 5 years and 16 years option
	Energy total (Heat Meters)	British Thermal Unit (Btu), MWH KWH
Pipe	Heat/cooling rate (Heat Meters)	Btu/hour, Kilowatts, Megawatts,
	Temperature (Heat Meters)	Fahrenheit, Celsius
	Power loss mode	The power-on time and corresponding flow rate of the last 64 power on and off events. Allow manual or automatic flow loss compensation
Liquid	Material	Steel, Stainless steel, Cast iron, Cement pipe, Copper, PVC, Aluminium, FRP etc. Liner is allowed
	Size	50-800mm
	Straight pipe section	In the upstream it must be beyond 10D, in the downstream it must be beyond 5D. In the upstream the length must be beyond 30D from the access of the pump. (D Stands for pipe diameter)
Environment	Types	Water, sea water, industrial sewage, acid and alkali liquid, alcohol, beer, all kinds of oils which can transmit ultrasonic single uniform liquid
	Temperature	Standard : -10°C - 160°C
	Turbidity	Less than 10000ppm, with a little bubble
	Flow Direction	Bi-directional measuring, net flow/heat measuring
Cable	Ambient Temperature	Main Unit: -4...140°F (-20...60°C)
	Altitude Restriction	Up to 2000 m (6561 ft)
	Humidity	Main Units: 0...85%, non-condensing Transducer : water-immersible, water depth less than 3m
Power Supply	DC24V	
Power	Less than 1.5W	
Protocols	MODBUS-RTU Protocol Standard. Option of BACnet MS/TP or IP with MC-603 Kamstrup make calculator available.	

Dimension & Flow details:



Model	Nominal Diameter (DN)	Flow Nominal M3/Hr	P/N P	Width W	Height H	Outer Diameter D	Bolt Hole Centers D1	Bolt Hole X Quantity & X n	Sealing Surface Diameter D2	Flange Thickness		Bolt Specification
										c	f	
65-UF-VIR-850	125	100	1.6	250	428	250	210	18x 8	184	22	2	M2 0x 80
65-UF-A-VIR-850	150	150	1.6	285	459	285	240	22x 12	211	24	2	M2 0x 90
65-UF-B-VIR-850	200	250	1.6	340	511	340	295	26x 12	266	26	2	M2 2x 90
65-UF-C-VIR-850	250	400	1.6	405	569	405	355	26x 12	319	28	2	M2 2x 90
65-UF-D-VIR-850	300	600	1.6	460	621	460	410	23x 16	370	32	2	M2 2x 90
65-UF-E-VIR-850	350	800	1.6	500	666	500	460	25x 16	428	28	4	M2 0x 80
65-UF-F-VIR-850	400	1000	1.6	565	697	565	515	25x 20	482	30	4	M2 2x 90
65-UF-G-VIR-850	450	1200	1.0	615	774	615	565	25x 20	532	30	4	M2 2x 90
65-UF-H-VIR-850	500	3000	1.0	670	826	670	620	30x 20	585	32	4	M2 2x 90
65-UF-I-VIR-850	600	4400	1.0	780	931	780	725	25x 24	685	36	5	M 27x 110
65-UF-J-VIR-850	700	6200	0.6	860	1021	860	810	30x 24	775	32	5	M2 2x 90
65-UF-K-VIR-850	800	8000	0.6	975	1129	975	920	30x 24	880	32	5	M 27 x 100

*All Dimensions in mm. +/- 3% variation.

Installation Requirements-VIR850

Sealing and Mechanical Support

- Ensure that the sealing gasket is correctly positioned between the flanges and does not intrude into the flow path.
- The piping must be adequately supported on both the inlet and outlet sides of the meter to minimize mechanical stresses such as vibration, bending, or tension on the sensor.
- Do not place any piping support or brace directly beneath the meter sensor.
- The converter must be shielded from direct sunlight to avoid damage or operational issues.
- Select an installation location that provides easy access for operators to the converter and meter rating plates.
- The sensor must always remain completely flooded with fluid, with minimal risk of air entrapment or aeration.

Important Note: After the meter is installed, no arc welding should be performed on adjacent piping. Additionally, do not weld flanges onto piping ends when the meter sensor is already attached.

Straight Pipe Requirements (per EN ISO 4064-5)


To ensure accurate measurement, the installation location must suitable fluid flow

- Consistent velocity profile
- Full flooding of the sensor
- Prevention of cavitation or foaming.

Straight Piping Sections

- The inlet and outlet of the meter must include straight piping sections, with lengths defined as multiples of the pipe's internal diameter (DN).
- For bi-directional flow, ensure the same straight lengths on both sides of the meter.
- The pipe inner diameter must closely match the sensor's — it should not be smaller, and should not exceed it by more than 1%.
- Avoid sharp edges or steps at the pipe-sensor joints that could create turbulence.
- Ideally, install the sensor upstream of any flow-disturbing components like pumps or valves.
- If the system uses pumps that generate pressure pulses (e.g., pneumatic pumps), a hydraulic damper should be installed to smooth out flow disturbances.



Straight Pipe Length Guidelines by Sensor Type-UF Series (Single-Ray Sensor)



Minimum straight lengths:

- 5 DN at the inlet
- 3 DN at the outlet

For bi-directional flow, both inlet and outlet require 5 DN. If multiple flow-disturbing elements are near the meter (e.g., bends, reducers), increase straight lengths proportionally.




If the flowmeter is smaller than the connected piping, use conical reducers with an apex angle not exceeding 15°. For horizontal piping systems, eccentric reducers should be used to avoid air bubble formation (refer to standard ČSN ISO 6817). Tapered reducers with a slope angle up to 8° can be treated as part of the straight piping section.

Limiting Pump Operation Effects

To prevent pressure drops inside the sensor and avoid issues such as cavitation, gas bubble formation, or fluid foaming:

- Always position the pump on the inlet side of the flowmeter.
- This configuration helps maintain higher pressure in the system, keeping the fluid below its saturated vapor pressure and thereby suppressing cavitation.
- A minimum of 20 DN of straight piping is required between the pump and the flowmeter sensor.




Limiting Effects of Closing and Regulation Valves

To maintain a stable velocity profile and minimize cavitation risk:

- Install closing or regulating valves preferably on the outlet side of the flowmeter.
- Ensure a minimum of 10 DN of straight piping between the flowmeter and the nearest valve.

The meter sensor shall not be located at the top of the piping system or, in vertical position, with the fluid flow direction downwards, especially if the piping discharge point is near. Observance of this rule will prevent measurement errors due to higher concentration of air bubbles inside the sensor.



The flowmeter position in the piping can be both horizontal and vertical.



Suitable deviation from the ideal position of horizontal axis:

VIR (single-ray) $\pm 30^\circ$ in both directions.

If a flowmeter is to be installed in a thermally insulated piping, thermal insulation is usually applied on the meter sensor too. In such a case, observe the following rules:

- Thermal insulation is placed on the sensor only. • The meter converter shall be protected against undesirable heating (by direct sunshine or water or rain)

Installation Process:

<p>① Confirm installation size</p> <p>Length of transducer L + 2×thickness of seal gasket + 10mm</p> 	<p>② Cutting pipeline</p> 
<p>③ Equip companion flanges</p> 	<p>④ Positioning the flanges</p>  <p>Twist 3 screws and averagey positioning the flanges. Fixing with spot welding.</p>
<p>⑤ Welding the flanges</p>  <p>Remove the inline transducer and full-length welding flanges.</p>	<p>⑥ As the flanges cooled, put in the seal gasket and tighten the screws. Then connect to converter with signal cable</p> 

Configuration Steps:

- Press the relevant key to access Menu10, input the pipe's outer diameter, and confirm with the [ENT] key.
- Navigate to Menu12 to input the pipe wall thickness, then press [ENT] to confirm.
- Proceed to Menu14, press [ENT] to enter selection mode, use the arrow keys to choose the pipe material, and confirm your choice.
- In Menu16, enter selection mode with [ENT], use arrow keys to select liner material, and press [ENT] to confirm. If there is no liner, select "No Liner."
- Access Menu20, enter selection mode with [ENT], use arrow keys to select the type of liquid, and confirm your choice.
- Go to Menu23, enter selection mode with [ENT], use arrow keys to select the appropriate transducer type, and press [ENT] to confirm.
- Enter Menu24, enter selection mode with [ENT], use arrow keys to choose the transducer mounting method, and confirm your selection.
- Move to Menu25 to obtain the required transducer installation distance.
- Finally, press [WW] to save all parameter settings.

Additional Considerations for Installation

Scaling:

- Internal scaling can negatively affect ultrasonic signal transmission and significantly reduce measurement accuracy. If scaling is present at the installation point, reliable measurement cannot be guaranteed.

Temperature:

- Ensure that the liquid temperature at the installation site is within the working range of the selected transducers. Opt for locations with lower temperatures whenever possible—avoid areas such as boiler or heat exchanger outlets. Return water pipes are generally preferable.
- Standard clamp-on and insertion transducers: -30°C to 90°C
- High-temperature clamp-on and insertion transducers: -30°C to 160°C


Pressure:

- The maximum pressure for standard insertion and inline transducers is 1.6 MPa. For applications outside this range, custom solutions are required.


Electromagnetic Interference (EMI):

Ultrasonic flow meters, along with their transducers and signal cables, are susceptible to interference from sources such as frequency converters, radio stations, microwave transmitters, GSM base stations, and high-voltage cables. To minimize EMI. Avoid installing equipment near these sources. Connect the shield layer of the flow meter, transducer, and signal cable to the earth. Use an isolated power supply. Do not share a power supply with frequency converters.


VIR-832 Flow Meter Wall Mount Integrated Transmitter/ Heat Calculator





VIR-850 Flow Meter with integrated Transmitter/ Heat Calculator




VIR-832-M Dinrail Transmitter/ Heat Calculator





Clamp – On Flow Detector Wiring:



Insertion Transducer Details:



Inline Flow Part: 65-UF series for use with VIR 832M or VIR832 Flow/Heat meter



Parameters & Menu Details:

Menu No.	Function
M00	Display flow rate and NET totalizer.
	If the net totalizer is turned off (refer to M34), the net totalizer value shown on the screen is the value prior to its turn off.
	Select all totalizer unit in menu M31.
M01	Display flow rate, velocity.
M02	Display flow rate and POS (positive) totalizer.
	If the positive totalizer is turned off, the positive totalizer value shown on the screen is the value prior to its turn off.
M03	Display flow rate and NEG (negative) totalizer.
	If the negative totalizer is turned off, the negative totalizer value shown on the screen is the value prior to its turn off.
M04	Display date and time, flow rate. The date and time setting method is found in MENU60.
M05	Display energy rate (instantaneous Caloric) and total energy (Caloric).
M06	Display temperatures, inlet T1, outlet T2.
M07	Display analogue inputs, AI3/AI4, current value and its corresponding temperature or pressure or liquid level value.
M08	Display all the detailed error codes.
	Display working condition and system error codes. 'R' stands for normal; others refer to Chapter 5 for details.

M09	Display today's total NET flow.
M10	Window for entering the outer perimeter of the pipe. If pipe outer diameter is known, skip this menu and go to Menu 11 to enter the outer diameter.
M11	Window for entering the outer diameter of the pipe. Valid range:0 to 18000mm. Note: you just need to enter either the outer diameter in M11 or the perimeter in M10.
M12	Window for entering pipe wall thickness You may skip the menu and enter inner diameter in M13 instead.
M13	Window for entering the inner diameter of the pipe If pipe outer diameter and wall thickness are entered correctly, the inner diameter will be calculated automatically, thus no need to change anything in the window
M14	Window for selecting pipe material Standard pipe materials (No need to enter material sound speed) include: (0) carbon steel (1) stainless steel (2) cast iron (3) ductile iron (4) copper (5) PVC (6) aluminium , (7) asbestos (8) fiberglass (9) other(need to enter material sound speed in M15)
M15	Window for entering the pipe material speed, only for non-standard pipe materials
M16	Window for selecting the liner material, select none for pipes without any liner.

	<p>Standard liner materials(no need to enter the liner sound speed) include:</p> <p>(0) None, No liner (1) Tar Epoxy (2) Rubber (3) Mortar (4) Polypropylene (5) Polystyrene (6)Polystyrene (7) Polyester (8) Polyethylene (9) Ebonite (10) Teflon (11) Other (need to enter liner sound speed in M17)</p>
M17	Window for entering the non-standard liner material speed.
M18	Window for entering the liner thickness, if there is a liner
M19	Window for entering the ABS thickness of the inside wall of the pipe
M20	<p>Window for selecting fluid type</p> <p>For standard liquids(no need to enter fluid sound speed) include:</p> <p>(0) Water (1) Sea Water (2) Kerosene (3) Gasoline (4) Fuel oil (5) Crude Oil (6) Propane at -45C (7) Butane at 0C (8)Other liquids(need to enter sound speed in M21 and viscosity in M22) (9) Diesel Oil (10)Caster Oil (11)Peanut Oil (12) #90 Gasoline (13) #93 Gasoline (14) Alcohol (15) Hot water at 125C</p>
M21	Window for entering the sound speed of non- standard liquid, used only when option item 8 'Other' is selected in M20
M22	Window for entering the viscosity of the non-standard liquids, used only when option item 8 'Other' is selected in M20
M23	Window for selecting transducer type, There are 22 types as following

	<p>0. Standard-M (The middle size) 1. Insertion Type C</p> <p>2. Standard-S 3. User Type 4. Standard B</p> <p>5. Insertion Type B(45) 6. Standard-L (The large size transducers)</p> <p>7. JH-Polyconics 8. Standard-HS (small size transducer for TUF-2000H)</p> <p>9. Standard-HM (middle size transducer for Handheld flow meter)</p> <p>10. Standard-M1 (middle size transducer #1)</p> <p>11. Standard-S1 (small size transducer #1)</p> <p>12. Standard-L1 (large size transducer #1)</p> <p>13. PI-Type 14. FS410 (middle size transducer for FUJI flow meter)</p> <p>15. FS510 (large size transducer for FUJI flow meter)</p> <p>16. Clamp-on TM-1 (Middle size transducer for Taosonics Instrument)</p> <p>17. Insertion TC-1 (for Virtec)</p> <p>18. Clamp-on TS-1 (small size for Taosonics Instrument)</p> <p>19. Clamp-on TS-1 20. Clamp-on TL-1 (For Virtec)</p> <p>21. Insertion TLC-2 (For Virtec)</p> <p>22. Clamp-on M2 23. Clamp-on L2</p>
	If the user-type-transducer is selected, you need enter additional 4 user-type-wedge parameters that describe the user transducers.
	If the PI-type transducer is selected, you need enter additional 4 PI-type transducer parameters that describe the PI-type transducers
M24	<p>Window for selecting the transducer mounting methods</p> <p>Four methods can be selected:</p>

	(0) V-method (1) Z-method (2) N-method (3) W-method
M25	Display the transducer mounting spacing or distance
M26	<p>(1) A switch for the parameters in flash memory will be loaded when power is turned on. The default option is that the parameters will be loaded. If this switch is not turned on, the system will try to use the parameters in the system RAM, if these parameters are ok, otherwise the system will load the parameters in flash memory</p> <p>(2) Function to store the current parameters into the flash memory, so that these parameters will be solidified and will be loaded as the default parameters every time when power is turned on.</p>
M27	<p>Entry to store to or restore from the internal Flash memory, as many as 9 different pipe parameter configurations</p> <p>To save or load the current setup parameter, use the going up or going down keys to change the address number, press 'ENT' key, and use going down or going up keys to select to save to or load from the memory.</p>
M28	Entry to determine whether or not to hold (or to keep) the last good value when poor signal condition occurs. YES is the default setup.
M29	<p>Entry to setup empty signal threshold. When the signal is less than this threshold, the pipe is regarded as empty pipe, and the flow meter will not totalize flow.</p> <p>This is based on the fact that, for most occasions, when pipe is empty, the transducer would still receive signal, just smaller than normal, As a result, The flow meter would show normal operation, which is not correct.</p> <p>Make sure that the entered value must be less than the normal signal strength.</p> <p>When much noisy signals are received, to make sure the flow meter will not incorrectly totalize flow, there is also a 'Q' threshold should be entered in M.5</p>
M30	Window for selecting unit system. The conversion English to Metric or vice versa will not affect the unit for totalizers.
M31	Window for selecting flow rate unit system.

	Flow rate can be in
	0. Cubic meter short for (m ³)
	1. Liter (l)
	2. USA gallon (gal)
	3. Imperial Gallon (igl)
	4. Million USA gallon (mgl)
	5. Cubic feet (cf)
	6. USA liquid barrel (bal)
	7. Oil barrel (ob)
	The flow unit in terms of time can be per day, per hour, per minute or per second. So, there are 32 different flow rate units in total for selection.
M32	Window for selecting the totalizers unit. Available units are the same as those in M31
M33	Window for setting the totalizer multiplying factor The multiplying factor ranges from 0.001 to 10000. Factory default is 1
M34	Turn on or turn off the NET totalizer
M35	Turn on or turn off the POS (positive) totalizer
M36	Turn on or turn off the NEG (negative) totalizer
M37	(1) Totalizer reset (2) Restore the factory default settings parameters. Press the dot key followed by the backspace key. Attention, it is recommended to make note on the parameters before doing the restoration
M38	Manual totalizer used for easier calibration. Press a key to start and press a key to stop the manual totalizer.
M39	Language selection. The selection could also be changed automatically by the system, if English LCD display is used as the display device.

M3A	Setup for local segmental LCD display. Enter 0 or 1 for the non-auto-scan mode; Enter 2~39 for the auto-scan mode. In the auto-scan mode the display will automatically scan displaying from 00 to the entered number of the local segmental LCD display.
M40	Flow rate damper for a stable value. The damping parameter ranges from 0 to 999 seconds.
	0 means there is no damping. Factory default is 10 seconds
M41	Low flow rate (or zero flow rate) cut-off to avoid invalid accumulation.
M42	Zero calibration/Zero-point setup. Make sure the liquid in the pipe is not running while doing the setup.
M43	Clear the zero point value and restore the solidified zero-point value.
M44	Set up a flow bias. Generally, this value should be 0.
M45	Flow rate scale factor. The default value is '1'.
	Keep this value as '1', when no calibration has been made.
M46	Networks address identification number. Any integer can be entered except 13(0DH, carriage return), 10 (0AH, line feeding), 42 (2AH), 38, 65535.
	Every set of the instrument in a network environment should have a unique IDN. Please refer to the chapter for communication.
M47	System locker to avoid modification of the system parameters.
	If password is forgotten, you could send a command 'LOCK0' to the serial input to unlock. Or you can write 0 to REGISTER49-50 under MODBUS protocol.
M48	Entry to linearity correcting data inputs. By using of this function, the non-linearity of flow meter will be corrected. Correcting data shall be obtained by careful calibration.

M49	Displays the input contents for the serial port.
	By checking the displays, you can know if the communication is ok.
M50	Switches for the built-in data logger. There are as many as 22 different items can be chosen. To turn this function, select 'YES' the system will ask for selecting the items. There are 22 items available. Turn on all those items you want to output
M51	Window to setup the time of scheduled output function (data logger, or Thermo-printer). This includes start time, time interval and how many times of output. When a number great than 8000 entered for the times of output, it means the output will be keeping always. The minimum time interval is 1 second and the maximum is 24 hours.
M52	<p>Data logging direction control.</p> <p>(1) If 'Send to RS485' is selected, all the data produced by the data logger will be transmitted out through the RS-232/RS485 interface</p> <p>(2) If 'To the internal serial BUS is selected, the data will be transmitted to the internal serial bus which allows a thermal printer, or a 4-20mA analogue output module, to be connected to it.</p>
M53	Display antilog inputs, AI5, current value and its corresponding temperature or pressure or liquid level value.
M54	Pulse width setup for the OCT (OCT1) output. Minimum is 6 mS, maximum is 1000 mS
M55	<p>Select analogue output (4-20mA current loop, or CL) mode. Available options:</p> <p>(0) 4-20mA output mode (setup the output ranges from 4-20mA)</p> <p>(1) 0-20mA output mode (setup the output ranges from 0-20mA, this mode can only be used with Version-15 flow meter)</p> <p>(2) RS232 Serial port controls 0-20mA</p> <p>(3) 4-20mA corresponding fluid sound speed</p> <p>(4) 20-4-20mA mode</p>

	(5) 0-4-20mA mode (can only be used with Version-15 flow meter)
	(6) 20-0-20mA mode (can only be used with Version-15 flow meter)
	(7) 4-20mA corresponding flow velocity
	(8) 4-20mA corresponding heat flow rate
M56	4mA or 0mA output value, Set the value which corresponds to 4mA or 0mA output current (4mA or 0mA is determined by the setting in M55)
	20mA output value, Set the value which corresponds to 20mA output current
M57	Current loop verification Check if the current loop is calibrated correctly.
	Display the present output of current loop circuit.
M59	Setup system date and time. Press ENT for modification. Use the dot key to skip the digits that need no modification.
M60	Display Version information and Electronic Serial Number (ESN) that is unique for each flow meter. The users may employ the ESN for instrumentation management
	RS-232/RS485 setup. All the devices connected with flow meter should have matched serial configuration. The following parameters can be configured: Baud rate (300 to 19200 bps), parity, data bits (always is 8), stop bits (1).
M63	Select communication protocol. Factory default is ‘MODBUS ASCII’. this is a mode for MODBUS-ASCII, Meter-BUS, Fuji Extended Protocol, Huizhong’s various protocols. If you are going using MODBUS-RTU you have to select ‘MODBUS_RTU’.
	AI3 value range.
	Used to enter temperature/pressure values that are corresponding to 4mA and 20mA input current. The display values have no unit, so that they can present any physical parameter.

M65	AI4 value range. Used to enter temperature/pressure values that are corresponding to 4mA and 20mA input current.
M66	AI5 value range. Used to enter temperature/pressure values that are corresponding to 4mA and 20mA input current.
M67	Windows to setup the frequency range (lower and upper limit) for the frequency output function. Valid range is 0Hz-9999Hz. Factory default value is 0-1000 Hz. For Version-12, Version-13, Version-14 flow meters, you need a hardware module, which shall be plugged to the Serial Expanding Bus, for the frequency output function. Please remember to order the module if you need frequency output function. For Version-15 flow meter, you need to indicate on your orders that you need the frequency function; Otherwise, you will get a flow meter which has no frequency output circuits.
M68	Window to setup the minimum flow rate value which corresponds to the lower frequency limit of the frequency output.
M69	Windows to setup the maximum flow Rate value that corresponds to the upper frequency limit of the frequency output.
M70	LCD display backlight control. The entered value indicates how many seconds the backlight will be on with every key pressing. If the enter value is great than 50000 seconds, it means that the backlight will always keeping on.
M71	LCD contrast control. The LCD will become darker or brighter when a value is entered.
M72	Working timer. It can be cleared by pressing ENT key, and then select YES.
M73	Window to setup the lower limit of flow rate for Alarm#1. When the flow rate is below the set value, Alarm#1 equals 'on'
M74	Window to setup the upper limit of flow rate for Alarm#1. When the flow rate is above the set value, Alarm#1 equals 'on' There are two alarms in the flow meter, and every alarm can be pointed to alarm output devices such as the BUZZER or OCT output or RELAY output. For example, if you want the Alarm#1 is to output by the OCT circuit, you need to set M78 at selection item 6.

M75	Window to setup the lower limit of flow rate for Alarm#2.
M76	Window to setup the upper limit of flow rate for Alarm#2.
M77	<p>Buzzer setup.</p> <p>If a proper input source is selected, the buzzer will beep when the trigger event occurs. The available trigger sources are:</p> <p>0. No Signal 1. Poor Signal</p> <p>2. Not Ready (No*R) 3. Reverse Flow 4. AO Over 100%</p> <p>5. FO Over 120% 6. Alarm #1 7. Reverse Alarm #2</p> <p>8. Batch Controller 9. POS Int Pulse 10.NEG Int Pulse</p> <p>11.NET Int Pulse 12. Energy POS Pulse 13. Energy NEG Pulse</p> <p>14.Energy NET Pulse 15. MediaVel=>Thresh 16.MediaVelo<Thresh</p> <p>17.ON/OFF viaRS485 18. Daily Timer (M51) 19.Timed alarm #1</p> <p>20. Timed alarm #2 21. Batch Total Full 22. Timer by M51</p> <p>23. Batch 90% Full 24. Key Stroking ON 24.Disable BEEPER</p>
M78	<p>OCT (Open Collect Transistor Output)/OCT1 setup</p> <p>By selecting a proper input source, the OCT circuit will close when the trigger event occurs. The available trigger sources are:</p> <p>0. No Signal 1. Poor Signal</p> <p>2. Not Ready(No*R) 3. Reverse Flow</p> <p>4. AO Over 100% 5. FO Over 120%</p> <p>6. Alarm #1 7. Reverse Alarm #2</p> <p>8. Batch Controller 9. POS Int Pulse</p>

	10.NEG Int Pulse	11.NET Int Pulse
	12.Energy POS Pulse	13.Energy NEG Pulse
	14.Energy NET Pulse	15.MediaVel=>Thresh
	16.MediaVelo<Thresh	17.ON/OFF viaRS485
	18. Daily Timer (M51)	19.Timed alarm #1
	20. Timed alarm #2	21.Batch Total Full 22.Timer by M51
	23.Batch 90% Full	24.Flow Rate Pulse 25.Disable OCT
	The OCT circuit does not source voltage at its output. It must be connected with an external power and pull-up resistor for some occasions.	
	When the OCT circuit is closed, it will draw current. The maximum current shall not be over 100mA.	
	Attention: the maximum voltage applied to OCT can not be over 80 volts.	
M79	Relay or OCT2 setup	
	By selecting a proper input source, the RELAY will close when the trigger event occurs	
	The available trigger sources are:	
	0. No Signal	1. Poor Signal
	2. Not Ready(No*R)	3. Reverse Flow 4. AO Over 100%
	5. FO Over 120%	6. Alarm #1 7. Reverse Alarm #2
	8. Batch Controller	9. POS Int Pulse 10.NEG Int Pulse
	11.NET Int Pulse	12.Energy POS Pulse

	13.Energy NEG Pulse 14.Energy NET Pulse
	15.MediaVel=>Thresh 16.MediaVelo<Thresh
	17.ON/OFF viaRS485 18. Timer (M51 Daily)
	19.Timed alarm #1 20. Timed alarm #2
	21.Batch Total Full 22.Timer by M51
	23.Batch 90% Full 24.Disable RELAY
	The RELAY is of SPST(Single pole, single throw) type. It is rated for 110VAC max and have a current rating of 0.5A resistive load. It highly recommended that a salve relay to be utilized whenever a large resistive load or inductive load is to be controlled. Note. In order to make the user interface compatible with the former version7, the name RELAY was used other than OCT2, but in fact it is an OCT output.
M80	Window for selecting the trigger signal for the built-in batch controller. Available trig sources: 0. Key input (press ENT key to start the batch controller) 1. Serial port 2. AI3 rising edge (when AI3 receives 2mA or more current) 3. AI3 falling edge (when AI3 stop receiving 2mA or more current) 4. AI4 rising edge (when AI3 receives 2mA or more current) 5. AI4 falling edge (when AI3 stop receiving 2mA or more current) 6. AI5 rising edge (when AI3 receives 2mA or more current) 7. AI5 falling edge (when AI3 stop receiving 2mA or more current) 8.Timer periodically (define the start time and interval time in M51)

	9.Timer daily (define the start time and interval time in M51)
	For the input analogue current signal, 0 mA indicates “0”, 4mA or more indicates ‘1’. By selecting item #8, the batch totalizer can be started periodically by the internal timer located at Menu51. When the batch totalizer is full, a signal which indicate the batch is full can be direct to either the OCT or the RELAY terminals to stop the pump or other devices.
	By selecting item #9, the batch totalizer could act as totalizer witch runs for only a period of the day so that a alarm signal could be produced if the total flow during that time period is over a certain amount of. For example, if you want a alarm signal which stand for the total flow is over 100 cubic meters during the period of every day from 20:00 to 06:00, setups is like
	M51 start time =20:00:00
	M51 interval =10:00:00
	M51 log times =9999 (means always)
	M80 select item #9
	M81 input 100 (Unit is defined in M30,M31,M32)
M81	The built-in batch controller Set the flow batch value(dose) The internal output of the batch controller can be directed either to the OCT or the RELAY output circuits. M81 and M80 should be used together to configure the batch controller. Note: Because the measuring period is 500mS, the flow for every dos should be keeping at 60 seconds long to get a 1% dose accuracy.
M82	View the daily, monthly and yearly flow totalizer and thermal energy totalizer value. The totalizer values and errors for the last 64 days, 32 last 32 months and last 2 years are stored in the RAM memory, To view them, use the ‘ENT’ and ‘UP’ ‘Down’ keys.

M83	Automatic Amending Function for automatic offline compensation.
	Select 'YES' to enable this function, select 'NO' to disable it.
	When the function is enabled, The flow meter will estimate the average flow uncounted (or 'lost') during the offline session and add the result to the totalizer.
	The estimation of the uncounted flow is made by computing the product of the offline time period and the average flow rate, which is the average of the flow rate before going offline and the one after going on line.
M84	Set the thermal energy unit: 0. GJ 1. KC 2.KWh 3. BTU
M85	Select temperature sources 0. from T1,T2 (factory default) 1. from AI3,AI4
M86	Select the Specific Heat Value. Factory default is 'GB'. Under this setting, the flow meter will calculate the enthalpy of water based on the international standard. If the fluid is other than water, you should select option '1. Fixed Specific Heat', and enter the specific heat value of the fluid.
M87	Turn on or turn off the Energy totalizer.
M88	Select thermal energy totalizer multiplying factor. Factory default is '1'.
M89	1. Display the temperature difference 2. Window for entering the lowest temperature difference.
M8.	Heat meter is on 1. Inlet 2. Outlet

	Select the heat meter installation place.
M90	<p>Display signal strengths S (one for upstream and one for downstream), and signal quality Q value.</p> <p>Signal strength is presented by 00.0 to 99.9, the bigger the value, the bigger the signal strength will be, and more reliable readings will be made.</p> <p>Q value is presented by 00 to 99, the bigger the better. It should at least be great than 50 for normal operations.</p>
M91	Displays the Time Ratio between the Measured Total Transit Time and the Calculated time. If the pipe parameters are entered correctly and the transducers are properly installed, the ratio value should be in the range of $100\pm3\%$. Otherwise the entered parameters and the transducer installation should be checked.
M92	Displays the estimated fluid sound velocity. If this value has an obvious difference with the actual fluid sound speed, pipe parameters entered and the transducer installation should be checked again.
M93	Displays total transit time and delta time(transit time difference)
M94	Displays the Reynolds number and the pipe factor used by the flow rate measurement program. Pipe factor is calculated based on the ratio of the line-average velocity and the cross-section average velocity.
M95	<p>(1) Display the positive and negative energy totalizers</p> <p>(2) Upon entering this window, the circular display function will be started automatically. The following windows will be displayed one by one, each window will stay for 8 seconds: M95>>M00>>M01>>M02>>M02>> M03>>M04>>M05>>M06>>M07>>M08>>M90>>M91>>M92>> M93>> M94>>M95. This function allows the user to visit all the important information without any manual action.</p> <p>To stop this function, simply press a key. Or switch to a window other than M95.</p>
M96	This is not a window but a command for the thermal printer to advance 5 lines of paper.
M97	This is not a window but a command to print the pipe parameters.

	By default, the produced data will be directed to the internal serial bus (thermal printer). You can also direct those data to the serial communication port.
M98	This is not a window but a command to print the diagnostic information.
	By default, the produced data will be directed to the internal serial bus (thermal printer). You can also direct those data to the serial communication port.
M99	This is not a window but a command to copy the current display window. By default, the produced data will be directed to the internal serial bus (thermal printer). You can also direct those data to the serial communication port.
	By use of the window copying function, you can hardcopy very window displaying manually by switching windows, or you can obtain the window displaying data by communication.
M+0	Browse the 32 recorded instrument power-on and power-off date and time with the flow rate at the time of power on and off
M+1	Displays the total working time of the flow meter.
	When the backup battery is removed, the total working time will be reset to zero.
M+2	Displays the last power-off date and time
M+3	Displays the last power-off flow rate
M+4	Displays how many times of has been powered on and powered off.
M+5	A scientific calculator for the convenience of field working.
	All the values are in single accuracy.
	The calculator can be used while the flow meter is conducting flow measurement.

	Water density and PT100 temperature can also be found in this function.
M+6	Set fluid sound speed threshold
	Whenever the estimated sound speed (displayed in M92) exceeds this threshold, an alarms signal will be generated and can transmitted to BUZZER or OCT or RELAY.
	This function can used to produce an alarm or output when fluid material changes.
M+7	Displays total flow for this month(only for the time past)
M+8	Displays total flow for this year(only for the time past)
M+9	Display the not-working total time in seconds. The total failure timer will also include the time when power off, if the back-up battery is applied.
M.2	Entry to solidify the zero point. Password protected.
M.5	Setup the Q value threshold.
	If the present Q is below this threshold, flow rate will be set to 0.
	This function is useful when flow meter is installed in noisy environment or on airy pipes.
M.8	The maximum flow rates for today and this month.
M.9	Serial port tester with CMM command output for very second.
M-0	Entry to hardware adjusting windows only for the manufacturer
M-1	4-20mA output adjustment

M-2	4mA calibration for AI3 input
M-3	20mA calibration for AI3 input
M-4	4mA calibration for AI4 input
M-5	20mA calibration for AI4 input
M-6	4mA calibration for AI5 input
M-7	20mA calibration for AI5 input
M-8	Lower Temperature Zero setup for the PT100
M-9	Higher Temperature Zero setup for the PT100
M-A	Temperature Calibration at 50°C
M-B	Temperature Calibration at 84.5°C

Additional Considerations for Installation

For precise output, the flow meter comes equipped with a 4~20mA current loop, offering accuracy within 0.5%. The system allows for easy programming and supports various output modules, including 4~20mA. To configure these settings, navigate to the "Setup Menu - Input and Output Setting."

Within this menu, you can calibrate the flow values corresponding to 4mA and 20mA. For example:

- If the flow measurement range is 0 to 1000 m³/h, enter 0 for 4mA and 1000 for 20mA.
- For a range of -1000 to 2000 m³/h, configure the module to cover the full flow direction by inputting -1000 and 2000.

Analog Output Calibration:

Each flow meter undergoes strict calibration before leaving the factory, so further adjustment is generally unnecessary. However, if the actual output current value does not match the value displayed in the "Setup Menu - Input and Output Setting" during calibration, recalibration may be required.

Product Support & Warranty

Virtec Instruments assures that all flow meters are manufactured with the highest standards of quality and precision. For warranty details, service support, and installation queries, please refer to the Warranty Certificate provided or contact our authorized service center.



Warranty Coverage:

- 2 years from the date of Supply against following:
- Manufacturing defects
- Sensor malfunctions
- Electronics issues (as per model specifications)
- Warranty does not cover:
 - Physical damage
 - Improper installation
 - Tampering with seal or calibration



Technical Support

- If you require assistance, please reach out to:



Note to Installer / User

Please ensure that:

- All installation steps were followed as per guidelines.
- Calibration and commissioning have been documented.
- Maintenance schedule is noted for future checks.



Service Log (For User Use)

Date	Service Description	Technician Name & Sign	Remarks



Document Control

- Document Title: Flow Meter Installation & Operation Manual
- Document No.: VIR-FM-UM-2021
- Revision: R2.0 Last Updated: July 2024



Virtec Instruments Inc.

2005 E 2700 S, STE 200 Salt Lake City, UT-84109,USA

+1 (304) 519-4567 | sales@virtec.us | www.virtec.us

Virtec is one of the global leaders providing Heat & Flow management solutions in HVAC & Water applications. The solutions are based on two measuring technologies, Ultrasonic & Electromagnetic principle. Our high-end services and cutting-edge product solutions in this field have made us the leading providers of technologically advanced Heat and Flow measuring instruments.

VIR-850, VIR-832 series & Virtec logo are registered trademarks of Virtec Instruments, Inc. USA.

Other trademarks appearing in this document are the property of their respective entities. Due to continuous research, product improvements and enhancements, Virtec reserves the right to change product or system specifications without notice, except to the extent an outstanding contractual obligation exists. © 2024 Virtec Instruments, Inc. All rights reserved.