

For Evaluation Purposes Only

Independent Engineering Report

Ardenfell Engineering Advisors Subject: Technical Review — Wrenfield Residential Solar Portfolio **Date:** February 10, 2026 **Prepared for:** Halcyon Infrastructure Partners **Report reference:** AEA-2026-0147

1. Scope of Review

Ardenfell Engineering Advisors was engaged to perform an independent technical review of the Wrenfield Residential Solar Portfolio in connection with a proposed acquisition. Our review covered the installed asset base, the contracted expansion program, cost assumptions, and the delivery schedule. This report presents our findings and the basis for our conclusions.

2. Technical Review

Aggregate portfolio capacity of 250 MW was verified against interconnection documentation provided in the data room. The installed base shows performance consistent with regional irradiance expectations, and availability figures are within industry norms for distributed residential assets.

The expansion program design assumes Tier-1 440 W modules, which we consider appropriate for residential applications and consistent with current procurement availability.

3. Cost Assessment

We estimate total expansion installation cost at \$211M. Our estimate reflects current labor rates in the portfolio's target markets, observed equipment pricing, and mobilization costs across a distributed installation program of this scale. We note that our estimate is not reconciled to the sponsor's internal figures and should be read as an independent bottom-up assessment.

The O&M cost assumption of \$14.2M per year is within market range for a portfolio of this composition and geographic spread.

4. Schedule

Commercial operation of the expansion tranche is achievable by Q4 2027, provided installation mobilization proceeds on the currently contemplated timeline and permitting activity continues at observed rates.

For Evaluation Purposes Only

5. Summary of Findings

Item	Assessment
Aggregate portfolio capacity	250 MW (verified)
Expansion installation cost (independent estimate)	\$211M
Expansion commercial operation	Achievable by Q4 2027
Module design assumption	Tier-1 440 W
O&M cost assumption	\$14.2M per year — within market range

6. Assumptions and Limitations

This review relies on documentation provided in the data room as of the report date. We have not independently verified counterparty contractual standing or financing arrangements, which fall outside the scope of this engagement.

Synthetic document created for hackathon demonstration purposes.