

## **Fraser Valley Fire Protection Ltd.**

Date: September 3, 2026

To: Northgate Mechanical & General / Elm Street Engineering

Re: Maple Ridge Commons - Suite 305 sprinkler head relocation

This letter confirms that the pendent sprinkler head in the ceiling space of Suite 305 was relocated on September 2, 2026 to provide clearance from the new supply duct. The head was re-piped from the existing branch line and the system was restored to service and pressure tested the same day.

Photos will be provided by the general contractor once ceiling finishes are reinstated.

Signed,

R. Dhaliwal, Project Manager