

Fraser Valley Fire Protection Ltd.

Date: September 8, 2026

To: Cedar Ridge Construction / Voltas Engineering

Re: Laurel - Unit F, upper floor, bedroom #2 walk-in closet

This letter confirms that one pendent sprinkler head was added in the walk-in closet of bedroom #2, upper floor, Unit F on September 6, 2026, piped from the existing branch line. The system was refilled and pressure tested the same day.

A photo will be provided by the general contractor once the ceiling patch is painted.

Signed,

Project Manager

Fraser Valley Fire Protection Ltd.