


GRID CONTROLLER OF INDIA LIMITED

NATIONAL LOAD DESPATCH CENTRE, NEW DELHI



Frequency profile for 23-Jun-2026 (Tuesday)



<49.7	<49.90	<49.97	49.7-49.8	49.8-49.9	49.9-50.0	50.0-50.1	50.1-50.2	49.90-50.05	49.7-50.2	49.97-50.03	50.05-50.1	>50	>50.03	>50.05	>50.2	<49.95	49.95-50.05	49.90-49.95
0.00	4.33	20.23	0.00	4.33	36.12	56.89	2.48	78.06	99.81	45.22	14.95	59.55	34.55	17.62	0.19	11.34	71.04	7.01

Average Frequency : 50.007	Frequency Variation Index : 0.0282	Standard Deviation : 0.0526	Mileage: 44.7	FDI: 21.9
----------------------------	------------------------------------	-----------------------------	---------------	-----------

Instantaneous Frequency		
Max	50.224	13:05:30
Min	49.820	16:43:50

15 minute Average Frequency		
Max	50.149	13:15:00
Min	49.872	9:45:00

No. of excursions	
above 50.03 Hz	204
below 49.97 Hz	133
above 50.00 Hz	170
below 50.00 Hz	169

Average time freq per excursion remains	
below 49.97	0:02:11
above 50.03	0:02:26

No. of hours freq outside 49.9-50.05 Hz	5:16:00
---	---------

Source : BALIPARA 10 Sec. (8640 samples)