portable fire-extinguishing appliances, the means of access to the various compartments and decks in the craft, the ventilating system including particulars of the master fan controls, the positions of dampers and identification numbers of the ventilating fans serving each section of the craft, the location of the international shore connection, if fitted, and the position of all means of control referred to in 7.5.3, 7.6.2, 7.7.1 and 7.7.4. The text of such plans* should be in the official language of the flag State.
* Refer to Graphical symbols for fire control plans adopted by the Organization by resolution A.654(16). W/1576n/pp/EWP RESOLUTION MSC.36(63) (adopted on 20 May 1994) ADOPTION OF THE INTERNATIONAL CODE OF SAFETY FOR HIGH SPEED CRAFT MSC 63/23/Add.2 ANNEX 18 Page 76 7.9.2 7.9.3 7.9.3.1 7.9.3.2 7.9.3.3 However, if the language is neither English nor French, atranslation into one of those languages should be included. Aduplicate set of fire control plans or abooklet containing such plans should be permanently stored in aprominently marked weathertight enclosure outside the deckhouse for the assistance of - Aduplicate set of fire control plans or abooklet containing such plans should be permanently stored in aprominently marked weathertight enclosure outside the deckhouse for the assistance of shore side fire-fighting personnel. Openings in fire-resisting divisions Except for the hatches between cargo, special category, store, and baggage spaces and between such spaces and the weather decks, all openings should be provided with permanently attached means of closing which should be at least as effective for resisting fires as the divisions in which they are fitted. It should be possible for each door to be opened and closed from each side of the bulkhead by one person only. Fire doors bounding major fire hazard areas and stairway enclosures should satisfy the following requirements: .1 The doors should be self-closing and be capable of closing with an angle of inclination of up to 3.5 0 opposing closure, and should have an approximately uniform rate of closure of no more than 40 sand no less than 10 swith the craft in the upright position • . 2 Remote-controlled sliding or power-operated doors should be - and should have an approximately uniform rate of closure of no more than 40 sand no less than 10 swith the craft in the upright position • . 2 Remote-controlled sliding or power-operated doors should be equipped with an alarm that sounds at least 5 sbut no more than 10 sbefore the door begins to move and continue sounding until the door is completely closed. Doors designed to reopen upon contacting an object in their paths should reopen sufficiently to allow aclear passage of at least 0.75 m, but no more than 1 m • . 3 All doors should be capable of remote and automatic release from acontinuously manned central control station, either simultaneously or in groups, and also individually from aposition at both sides of the door. Indication should be provided at the fire control panel in the continuously manned control station whether each of the remote-controlled doors is closed. The release mechanism should be so designed that