* Refer to the Recommendation on fire test procedures for upholstered furniture, adopted by the Organization by resolution A.652(16). ** Refer to the Recommendation on fire test procedures for ignitability of bedding components, adopted by the Organization by resolution A.688(17). *** Refer to the Recommendation on improved fire test procedures for surface flammability of bulkhead, ceiling and deck finish materials, adopted by the Organization by resolution A.653(16) and the Recommendation on fire test procedures for ignitability of primary deck coverings, adopted by the Organization by resolution A.687(16). W/1576n/pp/EWP RESOLUTION MSC.36(63) (adopted on 20 May 1994) ADOPTION OF THE INTERNATIONAL CODE OF SAFETY FOR HIGH SPEED CRAFT MSC 63/23/Add.2 ANNEX 18 Page 62 7.4.3.9 The exhaust gas pipes should be arranged so that the risk of fire is kept to aminimum. To this effect, the exhaust system should be insulated and all the compartments and structures which are contiguous with the exhaust system, or those which may be affected by increased temperatures caused by waste gases in normal operation or in an emergency, should be constructed of non-combustible - contiguous with the exhaust system, or those which may be affected by increased temperatures caused by waste gases in normal operation or in an emergency, should be constructed of non-combustible material or be shielded and insulated with non-combustible material to protect from high temperatures. 7.4.3.10 The design and arrangement of the exhaust manifolds or pipes should be such as to ensure the safe discharge of exhaust gases. 7.4.4 Arrangement 7.4.4.1 Internal stairways which serve more than two decks of accommodation should be enclosed at all levels with smoke-tight divisions of non-combustible or fire-restricting materials, and where only two decks are served, such enclosures should be provided on at least one level. Stairways may be fitted in the open in apublic space, provided they lie wholly within such public space. 7.4.4.2 Lift trunks should be so fitted as to prevent the passage of smoke and flame from one deck to another and should be provided with means of closing so as to permit the control of draught and smoke. 7.4.4.3 In accommodation and service spaces, control stations, corridors and - and flame from one deck to another and should be provided with means of closing so as to permit the control of draught and smoke. 7.4.4.3 In accommodation and service spaces, control stations, corridors and stairways air spaces enclosed behind ceilings, panelling or linings should be suitably divided by close fitting draught stops not more than 14 mapart. 7.5 Fuel and other flammable fluid tanks and systems 7.5.1 Tanks containing fuel and other flammable fluids should be separated from passenger, crew, and baggage compartments by vapour-proof enclosures or cofferdams which are suitably ventilated and drained. 7.5.2 Fuel oil tanks should not be located in or contiguous to major fire hazard areas. However, flammable fluids of aflashpoint not less than 60°Cmay be located within such areas provided the tanks are made of steel or other equivalent material. 7.5.3 Every oil fuel pipe which, if damaged, would allow oil to escape from ast