Smoke 74 11 5.5
Combined
smoke and heat 74 9 4.5
2.4.2.2.1 The Administration may require or permit other spacing based upon test data which demonstrate the characteristics of the detectors. Detectors located below movable ro-ro decks shall be in accordance with the above.
2.4.2.2.2 The distance between two sensor cables of the linear heat detection system shall not be more than 9.0 m, while the distance between such cables and bulkheads shall not be more than 4.5 m."
2.5 System control requirements
2.5.1 Visual and audible fire signals

SOURCE: MSC.555(108).pdf
URL:
https://wwwcdn.imo.org/localresources/en/KnowledgeCentre/IndexofIMOResolutions/MSCResolutions/MSC.555(108).pdf
bulkheads shall not be more than 4.5 m."
2.5 System control requirements
2.5.1 Visual and audible fire signals
6 The following new paragraphs 2.5.1.2, 2.5.1.3 and 2.5.1.4 are inserted after paragraph 2.5.1.1 and the subsequent paragraphs are renumbered accordingly:
"2.5.1.2 On ro -ro passenger ships constructed on or after 1 January 2026, alarm notifications shall follow a consistent alarm presentation scheme (wording, vocabulary, colour and position). Alarms shall be immediately recognizable on the navigation bridge and shall not be compromised by noise or poor placing.
2.5.1.3 On ro -ro passenger ships constructed on or after 1 January 2026, the interface shall provide alarm addressability, allow the crew to identify the alarm history, the most recent alarm and the means to suppress alarms while ensuring the alarms with ongoing trigger conditions are still clearly visible.
RESOLUTION MSC.555(108) (adopted on 23 May 2024)

SOURCE: MSC.555(108).pdf
URL:
https://wwwcdn.imo.org/localresources/en/KnowledgeCentre/IndexofIMOResolutions/MSCResolutions/MSC.555(108).pdf
alarms with ongoing trigger conditions are still clearly visible.
RESOLUTION MSC.555(108) (adopted on 23 May 2024)
AMENDMENTS TO THE INTERNATIONAL CODE FOR FIRE SAFETY SYSTEMS (FSS CODE)
- 5 -
2.5.1.4 On ro-ro passenger ships constructed on or after 1 January 2026, the smoke detector function in special category and ro -ro spaces may be disconnected during loading and unloading of vehicles. The time of disconnection shall be adapted to the time of loading/unloading and be automatically reset after this predetermined t ime. The central unit shall indicate whether the detector sections are disconnected or not. Disconnection of the heat detection function or manual call points shall not be permitted."
RESOLUTION MSC.555(108) (adopted on 23 May 2024)
AMENDMENTS TO THE INTERNATIONAL CODE FOR FIRE SAFETY SYSTEMS (FSS CODE)
RESOLUTION MSC.555(108) (adopted on 23 May 2024)
AMENDMENTS TO THE INTERNATIONAL CODE FOR FIRE SAFETY SYSTEMS (FSS CODE)

SOURCE: MSC.555(108).pdf
URL:

https://wwwcdn.imo.org/localresources/en/KnowledgeCentre/IndexofIMOResolutions/MSCResolutions/MSC.555(108).pdf
RESOLUTION MSC.555(108) (adopted on 23 May 2024)
AMENDMENTS TO THE INTERNATIONAL CODE FOR FIRE SAFETY SYSTEMS (FSS CODE)
RESOLUTION MSC.555(108)
(adopted on 23 May 2024)
AMENDMENTS TO THE INTERNATIONAL CODE FOR FIRE SAFETY SYSTEMS
(FSS CODE)
THE MARITIME SAFETY COMMITTEE,
RECALLING Article 28(b) of the Convention on the International Maritime Organization concerning the functions of the Committee,
RECALLING ALSO resolution MSC.98(73), by which it adopted the International Code for Fire Safety Systems ("the FSS Code"), which has become mandatory under chapter II -2 of the International Convention for the Safety of Life at Sea, 1974 ("the Convention"),
RECALLING FURTHER article VIII(b) and regulation II -2/3.22 of the Convention concerning the procedure for amending the FSS Code,
HAVING CONSIDERED, at its 108th session, amendments to the FSS Code, proposed and circulated in accordance with article VIII(b)(i) of the Convention,
---
SOURCE: MSC.555(108).pdf
URL:
https://wwwcdn.imo.org/localresources/en/KnowledgeCentre/IndexofIMOResolutions/MSCResolutions/MSC.555(108).pdf
circulated in accordance with article VIII(b)(i) of the Convention,
1 ADOPTS, in accordance with article VIII(b)(iv) of the Convention, amendments to the FSS Code, the text of which is set out in the annex to the present resolution;
2 DETERMINES, in accordance with article VIII(b)(vi)(2)(bb) of the Convention, that the amendments shall be deemed to have been accepted on 1 July 2025 unless, prior to that date, more than one third of the Contracting Governments to the Convention, or Cont racting Governments the combined merchant fleets of which constitute not less than 50% of the gross tonnage of the world's merchant fleet have notified the Secretary -General of their objections to the amendments;
3 INVITES Contracting Governments to note that, in accordance with article VIII(b)(vii)(2) of the Convention, the amendments shall enter into force on 1 January 2026 upon their acceptance in accordance with paragraph 2 above;

SOURCE: MSC.555(108).pdf
URL:
https://wwwcdn.imo.org/localresources/en/KnowledgeCentre/IndexofIMOResolutions/MSCResolutions/MSC.555(108).pdf
upon their acceptance in accordance with paragraph 2 above;
4 REQUESTS the Secretary -General, in conformity with article VIII(b)(v) of the Convention, to transmit certified copies of the present resolution and the text of the amendments contained in the annex to all Contracting Governments to the Convention;
5 ALSO REQUESTS the Secretary-General to transmit copies of this resolution and its annex to Members of the Organization which are not Contracting Governments to the Convention.
RESOLUTION MSC.555(108) (adopted on 23 May 2024)
AMENDMENTS TO THE INTERNATIONAL CODE FOR FIRE SAFETY SYSTEMS (FSS CODE)

ANNEX
AMENDMENTS TO THE INTERNATIONAL CODE FOR FIRE SAFETY SYSTEMS
(FSS CODE)
CHAPTER 7

Fixed pressure water-spraying and
water mist fire-extinguishing systems
2 Engineering specifications
1 The following new section 2.5 is added after existing section 2.4 (Fixed water-based fire-fighting systems for ro-ro spaces, vehicle spaces and special category spaces):

SOURCE: MSC.555(108).pdf
URL:
https://wwwcdn.imo.org/localresources/en/KnowledgeCentre/IndexofIMOResolutions/MSCResolutions/MSC.555(108).pdf
fire-fighting systems for ro-ro spaces, vehicle spaces and special category spaces):
"2.5 Fixed water-based fire-extinguishing system on ro-ro passenger ships' weather decks intended for the carriage of vehicles
This paragraph details the specification of fixed water-based fire-extinguishing system on ro-ro passenger ships having weather decks intended for the carriage of vehicles as required by chapter II -2 of the Convention. The requirements of this paragraph shall apply to ro-ro passenger ships constructed on or after 1 January 2026.
2.5.1 The protected area shall be the entire length and width of the weather deck intended for the carriage of vehicles. The fixed monitor(s) shall be capable of delivering water to:
.1 the area of weather decks intended for carriage of vehicles; and
.2 the area, including superstructure boundaries located up to 8.0 m, measured horizontally, from the area intended for vehicle storage, or the next vertical boundaries, whichever is less.

SOURCE: MSC.555(108).pdf
URL:
https://wwwcdn.imo.org/localresources/en/KnowledgeCentre/IndexofIMOResolutions/MSCResolutions/MSC.555(108).pdf
measured horizontally, from the area intended for vehicle storage, or the next vertical boundaries, whichever is less.
2.5.2 The combined capacity of all fixed monitors shall be minimum 2.0 L/min per square metre of the protected area, but in no case shall the output of any monitor be less than 1,250 L/min. Even distribution of water shall be ensured.
2.5.3 The distance from the monitor to the farthest extremity of the protected area forward of that monitor shall not be more than 75% of the monitor throw in still air conditions.
2.5.4 Each monitor shall be located outside the area which it protects, in a safe position, with access not likely to be cut off in case of fire.
Monitors shall be installed in positions which allow for unobstructed water coverage with vehicles stowed to maximum capacity of the weather deck. However, areas that cannot be covered by water monitors shall be protected by water nozzles.

SOURCE: MSC.555(108).pdf
URL:
https://wwwcdn.imo.org/localresources/en/KnowledgeCentre/IndexofIMOResolutions/MSCResolutions/MSC.555(108).pdf
cannot be covered by water monitors shall be protected by water nozzles.
Nozzles shall be designed and installed taking into account weather conditions and provide 5.0 L/min per square metre for the area they cover and have release controls in a position being accessible in case of a fire.
2.5.5 The system shall be available for immediate use and capable of continuously supplying water. The water supply shall be capable of simultaneously supplying water at the required rate for the entire width of the weather deck intended for carriage of

vehicles and a length of 40 m, or the entire length of the weather deck if this is less than 40 m. In no case shall the supply capacity be less than that required for the largest monitor.

RESOLUTION MSC.555(108) (adopted on 23 May 2024)

AMENDMENTS TO THE INTERNATIONAL CODE FOR FIRE SAFETY SYSTEMS (FSS CODE)

2.5.6 The system may be supplied by the fire main, the pump(s) serving other fixed

---

SOURCE: MSC.555(108).pdf
URL: https://wwwcdn.imo.org/localresources/en/KnowledgeCentre/IndexofIMOResolutions/MSCResolutions/MSC.555(108).pdf

- 3 -

2.5.6 The system may be supplied by the fire main, the pump(s) serving other fixed water-based fire-fighting systems or a dedicated pump providing a continuous supply of seawater.

Where the ship's fire pumps are used to feed the monitor(s):

.1 it shall be possible to segregate the ship's fire main from the monitor(s) by means of a valve in order to operate both systems separately or simultaneously; and

.2 the capacity of the pumps shall be sufficient to serve both systems simultaneously, including two jets of water at the required pressure from the fire main system. In case the weather deck shall also carry dangerous goods, capacity for four jets of water at the required pressure shall be provided.

Where another fixed water-based fire-fighting system is used to feed the monitor(s):

.3 it shall be possible to segregate the other fixed water -based fire-fighting system from the monitor(s) by means of a valve in order

---

SOURCE: MSC.555(108).pdf
URL: https://wwwcdn.imo.org/localresources/en/KnowledgeCentre/IndexofIMOResolutions/MSCResolutions/MSC.555(108).pdf

.3 it shall be possible to segregate the other fixed water -based fire-fighting system from the monitor(s) by means of a valve in order to operate both systems separately or simultaneously; and

.4 the capacity of the pump(s) shall, in case of open ro -ro spaces, be sufficient to serve both systems simultaneously, minimum two sections of the fixed water-based fire-fighting system being close to the openings facing weather deck and one monitor serving the weather deck. For closed ro-ro spaces and special category spaces, simultaneous operation is not required."

CHAPTER 9