SOURCE: MSC.36(63).pdf
and
.4 the first initiated fire alarm should not prevent any
other detector to initiate further fire alarms.
RESOLUTION MSC.36(63)
(adopted on 20 May 1994)
ADOPTION OF THE INTERNATIONAL CODE OF SAFETY
FOR HIGH SPEED CRAFT MSC 53/23/Add.2
ANNEX 18
Page 58
7.7.2.2
Type
Installation requirements:
.1 Manually operated call points should be installed throughout
the accommodation spaces, service spaces and control stations.
One manually operated call point should be located at each
exit. Manually operated call points should be readily
accessible in the corridors of each deck such that no part of
the corridor is more than 20 m from a manually operated call
point
. 2 Smoke detectors should be installed in all stairways,
corridors and escape routes within accommodation spaces.
Consideration should be given to the installation of
special purpose smoke detectors within ventilation
ducting .
. 3 Where a fixed fire detection and fire alarm system is
required for the protection of spaces other than those
specified in .2, at least one detector complying "lith
7.7.2.1.11 should be installed in each such space .

---CHUNK---

SOURCE: MSC.36(63).pdf
ducting .
. 3 Where a fixed fire detection and fire alarm system is
required for the protection of spaces other than those
specified in .2, at least one detector complying "lith
7.7.2.1.11 should be installed in each such space .
. 4 Detectors should be located for optimum performance.
positions near beams and ventilation ducts or other positions
where patterns of air flow could adversely affect performance
and positions where impact or physical damage is likely should
be avoided. In general, detectors which are located on the
overhead should be a minimum distance of 0.5 m away from
bulkheads .
. 5 The maximum spacing of detectors should be in accordance with
the table below:
of detector Maximum floor area Maximum distance Maximum
per detector apart between distance away
centres from bulkheads
Heat 37 m2 9 m 4.5 m
Smoke 74 m2 11 m 5.5 m
The Administration may require or permit other spacings based

upon test data which demonstrate the characteristics of the detectors .

. 5 Electrical wiring which forms part of the system should be so arranged as to avoid machinery spaces of major fire hazard, and other enclosed spaces of major fire hazard except, where

---CHUNK---

SOURCE: MSC.36(63).pdf

detectors .

. 5 Electrical wiring which forms part of the system should be so arranged as to avoid machinery spaces of major fire hazard, and other enclosed spaces of major fire hazard except, where it is necessary, to provide for fire detection or fire alarm in such spaces or to connect to the appropriate power supply.

W/1575n/pp/EWP

RESOLUTION MSC.36(63)

(adopted on 20 May 1994)

ADOPTION OF THE INTERNATIONAL CODE OF SAFETY FOR HIGH SPEED CRAFT 7.7.2.3

7.7.3

Design requirements:

MSC 63 / 23/Add.2

ANNEX 18

Page 69

.1 The system and equipment should be suitably designed to withstand supply voltage variation and transients, ambient temperature changes, vibration, humidity, shock, impact and corrosion normally encountered in ships.

'" I

.2 Smoke detectors required by paragr,aph 7.7.2.2.2 should be certi~ied to operate before the smoke density exceeds l2.5~ ObSC.llfation per metre, but not un:t.il the smoke ; density exceeds 2~ obscuration per metre. Smok~ .detectors to be installed in other spaces should operate with,in sensitivity limits to the satisfaction of the Administration having regard to the

---CHUNK---

SOURCE: MSC.36(63).pdf

2~ obscuration per metre. Smok~ .detectors to be installed in other spaces should operate with,in sensitivity limits to the satisfaction of the Administration having regard to the avoidance of detector insensitivity or over-sensitivity .

. 3 Heat detectors should be certified to operate before the temperature exceeds 78°C but not until the temperature exceeds 54°C, when the temperature is raised to those limits at a rate less than 1°C per minute. At higher rates of temperature rise, the heat detector should operate within temperature limits having regard to the avoidance of detector insensitivity or over-sensitivity .

. 4 At the discretion of the Administration, the permissible temperature of operation of heat detectors may be increased to 30°C above the maximum deckhead temperature in drying rooms

and similar spaces of a normal high ambient temperature .
. 5 Flame detectors referred to in 7.7.2.1.11 should have a sensitivity sufficient to determine flame against an illuminated space background and a false signal identification system.
A fixed fire detection and fire alarm system for periodically unattended machinery spaces should comply with the following

---CHUNK---

SOURCE: MSC.36(63).pdf
illuminated space background and a false signal identification system.
A fixed fire detection and fire alarm system for periodically unattended machinery spaces should comply with the following
requirements:
.1 The fire detection system should be so designed and the detectors so positioned as to detect rapidly the onset of fire in any part of those spaces and under any normal conditions of operation of the machinery and variations of ventilation as required by the possible range of ambient temperatures. Except in spaces of restricted height and where their use is specially appropriate, detection system using only thermal detectors should not be permitted. The detection system should initiate audible and visual alarms distinct in both respects from the alarms of any other system not indicating fire, in sufficient places to ensure that the alarms are heard and observed on the navigating bridge and by a responsible engineer officer. When the operating compartment is unmanned the alarm should sound in a place where a responsible member of the crew is on duty
. 2 After installation, the system should be tested under varying

---CHUNK---

SOURCE: MSC.36(63).pdf
engineer officer. When the operating compartment is unmanned the alarm should sound in a place where a responsible member of the crew is on duty
. 2 After installation, the system should be tested under varying conditions of engine operation and ventilation.
WI1576n/pp/EWP
RESOLUTION MSC.36(63)
(adopted on 20 May 1994)
ADOPTION OF THE INTERNATIONAL CODE OF SAFETY FOR HIGH SPEED CRAFT MSC 63/23/Add.2
ANNEX 18
Page 70
7.7.4
7. 7.5
7.7.6.1
Areas of major fire hazard should be protected by an approved fixed extinguishing system operable from the control position which is adequate for the fire hazard that may exist. The system should be

capable of local manual control and remote control from the continuously manned control stations.
In all craft where gas is used as the extinguishing medium, the quantity of gas should be sufficient to provide two independent discharges. The second discharge into the space should only be activated (released) manually from a position outside the space being protected~ Where the space has a second fixed means of extinguishing ins,talled, then the second discharge should not be required.

---CHUNK---

SOURCE: MSC.36(63).pdf
activated (released) manually from a position outside the space being protected~ Where the space has a second fixed means of extinguishing ins,talled, then the second discharge should not be required.
The fixed fire-extinguishing systems should comply with the following requirements:
.1 The use of a fire-extinguishing medium which, in the opinion of the Administration, either by itself or under expected conditions of use will adversely affect the earth's ozone layer and/or gives off toxic gases in such quantities as to