bilge pump as determined by 10.3.5 and 10.3.6 but not less than 25 m3 /h. Each fire pump should be able to deliver sufficient quantity and pressure of water to simultaneously operate the hydrants as required by .4

. 2 The arrangement of the pumps should be such that in the event of a fire in anyone compartment all the fire pumps will not be put out of action .

. 3 Isolating valves to separate the section of the fire main within the machinery space containing the main fire pump or pumps from the rest of the fire main should be fitted in an easily accessible and tenable position outside the machinery spaces. The fire main should be so arranged that when the isolating valves are shut all the hydrants on the craft,

except those in the machinery space referred to above, can be supplied with water by a fire pump not located in this

---CHUNK---

SOURCE: MSC.36(63).pdf

(adopted on 20 May 1994)
ADOPTION OF THE INTERNATIONAL CODE OF SAFETY
FOR HIGH SPEED CRAFT MSC 63/23/Add.2
ANNEX 18
Page 73

except those in the machinery space referred to above, can be supplied with water by a fire pump not located in this machinery space through pipes which do not enter this space .

. 4 Hydrants should be arranged so that any location on the craft can be reached by the water jets from two fire hoses from two different hydrants, one of the jets being from a single length of hose. Special category spaces hydrants should be located so that any location within the space can be reached by two water jets from two different hydrants, each jet being supplied from a single length of hose .

. 5 Each fire hose should be of non-perishable material and have a maximum length approved by the Administration. Fire hoses, together with any necessary fittings and tools, should be kept ready for use in conspicuous positions near the hydrants. All fire hoses in interior locations should be connected to the hydrants at all times. One fire hose should be provided for each hydrant as required by .4 .

---CHUNK---

SOURCE: MSC.36(63).pdf

ready for use in conspicuous positions near the hydrants. All fire hoses in interior locations should be connected to the

hydrants at all times. One fire hose should be provided for each hydrant as required by .4 .
. 6 Each fire hose should be provided with a nozzle of an approved dual purpose type (i.e. spray/jet type) incorporating a shutoff.
7.8 Protection of s~ecial category spaces
7.8.1 Structural protection
7.8.2
.1 Boundaries of special category spaces should be insulated in accordance with tables 7.4-1 and 7.4-2. The standing deck of a special category space need only be insulated on the underside if required .
. 2 Indicators should be provided on the navigating bridge which should indicate when any door leading to or from the special category space is closed.
Fixed fire-extinguishing system*
Each special category space should be fitted with an approved fixed pressure water-spraying system for manual operation which should protect all parts of any deck and vehicle platform in such space, provided that the Administration may permit the use of any other fixed fire-extinguishing system that has been shown by full-scale

---CHUNK---

SOURCE: MSC.36(63).pdf
protect all parts of any deck and vehicle platform in such space, provided that the Administration may permit the use of any other fixed fire-extinguishing system that has been shown by full-scale test in conditions simulating a flowing petrol fire in a special category space to be not less effective in controlling fires likely to occur in such a space.
Refer to the Recommendation on fixed fire-extinguishing systems for special category spaces, adopted by the Organization by resolution A.123(V).
W/1576n/pp/EWP
RESOLUTION MSC.36(63)
(adopted on 20 May 1994)
ADOPTION OF THE INTERNATIONAL CODE OF SAFETY FOR HIGH SPEED CRAFT MSC 63/23/Add.2
ANNEX 18
Page 74
7.8.3
7.8.3.1
7.8.3.2
7.8.4
7.8.4.1
7.8.5
7.8.5.1
7.8.5.2
7.8.5.3
7.8.5.4
Patrols and detection
A continuous fire patrol should be maintained in special category spaces unless a fixed fire detection and fire alarm system,

complying with the requirements of 7.7.2, and a television surveillance system are provided. The fixed fire detection system should be capable of rapidly detecting the onset of fire. The spacing and location of detectors should be tested taking into

---CHUNK---

SOURCE: MSC.36(63).pdf
surveillance system are provided. The fixed fire detection system should be capable of rapidly detecting the onset of fire. The spacing and location of detectors should be tested taking into account the effects of ventilation and other relevant factors.
Manually operated call points should be provided as necessary throughout the special category spaces and one should be placed close to each exit from such spaces.
Fire-extinguishing equipment
There should be provided in each special category space:
.1 at least three water fog applicators;
.2 one portable foam applicator unit consisting of an air-foam nozzle of an inductor type capable of being connected to the fire main by a fire hose, together with a portable tank containing 20 l of foam-making liquid and one spare tank. The nozzle should be capable of producing effective foam suitable for extinguishing an oil fire of at least 1.5 m3 /min. At least two portable foam applicator units should be available in the craft for use in such space; and
.3 portable fire extinguishers should be located so that no point in the space is more than approximately 15 m walking distance

---CHUNK---

SOURCE: MSC.36(63).pdf
least two portable foam applicator units should be available in the craft for use in such space; and
.3 portable fire extinguishers should be located so that no point in the space is more than approximately 15 m walking distance from an extinguisher, provided that at least one portable extinguisher is located at each access to such space.
Ventilation system
There should be provided an effective power ventilation system for the special category spaces sufficient to give at least 10 air changes per hour while navigating and 20 air changes per hour at the quayside during vehicle loading and unloading operations.
The system for such spaces should be entirely separated from other ventilation systems and should be operating at all times when vehicles are in such spaces. Ventilation ducts serving special category spaces capable of being effectively sealed should be separated for each such space. The system should be capable of being controlled from a position outside such spaces.
The ventilation should be such as to prevent air stratification and the formation of air pockets.
Means should be provided to indicate in the operating compartment

---CHUNK---

SOURCE: MSC.36(63).pdf
being controlled from a position outside such spaces.
The ventilation should be such as to prevent air stratification and the formation of air pockets.
Means should be provided to indicate in the operating compartment any loss or reduction of the required ventilating capacity.
Arrangements should be provided to permit a rapid shutdown and effective closure of the ventilation system in case of fire, taking into account the weather and sea conditions.
W/1576n/pp/EWP
RESOLUTION MSC.36(63)
(adopted on 20 May 1994)
ADOPTION OF THE INTERNATIONAL CODE OF SAFETY
FOR HIGH SPEED CRAFT 7.8.5.5
7.8.6
7.8.6.1
7.8.7
7.8.7.1
7.8.7.2
MSC 63/23/Add.2
ANNEX 18
Page 75