extremely remote.
Where loss of particular essential service would cause serious risk to the craft, the service should be fed by at least two independent circuits fed in such a way that no single failure in the electrical supply or distribution systems would effect both supplies.
The securing arrangements for heavy items, i.e. accumulator batteries, should, as far as practicable, prevent excessive movemen' during the accelerations due to grounding or collision.
Precautions should be taken to minimize risk of supplies to essential and emergency services being interrupted by the inadvertent or accidental opening of switches or circuit breakers.
Main so u rce o f electrical p~
A main source of electrical power of sufficient capacity to supply

---CHUNK---

SOURCE: MSC.36(63).pdf
essential and emergency services being interrupted by the inadvertent or accidental opening of switches or circuit breakers.
Main so u rce o f electrical p~
A main source of electrical power of sufficient capacity to supply all those services mentioned in 12.1.1 should be provided. The main source of electrical power should consist of at least two generating sets.
Refer to the recommendations published by the International Electrotechnical Commission and, in particu,lar, Publication 92 - Electrical installations in ships.
WIl687n/pp/EWP
RESOLUTION MSC.36(63)
(adopted on 20 May 1994)
ADOPTION OF THE INTERNATIONAL CODE OF SAFETY FOR HIGH SPEED CRAFT 12.2.2
12.2.3
12.2.4
12.2.5
12.2.6
12.2.7
12.2.8
12.2.9
MSC 62123/Add.2
ANNEX 18
Page J.11
The capacity of these generating sets should be such that in the event of anyone generating set being stopped or failing it will still be possible to supply those services necessary to provide the normal operational conditions of propulsion and safety. Minimum comfortable conditions of habitability should also be ensured which include at least adequate services for cooking, heating, domestic

---CHUNK---

SOURCE: MSC.36(63).pdf
normal operational conditions of propulsion and safety. Minimum comfortable conditions of habitability should also be ensured which

include at least adequate services for cooking, heating, domestic refrigeration, mechanical ventilation, sanitary and fresh water.
The arrangements of the craft's main source of electrical power should be such that the services referred to in 12.1.1.1 can be maintained regardless of the speed and direction of the propulsion machinery or shafting.
In addition, the generating sets should be such as to ensure that with anyone generator or its primary source of power out of operation, the remaining generating set should be capable of providing the electrical services necessary to start the main propulsion plant from dead craft condition. The emergency source of electrical power may be used for the purpose of starting from a dead craft condition if its capability either alone or combined with that of any other source of electrical power is sufficient to provide at the same time those services required to be provided by 12.7.3.1 to 12.7.3.3 or 12.7.4.1 to 12.7.4.4 or 12.8.2.1 to 12.8.2.4.1, as appropriate.

---CHUNK---

SOURCE: MSC.36(63).pdf
of any other source of electrical power is sufficient to provide at the same time those services required to be provided by 12.7.3.1 to 12.7.3.3 or 12.7.4.1 to 12.7.4.4 or 12.8.2.1 to 12.8.2.4.1, as appropriate.
Where transformers constitute an essential part of the electrical supply system required by this section, the system shou~d be so arranged as to ensure the same continuity of supply as is stated in 12.2.
A main electric lighting system which should provide illumination throughout those parts of the craft normally accessible to and used by passengers and crew should be supplied from the main source of electrical power.
The arrangement of the main electric lighting system should be such that a fire or other casualty in spaces containing the emergency source of electrical power, associated transforming equipment, if any, the emergency switchboard and the emergency lighting switchboard will not render inoperative the main electric lighting system required by 12.2.6.
The main switchboard should be so placed relative to one main generating station that, as far as practicable, the integrity of the

---CHUNK---

SOURCE: MSC.36(63).pdf
switchboard will not render inoperative the main electric lighting system required by 12.2.6.
The main switchboard should be so placed relative to one main generating station that, as far as practicable, the integrity of the normal electrical supply may be affected only by a fire or other casualty in one space. An environmental enclosure for the main switchboard, such as may be provided by a machinery control room situated within the main boundaries of the space, should not be considered as separating the switchboards from the generators.

The main busbars should normally be subdivided into at least two parts which should be connected by a circuit-breaker or other approved means. So far as is practicable, the connection of generating sets and any other duplicated equipment should be equally divided between the parts. Equivalent arrangements may be permitted to the satisfaction of the Administration.
W/1687n/pp/EWP
RESOLUTION MSC.36(63)
(adopted on 20 May 1994)
ADOPTION OF THE INTERNATIONAL CODE OF SAFETY
FOR HIGH SPEED CRAFT MSC 62/23/Add.2
ANNEX 18
Page 112
12.3
12.3.1
12.3.2
12.3.3
12.3.4
12.3.5
12.3.6
Emergency source~ electrical powtl

---CHUNK---

SOURCE: MSC.36(63).pdf
RESOLUTION MSC.36(63)
(adopted on 20 May 1994)
ADOPTION OF THE INTERNATIONAL CODE OF SAFETY
FOR HIGH SPEED CRAFT MSC 62/23/Add.2
ANNEX 18
Page 112
12.3
12.3.1
12.3.2
12.3.3
12.3.4
12.3.5
12.3.6
Emergency source~ electrical powtl
A self-contained emergency source of electrical power should be provided.
The emergency source of electrical power, associated transforming equipment, if any, transitional source of electrical power, emergency switchboard and emergency lighting switchboard should be located above the waterline in the final condition of damage as referred to in chapter 2, operable in that condition and readily accessible.
The location of the emergency source of electrical power and associated transforming equipment, if any, the transitional source of emergency power, the emergency switchboard and the emergency electrical lighting switchboards in relation to the main source of electrical power, associated transforming equipment, if any, and the main switchboard should be such as to ensure that a fire or other casualty in spaces containing the main source of electrical power,

associated transforming equipment, if any, and the main switchboard

---CHUNK---

SOURCE: MSC.36(63).pdf
main switchboard should be such as to ensure that a fire or other casualty in spaces containing the main source of electrical power, associated transforming equipment, if any, and the main switchboard or in any machinery space will not interfere with the supply, control and distribution of emergency electrical power. As far as practicable, the space containing the emergency source of electrical power, associated transforming equipment, if any, the transitional source of emergency electrical power and the emergency switchboard should not be contiguous to the boundaries of main machinery spaces or those spaces containing the main source of electrica~ power, associated transforming equipment, if any, or the main swi~chboard. Provided that suitable measures are taken for safeguarding independent emergency operation under all circumstances, the emergency generator, if provided, may be used exceptionally, and for short periods, to supply non-emergency circuits.
Distribution systems should be so arranged that the feeders from the main and emergency sources are separated both vertically and horizontally as widely as practicable.