Transitional source of emergency electrical power
The transitional source of emergency electrical power required by paragraph 12.3.6.1.3 may consist of an accumulator battery suitably located for use in an emergency which should operate without recharging while maintaining the voltage of the battery throughout

---CHUNK---

SOURCE: MSC.36(63).pdf
paragraph 12.3.6.1.3 may consist of an accumulator battery suitably located for use in an emergency which should operate without recharging while maintaining the voltage of the battery throughout the discharge period within 12% above or below its nominal voltage and be of sufficient capacity and so arranged as to supply automatically in the event of failure of either the main or emergency source of electrical power at least the following services, if they depend upon an electrical source for their operation:
.1 for a period of 30 min, the load specified in 12.7.3.1, .2 and .3, or in 12.7.4.1, .2 and .3; and
.2 with respect to the watertight doors:
.2.1 power to operate the watertight doors, but not necessarily simultaneously, unless an independent temporary source of stored energy is provided. The power source should have sufficient capacity to operate each door at least three times, i.e. closed - open
.2.2
- closed, against an adverse list of 15°; and
power to the control, indication and alarm circuits for the watertight doors for half an hour.
The requirements of 12.7.5 may be considered satisfied without the

---CHUNK---

SOURCE: MSC.36(63).pdf
.2.2
- closed, against an adverse list of 15°; and
power to the control, indication and alarm circuits for the watertight doors for half an hour.
The requirements of 12.7.5 may be considered satisfied without the installation of a transitional source of emergency electrical power if each of the services required by that paragraph has independent supplies, for the period specified, from accumulator batteries suitably located for use in an emergency. The supply of emergency power to the instruments and controls of the propulsion and direction systems should be uninterruptib1e.
In category A craft having limited public spaces, emergency lighting fittings of the type described in 12.7.9.1 as meeting the requirements of 12.7.3.1 and 12.7.5.1 may be accepted, provided that an adequate standard of safety is attained.
W/1687n/pp/EWP
RESOLUTION MSC.36(63)
(adopted on 20 May 1994)
ADOPTION OF THE INTERNATIONAL CODE OF SAFETY

FOR HIGH SPEED CRAFT 12.7.8
12.7.9
12.7.10
12.8
12.8.1
MSC 62/23/Add.2
ANNEX 18
Page 123
Provision should be made for the periodic testing of the complete emergency system including the emergency consumers required by

---CHUNK---

SOURCE: MSC.36(63).pdf
FOR HIGH SPEED CRAFT 12.7.8
12.7.9
12.7.10
12.8
12.8.1
MSC 62/23/Add.2
ANNEX 18
Page 123
Provision should be made for the periodic testing of the complete emergency system including the emergency consumers required by 12.7.3 or 12.7.4 and 12.7.5, and should include the testing of automatic starting arrangements.
In addition to the emergency lighting required by 12.7.3.1, 12.7.4.1 and 12.7.5.1 on every craft with special category spaces:
.1 all passenger public spaces and alleyways should be provided with supplementary electric lighting that can operate for at least 3 h when all other sources of electric power have failed and under any condition of heel. The illumination provided should be such that the approach to the means of escape can be readily seen. The source of power for the supplementary lighting should consist of accumulator batteries located within the lighting units that are continuously charged, where practicable, from the emergency switchboard. Alternatively, any other means of lighting, which is at least as effective, may be accepted by the Administration. The supplementary lighting should be such that any failure of

---CHUNK---

SOURCE: MSC.36(63).pdf
charged, where practicable, from the emergency switchboard. Alternatively, any other means of lighting, which is at least as effective, may be accepted by the Administration.
The supplementary lighting should be such that any failure of the lamp will be immediately apparent. Any accumulator battery provided should be replaced at intervals having regard to the specified service life in the ambient condition that it is subject to in service; and
.2 a portable rechargeable battery operated lamp should be provided in every crew space alleyway, recreational space

and every working space which is normally occupied unless supplementary emergency lighting, as required by .1, is provided.
Distribution systems should be so arranged that fire in any main vertical zone will not interfere with services essential for safety in any other such zone. This requirement will be met if main and emergency feeders passing through any such zone are separated both vertically and horizontally as widely as is practicable.
PART C - REQUIREMENTS FOR CARGO CRAFT
General
Separation and duplication of electrical supply should be provided

---CHUNK---

SOURCE: MSC.36(63).pdf
emergency feeders passing through any such zone are separated both vertically and horizontally as widely as is practicable.
PART C - REQUIREMENTS FOR CARGO CRAFT
General
Separation and duplication of electrical supply should be provided for duplicated consumers of essential services. During normal operation these consumers may be connected to the same power-bus directly or via distribution boards or group starters, but should be separated by removeable links or other approved means. Each power-bus should be able to supply all equipment necessary to maintain the control of propulsion, steering, stabilization, navigation, lighting and ventilation, and allow starting of the largest essential electric motor at any load. However, having regard to 12.1.2, partial reduction in the capability from normal operation may be accepted. Non-duplicated consumers of essential services connected to the emergency switchboard directly or via distribution boards may be accepted. Automatic load-dependent disconnection of non-essential consumers may be allowed.
W/1687n/pp/EWP
RESOLUTION MSC.36(63)
(adopted on 20 May 1994)
ADOPTION OF THE INTERNATIONAL CODE OF SAFETY

---CHUNK---

SOURCE: MSC.36(63).pdf
distribution boards may be accepted. Automatic load-dependent disconnection of non-essential consumers may be allowed.
W/1687n/pp/EWP
RESOLUTION MSC.36(63)
(adopted on 20 May 1994)
ADOPTION OF THE INTERNATIONAL CODE OF SAFETY
FOR HIGH SPEED CRAFT MSC 62/23/Add.2
ANNEX 18
Page 124
12.8.2 Emergency source of electrical power
12.8.2.1 Where the main source of electrical power is located in two or more compartments which are not contiguous, each of which has its own self-contained systems, including power distributlon and control

systems, completely independent of each other and such that a fire or other casualty in anyone of the spaces will not affect the power distribution from the others, or to the services required by 12.8.2.2, the requirements of 12.3.1, 12.3.2 and 12.3.4 may be considered satisfied without an additional emergency source of electrical power, provided that:

.1 there is at least one generating set, meeting the requirements of 12.3.12 and each of sufficient capacity to meet the requirements of 12.8.2.2, in each of at least two non-contiguous spaces;

.2 the arrangements required by .1 in each such space are

---CHUNK---

SOURCE: MSC.36(63).pdf

of 12.3.12 and each of sufficient capacity to meet the requirements of 12.8.2.2, in each of at least two non-contiguous spaces;

.2 the arrangements required by .1 in each such space are equivalent to those required by 12.3.6.1, 12.3.7 to 12.3.11 and 12.4 so that a source of electrical power is available at all times to the services required by 12.8.2; and

.3 the generator sets referred to in .1 and their self-contained