ments where smoking is
not allowed, adequate notices should be displayed.
* Refer to the Recommendation on fire test procedures for upholstered
furniture, adopted by the Organization by resolution A.652(16).
** Refer to the Recommendation on fire test procedures for ignitability of
---CHUNK---
SOURCE: MSC.36(63).pdf
* Refer to the Recommendation on fire test procedures for upholstered
furniture, adopted by the Organization by resolution A.652(16).
** Refer to the Recommendation on fire test procedures for ignitability of
bedding components, adopted by the Organization by resolution A.688(17).
*** Refer to the Recommendation on improved fire test procedures for surface
flammability of bulkhead, ceiling and deck finish materials, adopted by
the Organization by resolution A.653(16) and the Recommendation on fire
test procedures for ignitability of primary deck coverings, adopted by
the Organization by resolution A.687(16).
W/1576n/pp/EWP
RESOLUTION MSC.36(63)
(adopted on 20 May 1994)
ADOPTION OF THE INTERNATIONAL CODE OF SAFETY
FOR HIGH SPEED CRAFT MSC 63/23/Add.2
ANNEX 18
Page 62
7.4.3.9 The exhaust gas pipes should be arranged so that the risk of fire
is kept to a minimum. To this effect, the exhaust system should be
insulated and all the compartments and structures which are
contiguous with the exhaust system, or those which may be affected
by increased temperatures caused by waste gases in normal operation
or in an emergency, should be constructed of non-combustible
---CHUNK---
SOURCE: MSC.36(63).pdf
contiguous with the exhaust system, or those which may be affected
by increased temperatures caused by waste gases in normal operation
or in an emergency, should be constructed of non-combustible
material or be shielded and insulated with non-combustible material
to protect from high temperatures.
7.4.3.10 The design and arrangement of the exhaust manifolds or pipes should
be such as to ensure the safe discharge of exhaust gases.
7.4.4 Arrangement
7.4.4.1 Internal stairways which serve more than two decks of accommodation
should be enclosed at all levels with smoke-tight divisions of
non-combustible or fire-restricting materials, and where only two
decks are served, such enclosures should be provided on at least one
level. Stairways may be fitted in the open in a public space,
provided they lie wholly within such public space.
7.4.4.2 Lift trunks should be so fitted as to prevent the passage of smoke
and flame from one deck to another and should be provided with means
of closing so as to permit the control of draught and smoke.
7.4.4.3 In accommodation and service spaces, control stations, corridors and
---CHUNK---
SOURCE: MSC.36(63).pdf
and flame from one deck to another and should be provided with means
of closing so as to permit the control of draught and smoke.
7.4.4.3 In accommodation and service spaces, control stations, corridors and
stairways air spaces enclosed behind ceilings, panelling or linings
should be suitably divided by close fitting draught stops not more
than 14 m apart.
7.5 Fuel and other flammable fluid tanks and systems
7.5.1 Tanks containing fuel and other flammable fluids should be separated
from passenger, crew, and baggage compartments by vapour-proof
enclosures or cofferdams which are suitably ventilated and drained.
7.5.2 Fuel oil tanks should not be located in or contiguous to major fire
hazard areas. However, flammable fluids of a flashpoint not less
than 60°C may be located within such areas provided the tanks are
made of steel or other equivalent material.
7.5.3 Every oil fuel pipe which, if damaged, would allow oil to escape
from a storage, settling or daily service tank should be fitted
with a cock or valve directly on the tank capable of being closed
from a position outside the space concerned in the event of a fire
---CHUNK---
SOURCE: MSC.36(63).pdf
from a storage, settling or daily service tank should be fitted
with a cock or