tion on improved fire test procedures for surface
flammability of bulkhead, ceiling and deck finish materials, adopted by
the Organization by resolution A.653(16) and the Recommendation on fire
test procedures for ignitability of primary deck coverings, adopted by
the Organization by resolution A.687(16).
W/1576n/pp/EWP
RESOLUTION MSC.36(63)
(adopted on 20 May 1994)
ADOPTION OF THE INTERNATIONAL CODE OF SAFETY
FOR HIGH SPEED CRAFT MSC 63/23/Add.2
ANNEX 18
Page 62
7.4.3.9 The exhaust gas pipes should be arranged so that the risk of fire
is kept to a minimum. To this effect, the exhaust system should be
insulated and all the compartments and structures which are
contiguous with the exhaust system, or those which may be affected
by increased temperatures caused by waste gases in normal operation
or in an emergency, should be constructed of non-combustible
-
contiguous with the exhaust system, or those which may be affected
by increased temperatures caused by waste gases in normal operation
or in an emergency, should be constructed of non-combustible
material or be shielded and insulated with non-combustible material
to protect from high temperatures.
7.4.3.10 The design and arrangement of the exhaust manifolds or pipes should
be such as to ensure the safe discharge of exhaust gases.
7.4.4 Arrangement
7.4.4.1 Internal stairways which serve more than two decks of accommodation
should be enclosed at all levels with smoke-tight divisions of
non-combustible or fire-restricting materials, and where only two
decks are served, such enclosures should be provided on at least one
level. Stairways may be fitted in the open in a public space,
provided they lie wholly within such public space.
7.4.4.2 Lift trunks should be so fitted as to prevent the passage of smoke
and flame from one deck to another and should be provided with means
of closing so as to permit the control of draught and smoke.
7.4.4.3 In accommodation and service spaces, control stations, corridors and
-
and flame from one deck to another and should be provided with means
of closing so as to permit the control of draught and smoke.
7.4.4.3 In accommodation and service spaces, control stations, corridors and
stairways air spaces enclosed behind ceilings, panelling or linings
should be suitably divided by close fitting draught stops not more
than 14 m apart.

7.5 Fuel and other flammable fluid tanks and systems
7.5.1 Tanks containing fuel and other flammable fluids should be separated from passenger, crew, and baggage compartments by vapour-proof enclosures or cofferdams which are suitably ventilated and drained.
7.5.2 Fuel oil tanks should not be located in or contiguous to major fire hazard areas. However, flammable fluids of a flashpoint not less than 60°C may be located within such areas provided the tanks are made of steel or other equivalent material.
7.5.3 Every oil fuel pipe which, if damaged, would allow oil to escape from a storage, settling or daily service tank should be fitted with a cock or valve directly on the tank capable of being closed from a position outside the space concerned in the event of a fire
-
from a storage, settling or daily service tank should be fitted with a cock or valve directly on the tank capable of being closed from a position outside the space concerned in the event of a fire occurring in the space in which such tanks are situated.
7.5.4 Pipes, valves and couplings conveying flammable fluids should be of steel or such alternative material satisfactory to a standard*, in respect of strength and fire integrity having regard to the
* Refer to Guidelines for materials other than steel for pipes adopted by the Organization by resolution A.753(18).

service pressure and the spaces in which they are installed.
Wherever practicable, the use of flexible pipes should be avoided.
Pipes, valves and couplings conveying flammable fluids should be arranged as far from hot surfaces or air intakes of engine installations, electrical appliances and other potential sources of ignition as is practicable and be located or shielded so that the
-
arranged as far from hot surfaces or air intakes of engine installations, electrical appliances and other potential sources of ignition as is practicable and be located or shielded so that the likelihood of fluid leakage coming into contact with such sources of ignition is kept to a minimum.
Fuel with a flashpoint belo