C.555(108)

(adopted on 23 May 2024)

(FSS CODE)

THE MARITIME SAFETY COMMITTEE,

RECALLING Article 28(b) of the Convention on the International Maritime Organization concerning the functions of the Committee,

RECALLING ALSO resolution MSC.98(73), by which it adopted the International Code for Fire Safety Systems ("the FSS Code"), which has become mandatory under chapter II -2 of the International Convention for the Safety of Life at Sea, 1974 ("the Convention"),

RECALLING FURTHER article VIII(b) and regulation II -2/3.22 of the Convention concerning the procedure for amending the FSS Code,

HAVING CONSIDERED, at its 108th session,

circulated in accordance with article VIII(b)(i) of the Convention,

---

URL:
https://wwwcdn.imo.org/localresources/en/KnowledgeCentre/IndexofIMOResolutions/MSCResolutions/MSC.555(108).pdf

circulated in accordance with article VIII(b)(i) of the Convention,

1 ADOPTS, in accordance with article VIII(b)(iv) of the Convention,

FSS Code, the text of which is set out in the annex to the present resolution;

2 DETERMINES, in accordance with article VIII(b)(vi)(2)(bb) of the Convention, that the amendments shall be deemed to have been accepted on 1 July 2025 unless, prior to that date, more than one third of the Contracting Governments to the Convention, or Cont racting Governments the combined merchant fleets of which constitute not less than 50% of the gross tonnage of the world's merchant fleet have notified the Secretary -General of their objections

to the amendments;

3 INVITES Contracting Governments to note that, in accordance with article VIII(b)(vii)(2) of the Convention, the amendments shall enter into force on 1 January 2026

upon their acceptance in accordance with paragraph 2 above;

URL:
https://wwwcdn.imo.org/localresources/en/KnowledgeCentre/IndexofIMOResolutions/MSCResolutions/MSC.555(108).pdf

upon their acceptance in accordance with paragraph 2 above;

4 REQUESTS the Secretary -General, in conformity with article VIII(b)(v) of the Convention, to transmit certified copies of the present resolution and the text of the amendments contained in the annex to all Contracting Governments to the Convention;

5 ALSO REQUESTS the Secretary-General to transmit copies of this resolution and its annex to Members of the Organization which are not Contracting Governments to the Convention.

RESOLUTION MSC.555(108) (adopted on 23 May 2024)

- 2 -

ANNEX

(FSS CODE)

CHAPTER 7

Fixed pressure water-spraying and
water mist fire-extinguishing systems
2 Engineering specifications
1 The following new section 2.5 is added after existing section 2.4 (Fixed water-based fire-fighting systems for ro-ro spaces, vehicle spaces and special category spaces):

URL:
https://wwwcdn.imo.org/localresources/en/KnowledgeCentre/IndexofIMOResolutions/MSCResolutions/MSC.555(108).pdf
fire-fighting systems for ro-ro spaces, vehicle spaces and special category spaces):
"2.5 Fixed water-based fire-extinguishing system on ro-ro passenger ships'
weather decks intended for the carriage of vehicles
This paragraph details the specification of fixed water-based fire-extinguishing system on ro-ro passenger ships having weather decks intended for the carriage of vehicles as required by chapter II -2 of the Convention. The requirements of this paragraph shall apply to ro-ro passenger ships constructed on or after 1 January 2026.
2.5.1 The protected area shall be the entire length and width of the weather deck intended for the carriage of vehicles. The fixed monitor(s) shall be capable of delivering water to:
.1 the area of weather decks intended for carriage of vehicles; and
.2 the area, including superstructure boundaries located up to 8.0 m, measured horizontally, from the area intended for vehicle storage, or the next vertical boundaries, whichever is less.

URL:
https://wwwcdn.imo.org/localresources/en/KnowledgeCentre/IndexofIMOResolutions/MSCResolutions/MSC.555(108).pdf
measured horizontally, from the area intended for vehicle storage,
or the next vertical boundaries, whichever is less.
2.5.2 The combined capacity of all fixed monitors shall be minimum 2.0 L/min per square metre of the protected area, but in no case shall the output of any monitor be less than 1,250 L/min. Even distribution of water shall be ensured.
2.5.3 The distance from the monitor to the farthest extremity of the protected area forward of that monitor