


Portable Appliance Testing Report



Presented to

Tested by

House Management Group

Camelog...

Portable Appliance Testing

Commencement Date


05/01/2022


Bespoke Electrical Services

Appliances tested for electrical safety in accordance with
the IET code of practice for in service and inspection and
testing of electrical equipment



Portable Appliance Test (PAT) Completion Certificate



DETAILS OF THE CLIENT		ADDRESS OF TESTING	
Client and address	House Management Group Treravel House Padstow	Camelog Rosehill Little Petherick	Postcode:
	PL28 8LB		Postcode:
*ANY LIMITATIONS AGREED ON TESTING		The Premises Are:	
<small>*If any, reasons and with whom agreed</small> N/A		<input checked="" type="checkbox"/> Domestic <input checked="" type="checkbox"/> Commercial <input type="checkbox"/> Industrial	
DECLARATION		ENGINEER, NAME & SIGNATURE	
<p>This is to certify the electrical appliances details in this certificate and record sheets have been tested for electrical safety in accordance with the IET code of practice for in service and inspection and testing of electrical equipment. It does not guarantee the correct operation of the appliance for any length of time. Users of the appliance should be aware of any fault or defect that may occur with future use. Any doubt regarding the safety or correct operation of the appliance, the device should be removed from service for further inspection by a competent person.</p>		Signature  Name CALLUM CARTER Date 05/01/2022 	
TESTING CARRIED OUT BY		PAT TESTER SERIAL NUMBER	
Trading Title	Bespoke Electrical Services	N/A	
	Shieldaig Clann Lane Lanivet	Email	
		Web	
Telephone No	07702079450	Postcode	PL30 5HD
Registration No: (if applicable)		Branch No: (if applicable)	
NOTES			
N/A			

ANY FAILED APPLIANCES SHOULD BE REMOVED FROM SERVICE UNTIL THE DEFECT HAS BEEN RECTIFIED

APPLIANCE SUMMARY FOR House Mangement Group Camelog Rosehill Little Petherick

Total Appliances

38

Appliances Passed

36

Appliances Failed

2

PORTABLE APPLIANCE REGISTER

Appliance number	Appliance	Class	Polarity	Location	Serial number/ID	Test Results				Visual check	Fuse rating (A)	Formal Visual Inspection (months)	Combined Inspection & Test (months)	Result	Repair Code
						Earth continuity test(Ω)	Insulation Resistance M(Ω)	Load test (kVA)	Earth Leakage Test (mA)						
1	Toaster	1	Yes	Kitchen	001	N/A	N/A	N/A	N/A	✓	13	3	12	Pass	

2	Whirlpool Maximo	2	Yes	Kitchen	002	N/A	N/A	N/A	N/A	✓	13	3	12	Pass	
3	Kettle	1	Yes	Kitchen	003	N/A	N/A	N/A	N/A	✓	13	3	12	Pass	
4	Coffee Machine	1	Yes	Kitchen	004	N/A	N/A	N/A	N/A	✓	13	3	12	Pass	
5	Phone	2	N/A	Kitchen	005	N/A	N/A	N/A	N/A	✓	N/A	3	12	Pass	
6	Extension Lead	IEC	Yes	Kitchen	006	N/A	N/A	N/A	N/A	✓	13	3	12	Pass	
7	Iron	1	Yes	Lounge	007	N/A	N/A	N/A	N/A	✓	13	3	12	Pass	
8	Hair Dryer	2	N/A	Lounge	008	N/A	N/A	N/A	N/A	✓	13	3	12	Pass	
9	Lamp	2	Yes	Lounge	008	N/A	N/A	N/A	N/A	✓	13	3	12	Pass	
10	Dust Buster	2	Yes	Lounge	9	N/A	N/A	N/A	N/A	X	N/A	3	12	Fail	
11	Pioneer Stereo	2	N/A	Lounge	10	N/A	N/A	N/A	N/A	✓	5	3	12	Pass	
12	Touch	2	Yes	Lounge	011	N/A	N/A	N/A	N/A	✓	N/A	3	12	Pass	
13	Extension Lead	IEC	N/A	Lounge	012	N/A	N/A	N/A	N/A	✓	13	3	12	Pass	
14	Plug In Emergency Light	2	N/A	Lounge	0013	N/A	N/A	N/A	N/A	X	13	3	12	Fail	
15	Tv	2	N/A	Lounge	015	N/A	N/A	N/A	N/A	✓	10	3	12	Pass	
16	Sky Box	2	N/A	Lounge	016	N/A	N/A	N/A	N/A	✓	10	3	12	Pass	

Repair Codes:

A = Replace plug

D = Fit rubber plug

G = Replace lead

B = Rewire plug

E = Fit inline switch

H = Other

C = Fit BS1361 sleeved plug

F = Replace IEC lead

Page 3 of certificate ref:

12963977

Completed using iCertifi electrical certificates on iOS

Appliance number	Appliance	Class	Polarity	Location	Serial number/ID	Test Results				Visual check	Fuse rating (A)	Formal Visual Inspection & Test (months)	Combined Inspection & Test (months)	Result	Repair Code
						Earth continuity test(Ω)	Insulation Resistance M(Ω)	Load test (kVA)	Earth Leakage Test (mA)						
17	DVD Player	2	Yes	Lounge	017	N/A	N/A	N/A	N/A	✓	3	3	10	Pass	
18	Router	2	Yes	Lounge	018	N/A	N/A	N/A	N/A	✓	N/A	3	12	Pass	
19	Extension Lead	IEC	N/A	Lounge	019	N/A	N/A	N/A	N/A	✓	13	2	12	Pass	
20	Bedside Lamp	2	N/A	Twin Room	020	N/A	N/A	N/A	N/A	✓	13	3	12	Pass	
21	Bedside Lamp	2	Yes	Twin Room	021	N/A	N/A	N/A	N/A	✓	13	3	12	Pass	
22	Extension Lead	IEC	Yes	Twin Room	022	N/A	N/A	N/A	N/A	✓	13	3	12	Pass	
23	Hoover	2	N/A	Twin Room Cupboard	023	N/A	N/A	N/A	N/A	✓	13	3	12	Pass	
24	Speaker	2	Yes	Twin Room Cupboard	024	N/A	N/A	N/A	N/A	✓	N/A	3	12	Pass	
25	Bt Router	2	N/A	Twin Room Cupboard	025	N/A	N/A	N/A	N/A	✓	N/A	3	12	Pass	
26	Extension Lead	IEC	Yes	Twin Room Cupboard	026	N/A	N/A	N/A	N/A	✓	13	3	12	Pass	
27	Open Reach ONT	2	N/A	Twin Room Cupboard	027	N/A	N/A	N/A	N/A	✓	N/A	3	12	Pass	
28	Heatmiser Hub	2	Yes	Twin Room Cupboard	028	N/A	N/A	N/A	N/A	✓	N/A	3	12	Pass	
29	Bedside Lamp	2	Yes	Twin Room	029	N/A	N/A	N/A	N/A	✓	5	3	12	Pass	
30	Bedside Lamp	2	Yes	Twin Room	030	N/A	N/A	N/A	N/A	✓	5	3	12	Pass	
31	Extension Lead	IEC	Yes	Twin Room	031	N/A	N/A	N/A	N/A	✓	13	3	12	Pass	
32	Printer	2	N/A	Twin Room	032	N/A	N/A	N/A	N/A	✓	10	3	12	Pass	

Repair Codes:

A = Replace plug

B = Rewire plug

E = Fit inline switch

G = Replace lead

C = Fit BS1361 sleeved plug

F = Replace IEC lead

H = Other

Repair Codes:

A = Replace plug

B = Rewire plug

C = Fit BS1361 sleeved plug

F = Fit inline switch

G = Replace lead

H = Other

G = Replace lead

H = Other

Report page 5 of certificate ref:

12963977

Completed using iCertifi electrical certificates on iOS