




**ROUND DUCT INSULATION DETAIL**  
NO SCALE




**ROUND DUCT INSTALLATION DETAIL**  
NO SCALE




**RECTANGULAR DUCT INSULATION DETAIL**  
NO SCALE



**RETURN AIR PLENUM DETAIL**  
NO SCALE #D-1-10A



**ROUND TAP DETAIL**  
NO SCALE #D-1-8



**ROUND DUCT MOUNTED REGISTER DETAIL**  
NO SCALE #D-1-9

## PLAN NOTES

- SEE DETAILS ON THIS SHEET & SHEET M-2 FOR ADDITIONAL INFORMATION.
- ALL TERMINATIONS TO CEILING MOUNTED DIFFUSERS TO BE MADE WITH A MAXIMUM OF 5' OF FLEXIBLE DUCTWORK. PROVIDE SPIN COLLAR AND/OR LOCKING TYPE DAMPER AT ALL FINAL BRANCH TAPS FOR ALL GRILLES AND DIFFUSERS. SEE DIVISION 23 (HVAC) NOTES.  
  
ALL TERMINATIONS TO EXPOSED CEILING GRILLES, REGISTERS AND DIFFUSERS TO BE MADE WITH HARD DUCT CONNECTIONS. PROVIDE SPIN COLLAR AND/OR LOCKING TYPE DAMPER AT ALL FINAL BRANCH TAPS. SEE DIVISION 23 (HVAC) NOTES.  
  
ALL LAY-IN DIFFUSERS MOUNTED IN GYPSUM CEILINGS TO HAVE PLASTER FRAMES.  
  
SEPARATE NEW BRANCH DUCT TAP LOCATIONS. MINIMUM CENTERLINE SEPARATION DISTANCE TO BE (2) EQUIVALENT DUCT MAIN DIAMETERS.
- TRANSITION FROM UNIT CONNECTION SIZE(S) TO PLAN SIZE AND TURN HORIZONTAL WITH SQUARE THROAT VANED ELBOW(S). TAPS NOT ACCEPTABLE. (SEE DUCTWORK SYMBOLS LEGEND)
- ALL ELBOWS TO BE RADIUS TYPE - UNLESS NOTED OTHERWISE (SQUARE THROAT ELBOWS ARE NOT ACCEPTABLE). (SEE DUCTWORK SYMBOLS LEGEND)
- INSTALL ALL NEW DUCTS, DIFFUSERS, GRILLES AND/OR REGISTERS BETWEEN WALL STUDS.
- VERIFY ACCESS TO ALL EQUIPMENT.
- INSTALL ALL DUCTWORK AS HIGH AS POSSIBLE BELOW ALL BUILDING STEEL. BOTTOM OF ALL HVAC EQUIPMENT AND DUCTWORK TO BE AT A MINIMUM OF 12'-3" A.F.F. EXCEPT IN FINISHED CEILING AREAS. SEE GAS ROOF TOP UNIT DETAILS.
- INSTALL ALL GRIDPOINT REMOTE SENSORS & CO2 SENSORS AT AN ACCESSIBLE LOCATION. SENSORS ARE NOT TO BE LOCATED BEHIND TENANT SHELVING. CONTRACTOR SHALL FIELD SPLICE CABLE & EXTEND CABLE TO LOCATIONS AS SHOWN. SEE TENANT'S "EM" SHEETS FOR MORE INFORMATION. LOCATIONS ARE PER O'REILLY'S REQUIREMENTS.
- COORDINATE LOCATION OF LIGHT FIXTURE(S).
- EXPOSED CEILING AREA. ALL OTHER AREAS ARE GYPSUM OR LAY-IN AS SHOWN.
- SEE ROUND DUCT MOUNTED REGISTER DETAIL #D-1-9
- SEE ROUND TAP DETAIL #D-1-8.
- SIDEWALL RETURN AIR GRILLE(S). SEE RETURN DUCT DETAIL.
- RUN EXHAUST DUCT TO EXHAUST FAN AND OUT TO WALL CAP. COORDINATE ELEVATION (MINIMUM 10'-0") OF WALL CAP WITH GENERAL CONTRACTOR.
- ALL CAULKING ON BUILDING PENETRATIONS SHALL BE A ONE-COMPONENT NON-SAG URETHANE ELASTOMERIC SEALANT (NO EXCEPTIONS).
- COVER ALL DUCT OPENINGS AND PROTECT ALL MECHANICAL EQUIPMENT DURING CONSTRUCTION AND STORAGE PRIOR TO CONSTRUCTION UNTIL FINAL START UP OF THE HVAC EQUIPMENT. ALL DUCT AND OTHER RELATED AIR DISTRIBUTION OPENINGS SHALL BE COVERED WITH TAPE, PLASTIC, SHEET METAL OR OTHER METHODS TO REDUCE THE AMOUNT OF DUST OR DEBRIS COLLECTING IN THE HVAC SYSTEMS.
- THERMOSTAT BANK LOCATION. GRIDPOINT THERMOSTATS PROVIDED BY THE TENANT AND INSTALLED BY THE TENANT'S SUGGESTED EMS CONTRACTOR.
- PROVIDE TEMPORARY THERMOSTAT AND WIRING FOR UNIT START UP. PERMANENT THERMOSTAT TO BE INSTALLED BY TENANT'S SUGGESTED EMS CONTRACTOR.
- REMOTE TEST STATION FOR DUCT SMOKE DETECTOR. MOUNT AT 5'-0" A.F.F.
- REMOTE ALARM/STROBE FOR DUCT SMOKE DETECTOR. MOUNT AT 7'-6" A.F.F.
- OFFICE INLINE FAN TO DISCHARGE INTO PLENUM SPACE.
- SEE RETURN AIR PLENUM DETAIL D-1-10A. INSTALL ELBOW JUST ABOVE CEILING PLATFORM.

PRIOR TO INSTALLATION, VERIFY ALL DUCTWORK, PIPING, WIRING, CONDUITS AND EQUIPMENT LOCATIONS SHOWN ON DRAWINGS TO AVOID CONFLICTS WITH THE BUILDING STRUCTURE, WALLS, CEILINGS, LIGHTS, ELECTRICAL ITEMS AND/OR OTHER TRADE ITEMS. NOTIFY DESIGN ENGINEER IN WRITING PRIOR TO ANY CHANGES.

All rights reserved. This document is fully protected by copyright and nothing that appears in it may be reproduced, either wholly or in part, without special permission. United Engineering, Inc. specifically excludes warranties, expressed or implied, as to the accuracy of the data and other information set forth in this document and does not assume liability for any losses or damage resulting from the use of the materials or application of the data discussed in this document.

**United Engineering, Inc.**

PROJECT ENGINEERING AND LAYOUT SERVICES  
1006 GENEVA ST. \* SHOREWOOD, IL 60404  
PHONE: (815)744-1010 \* FAX: (815)744-1516  
www.unitedmep.com

1/3/20

REVISIONS

THIS DRAWING	FOR COORDINATION	FOR BIDDING	FOR PERMIT	FOR CONTRACTING	NOT FOR CONSTRUCTION
NOT	NOT	10/16/19	10/16/19	NOT	NOT

**KMA & ASSOCIATES, INC. ARCHITECTS**  
SUITE F  
1121 LAKE COOK ROAD  
DEERFIELD, ILLINOIS 60015-5235  
(847)945-0284  
FAX: (847)945-6869



**O'REILLY AUTO PARTS**  
**DOLTON PLAZA**  
**1317 E. 8181 BLVD DOLTON, IL 60418**  
**FOR: DEPARTMENT PROPERTY GROUP, LLC**

SHEET TITLE  
HVAC PLAN

1906

**M**  
**1**