


GAS METER LOAD SCHEDULE		
TENANT	CFH	PRESSURE
100-RETAIL	480 (ALT)	6" W.C.

- ### PLAN NOTES
- SEE DETAILS ON THIS SHEET FOR ADDITIONAL INFORMATION.
 - TYPICAL EQUIPMENT MOUNTED ON CURB. SEE ROOF CURB DETAIL #D-1-11A.
 - GAS PIPE UP IN CURB AND THRU UNIT BASE.
 - SEE GAS ROOF TOP UNIT DETAIL FOR GAS PIPING TRIM.
 - GAS METER LOCATION. COORDINATE METER SIZE AND LOCATION WITH GAS COMPANY. SEE GAS METER LOAD SCHEDULE.
 - RUN GAS PIPING BELOW ROOF. GAS PIPING TO BE INSTALLED ABOVE BOTTOM OF JOISTS WHEN POSSIBLE.
 - RUN GAS PIPING UP EXTERIOR WALL. GAS PIPING TO ENTER BUILDING ABOVE THE BOTTOM OF THE JOISTS. VERIFY ELEVATION OF GAS PIPE INTO BUILDING WITH CITY.
 - PAINT ALL EXTERIOR GAS PIPING TO MATCH COLOR OF EXTERIOR WALL.
 - REPLACE ALL RTU FILTERS FOR RETURN AND OUTSIDE AIR PRIOR TO STORE OPENING. PROVIDE ADDITIONAL SET OF FILTERS TO OWNER AT JOB COMPLETION. CONTRACTOR TO SHOW THE STORE MANAGER THE LOCATION OF FILTERS AND INSTRUCT MANAGER HOW TO CHANGE ALL UNIT FILTERS.

GAS PIPING PLAN


SCALE: 1/8" = 1'-0"



RPS CORPORATION, MODEL: RC-2 OR EQUAL
 * 18 GAUGE GALVANIZED STEEL
 * WOOD NAILER
 * UNITIZED CONSTRUCTION
 * SLOPED CURB AS REQUIRED FOR ROOF PITCH
 * INTERIOR LINING
 * DAMPER SHELF (IF REQUIRED)


ROOF CURB DETAIL

NO SCALE #D-1-11A



GAS ROOF TOP UNIT (SUPPLY DUCT) DETAIL

(LOW PRESSURE) GAS PIPE INSIDE



GAS ROOF TOP UNIT (RETURN DUCT) DETAIL

(LOW PRESSURE) GAS PIPE INSIDE

PRIOR TO INSTALLATION, VERIFY ALL DUCTWORK, PIPING, WIRING, CONDUITS AND EQUIPMENT LOCATIONS SHOWN ON DRAWINGS TO AVOID CONFLICTS WITH THE BUILDING STRUCTURE, WALLS, CEILINGS, LIGHTS, ELECTRICAL ITEMS AND/OR OTHER TRADE ITEMS. NOTIFY DESIGN ENGINEER IN WRITING PRIOR TO ANY CHANGES.

All rights reserved. This document is fully protected by copyright and nothing that appears in it may be reproduced, either wholly or in part, without special permission. United Engineering, Inc. specifically excludes warranties, expressed or implied, as to the accuracy of the data and other information set forth in this document and does not assume liability for any losses or damage resulting from the use of the materials or application of the data discussed in this document.

United Engineering, Inc.
 PROJECT ENGINEERING AND LAYOUT SERVICES
 1006 GENEVA ST., * SHOREWOOD, IL 60404
 PHONE: (815)744-1010 * FAX: (815)744-1516
 www.unitedmep.com

1/3/20
 REVISIONS

THIS DRAWING	FOR COORDINATION	FOR BIDDING	FOR PERMIT	FOR CONTRACTING	NOT FOR CONSTRUCTION
NOT	10/16/14	10/16/14	10/16/14	10/16/14	NOT

KMA & ASSOCIATES, INC. ARCHITECTS
 SUITE F
 1121 LAKE COOK ROAD
 DEERFIELD, ILLINOIS 60015-5235
 (847)945-0284
 (847)945-6869



O'REILLY AUTO PARTS
DOLTON PLAZA
1317 E 818TH BLVD DOLTON, IL 60418
FOR: DEPARTMENT PROPERTY GROUP, LLC

SHEET TITLE
 GAS PIPING PLAN

1906

M
2