
	LIGHT FIXTURE SCHEDULE														INTERIOR LIGHTING ZO		
WILL BE SHALL BE	SUPPLIED BY T	HE "LIGHT FIXTURE SCHEDULE" HE OWNER (O'REILLY). ITEMS RED AND OR RELEASED FROM EQUIPMENT DISTRIBUTOR:	GRAYBAR ELECTRIC CO. INC. 11885 LACKLAND ROAD ST. LOUIS, MO 63146										GRAYBAR OREILLY TEAM EMAIL: oreilly@graybar.com TOLL FREE: (314) 573-2080 NO SUBSTITUTES		ALL NTERIOR LIGHTING WITH N PARTS AREA "A" SHALI CONSIDERED "SALES" ZONE (ON ONLY WHEN STORE FOR BUSINESS). ALL NTERIOR LIGHTING WITH PARTS AREA "B", PARTS		
100000000000	SSS-410 ASSESS		SUPPLY	SASCOPPRIE DE	RECESSED SE SURFACE WALL SE SURF. CEILING	± a L	_ [_ [NCANDESCENT 34	OTHER STANDING TO STAND STANDING TO STANDI	(General Electric)	FLEASSOCIEVIENSIA DALONIO	DESCRIPTION OF		TOTAL	RESTROOMS, OFFICE, AND BREAK AREA SHALL BE CON "WORK" ZONES (ON WHENEVER THERE IS MOTION OR STORE IS OPEN). EMERGENCY/EXIT LIGHT		
MARK	MFR.	CATALOG NUMBER	VOLTAGE			22. 22.	200 C2-85 T			NUMBER/TYPE	WATTAGE	ACCESSORIES	NOTES		PLACE EXIT SIGNS HIGH ENOUGH TO BE SEEN ABOVE A MERCHANDISE WITH THE FOLLOWING LIMITATION: THE		
LED DI	MMABLE LIGHTS	S - ALL INDOOR LIGHT FIXTURES SHALL HAVE	DISCONNEC	T NG MEAN	The second second second	550-100-1550-1	NEC 4	10.130	(G)	Ţ.				1	HEIGHT FOR AN EXIT LIGHT ASSOCIATED WITH A SPECI		
Α	LSI	SDL 8 LED 80L FL UNV DIMI 40 80CRI OR NO SUBSTITUTIONS	120	WHITE	X			X			62	GRID HANGER (2 PER FIXTURE)	GRID HANGER (648480) (CEILING GRID ONLY) 0-10 VOLT DIMMING DRIVER STANDARD	52	OPENING (I.E. MOUNTED OVER A DOOR OR OPENING) NO GREATER THAN THE CODE ALLOWED 6'-8" ABOVE T		
В	LSI	SDL 4 LED 40L FL UNV DIMI 40 80CRI OR NO SUBSTITUTIONS	120	WHITE	x			x			30	GRID HANGER (2 PER FIXTURE)	GRID HANGER (648480) (CEILING GRID ONLY 0-10 VOLT DIMMING DRIVER STANDARD. OMIT GRID HANGER @ HARD CEILING	9	EDGE OF THE DOOR OR OPENING.		
С	LSI	SDL 8 LED 80L FL UNV DIMI 40 80CRI OR NO SUBSTITUTIONS	120	WHITE		X		x			62	5' CHAIN HANGING KIT (1 PER FIXTURE)	HANG TOP OF FIXTURE AT 12' AFF. WITH CHAIN HANGERS AND LENGTH OF CHAIN AS REQUIRED. 0-10 VOLT DIMMING DRIVER STANDARD	33	NOTE: ELECTRICAL TRADE SHALL WIRE NL LIGHTING TO SEPARATE INDEPENDENT UN-SWITCHED		
D	LSI	SDL 4 LED 40L FL UNV DIMI 40 80CRI OR NO SUBSTITUTIONS	120	WHITE		x		x		222	30	5' CHAIN HANGING KIT (1 PER FIXTURE)	HANG TOP OF FIXTURE AT 12' AFF. WITH CHAIN HANGERS AND LENGTH OF CHAIN AS REQUIRED. 0-10 VOLT DIMMING DRIVER STANDARD	8	CIRCUIT. WIRE IN SEPARATE RACEWAY. WIRING IS NOT SHOWN FOR CLARITY. NO APPLIANCES, LAMPS OTHER THAN THOSE		
COMB N	ATION EXIT/ EMER	RGENCY LIGHTS, EMERGENCY LIGHTS & EXTERIOR E	MERGENCY RE	MOTE HEAD	S	en en				- Ar	eta ,	2			SPECIFIED AS REQUIRED FOR NIGHT LIGHT USE		
XR	COOPER	APCH7R (RED LETTERS)	120	WHITE	x x			x	2	LED EXIT + (2) 3.6V.	2 34	UNIVERSAL WALL/CLG. SINGLE OR DOUBLE FACE	BACKUP BATTERIES SHALL MAINTAIN 100% ILLUMINATION FOR A MINIMUM OF 90 MINUTES TO COMPLY WITH ARTICLE 700.12 (A.) OF THE N.E.C.	9	SHALL BE SUPPLIED BY NIGHT LIGHT CIRCUIT.		
EM	COOPER	APEL	120	WHITE	x x			x	2	3 6V.	0 33	UNIVERSAL WALL/ CLG.	BACKUP BATTERIES SHALL MAINTAIN 100% ILLUMINATION FOR A MINIMUM OF 90 MINUTES TO COMPLY WITH ARTICLE 700.12 (A.) OF THE N.E.C.	15			
RH2	COOPER	APWR2 Dual Voltage (IFC 1003.2.10.5)	6V. DC	WHITE	x			x	2	LED REMOTE HEAD	0	WALL MOUNT	POWERED BY EMERGENCY "XR" FIXTURE	3	Q		
LED EXT	ERIOR LIGHTS					E E				1			T				
PC	INTERMATIC	PHOTOCELL #4251	120	DARK BRONZE	X					(<u>4.5.45 - 19 1</u>	227	<u> </u>	MOUNT ABOVE WALL PACK LOCATED NEAR FREIGHT DOOR.	1			
L	LSI	LAD6 41 LED 40 75 UE TR6R SFHAZ	120	CLEAR	x			x	1	<u></u>	45	<u> </u>	RECESSED CAN.	1			
WP1	LSI	XWM-FT-LED-06L-40-UE-BRZ	120	DARK BRONZE	x			x	1	<u> </u>	59	8 <u>1—422-32</u> 2	FULL CUT-OFF. MOUNT 12' A.F.F. TO CENTERLINE OF FIXTURE.	2			
WS1	LSI	XWM-FT-LED-DBL-40-UE-BRZ	120	DARK BRONZE	x			x	1		59	2 7-3-4 2	FULL CUT-OFF, PARAPET WALL	1			
F4	LSI	XWM-FT-LED-06-40-UE-BRZ	120	DARK BRONZE	x			X	1	<u></u>	59	(====)	FULL CUT-OFF.	2			

GENERAL NOTES

- A. LIGHTING AND EQUIPMENT BRANCH CIRCUIT BREAKERS ARE SERIES RATED WITH REMOTE MAIN BREAKERS IN ACCORDANCE WITH UL 489.
- B. PANELBOARD COMPONENTS INCLUDING OVERCURRENT PROTECTION DEVICES SHALL BE FULLY RATED FOR THE AVAILABLE FAULT CURRENT.
- C. NO DESIGN CHANGES MAY BE MADE TO THE SYSTEM WITHOUT PRIOR WRITTEN APPROVAL OF THE OWNER AND THE ELECTRICAL INSPECTOR.
- D. A.I.C. RATING SHOWN AT THE PANEL BOARD IS MINIMUM RATING FOR OVERCURRENT PROTECTION DEVICES. EACH DEVICE SHALL BE FULLY RATED WITH UPSTREAM DEVICES AT AFC AS SHOWN ON PANEL SCHEDULE.
- E. ELECTRICAL BOXES AND/OR CONDUIT INSTALLED IN SUSPENDED CEILINGS SHALL NOT EXCEED 100 CUBIC INCHES IN SIZE, AND THEY SHALL EITHER BE FASTENED TO FRAMING MEMBERS BY BOLTS, SCREWS, RIVETS OR APPROVED CLIPS, OR SECURED TO CEILING SUPPORT.



LIGHTS-NEUTRAL

FAN-NEUTRAL

IGHTS-NEUTRAL

FAN-SWITCHED .

LIGHT

LIGHTING - KEYNOTES

- MOUNT J-BOX INS DE BUILDING & FLEX CONDUIT THRU WALL FOR POWER SUPPLY TO LLUMINATED SIGN. EXACT LOCATIONS OF PENETRATIONS SHALL BE COORD NATED WITH SIGN COMPANY. PENETRATIONS SHALL BE BEHIND SIGNAGE. WATERPROOF W/ ELASTOMERIC POLYURETHANE (NO EXCEPTIONS) EQUAL TO "VULKEM" 116. WIRE TO SIGN WITH 15' OF WIRING "WHIP" SHALL BE FLEX OR TYPE MC CABLE). COIL AND "CABLE TIE" W RING "WHIP TO WALL ABOVE CEILING. TYPICAL.
- 2 TO "OPEN" SIGN. SEE SHEET E2.
- SEE "E" PANEL TRANSFER SWITCH SCHEDULE FOR POSITION OF CIRCUIT W RES THROUGH TRANSFER SWITCH.
- 4 VIA LIGHTING CONTROL PANEL. SEE EM SHEET.
- DIMMER LIGHTING CONTROL SWITCHES LOCATED ON OUTS DE WALL OF OFFICE. SEE LIGHTING PLAN FOR QUANTITY. SEE DETAILS ON SHEET E4 FOR MORE NFORMATION.
- 6 SUSPEND 8'-0" A.F.F. THIS FIXTURE ONLY.
- ROUTE THE OFFICE AND RESTROOM'S LIGHTING CIRCUIT THRU THE LOCAL OCCUPANCY SENSORS AND DIRECTLY TO THE CIRCUIT BREAKER, THESE FIXTURES SHALL NOT BE SWITCHED BY THE LIGHTING CONTROL PANEL. SEE "E" PANEL TRANSFER SWITCH SCHEDULE FOR POSITION OF CIRCUIT WIRES THROUGH TRANSFER
- WALL MOUNTED FIXTURES TO BE ROUTED TO GRIDPOINT SYSTEM AS NOTED, PROVIDE BACK BOXES, FIXTURES MOUNTED AT 16'-6". AS NOTED. PROVIDE BACK BOXES, FIXTURES MOUNTED AT 16'-6".
- 9 SECURITY & EGRESS FIXTURE TO BE AS CLOSE AS POSSIBLE BUT NOT OVER THE OVERHEAD DOOR WHEN OPEN.
- ROUTE SECURITY & EGRESS LIGHTING C RCUIT D RECTLY TO THE ELECTRICAL PANEL.
- EC SHALL PROVIDE CE LING SUPPORT AS REQUIRED FOR EXIT AND EMERGENCY INSTALLATION.
- EC SHALL PROVIDE ADDITIONAL SUPPORT AT STRUCTURAL AS REQUIRED FOR EXIT AND EMERGENCY INSTALLATION.

LIGHTING CIRCUIT FROM ELECTRICAL PANEL. -"NORMAL" ONLY TYPICAL JUNCTION BOX PANEL PLP INTERIOR LOCATED NEXT TO PANEL. LIGHTS. SEE KEYNOTE #4. N ORDER TO COMPLY WITH NEC 700.12 (F): ALL **EMERGENCY** FIXTURES SHALL BE WIRED TO THE LIGHT NG CONTROL PANEL SAME BRANCH CIRCUIT AS THAT SERVING THE NORMAL LIGHTING IN THE AREA AND CONNECTED AHEAD OF LOCAL OPEN SIGN, PARTS AREA A SWITCHES AND THE EMERGENCY/EXIT "LIGHTING CONTROL FIXTURE (TYP.) SECURITY & EGRESS LIGHTING EMERGENCY/ EXIT LIGHTING CONNECTION DIAGRAM

INTERIOR LIGHTING ZONES AUTOMATIC LIGHTING CONTROL

SCALE: 1/8" = 1'-0"

ALL NTERIOR LIGHTING WITH N PARTS AREA "A" SHALL BE CONSIDERED "SALES" ZONE (ON ONLY WHEN STORE IS OPEN FOR BUSINESS).

ALL NTERIOR LIGHTING WITH PARTS AREA "B", PARTS AREA "C", RESTROOMS, OFFICE, AND BREAK AREA SHALL BE CONS DERED "WORK" ZONES (ON WHENEVER THERE IS MOTION OR THE STORE IS OPEN).

EMERGENCY/EXIT LIGHTING

PLACE EXIT SIGNS HIGH ENOUGH TO BE SEEN ABOVE ALL MERCHANDISE WITH THE FOLLOWING LIMITATION: THE MAX MUM HEIGHT FOR AN EXIT LIGHT ASSOCIATED WITH A SPECIFIC OPENING (I.E. MOUNTED OVER A DOOR OR OPENING) SHALL BE NO GREATER THAN THE CODE ALLOWED 6'-8" ABOVE THE TOP EDGE OF THE DOOR OR OPENING.

COMPLIANCE WITH ENERGY CODE IS ACHIEVED BY:

ONCE THE EMS HAS BEEN PROGRAMMED. THE INTERIOR AND EXTERIOR LIGHTS WILL TURN ON AND OFF USING THE FOLLOWING LOGIC: SEE EM

INTERIOR WORK LIGHTS WILL TURN ON WITH FIRST MOTION IN THE STORE AND WILL TURN OFF 15 MINUTES AFTER LAST MOTION ONCE THE STORE IS

INTERIOR SALES LIGHTS WILL TURN ON AT STORE OPENING AND TURN OFF 15 MINUTES AFTER STORE CLOSING.

EXTERIOR SIGN LIGHTS WILL TURN ON WHEN ITS DARK ENOUGH OUTS DE ANYTIME DUR NG STORE HOURS, AND WILL TURN OFF AT STORE CLOSING.

EXTERIOR SITE LIGHTS WILL TURN ON WHEN IT IS DARK ENOUGH OUTS DE AND IT IS WITH N STORE HOURS OR THERE IS MOTION N THE STORE. THEY WILL TURN OFF 30 M NUTES AFTER LAST MOTION ONCE THE STORE IS CLOSED.

FOR NEW CONSTRUCTION LOCATIONS ONLY, THERE IS A TEMPORARY PROGRAM TO KEEP SIGN AND SITE LIGHTS ON UNTIL M DNIGHT RATHER THAN THE TIMES INDICATED ABOVE. O'REILLY WILL DISABLE THIS PROGRAM ONE YEAR AFTER STORE OPENING.

RESTROOMS AND OFFICES: ALL LIGHTING IN THESE AREAS ARE CONTROLLED BY OCCUPANT-SENSING DEVICES.


CONDUIT REQUIREMENTS

ALL WIRING SHALL BE IN CONDUIT, EXCEPT THAT MC-CABLE MAY BE SUBSTITUTED ONLY AS FOLLOWS A. MC-CABLE (MAXIMUM CABLE LENGTH OF 6'-0") MAY BE

LOCATIONS INDICATED ON E2 SHEET."

SEE SHEET E4 FOR MORE REQUIREMENTS

INSTALLED ONLY FOR BRANCH CIRCUIT WIR NG TO LIGHT B. "MC-CABLE (MAXIMUM CABLE LENGTHS SHOWN ON DETA L 2/E2) MAY BE INSTALLED ONLY ABOVE SLAB AND ONLY AT



/1\ 1/13/20 REVISIONS

SCALE: NONE

RESTROOM 1 (RR1)

RESTROOM 2 (RR2)

FAN AND LIGHT C RCUITS MUST BE

RESTROOM EXHAUST FAN WIRING DIAGRAM

WIRE ON THE SAME PHASE

LIGHT RR1-SWITCHED

FAN-SWITCHED

LIGHT RR1-SWITCHED

FAN-SWITCHED

LIGHT RR1-HOT

FAN-HOT

RR2-HOT

FAN-HOT