

		PROTECTIVE DEVICE AND THEIR DESIGNATIONS																																								
		CAPACITOR BANK C1			OUTGOING NO.1		OUTGOING NO.2		INCOMING LINE NO.1					OUTGOING NO.3		OUTGOING NO.4		OUTGOING NO.5		BUS COUPLING BREAKER		OUTGOING NO.6		OUTGOING NO.7		OUTGOING NO.8		INCOMING LINE NO.2					OUTGOING NO.9		OUTGOING NO.10		CAPACITOR BANK C2					
		OVERCURRENT PHASE AND GROUND RELAY	CAPACITOR BANK UNBALANCE SENSING RELAY	CAPACITOR BANK BREAKER FAILURE RELAYING	OVERCURRENT PHASE AND GROUND RELAY	OUTGOING BREAKER FAILURE RELAYING	OVERCURRENT PHASE AND GROUND RELAY	OUTGOING BREAKER FAILURE RELAYING	OVERCURRENT PHASE AND GROUND RELAY	22kV.SWITCHGEAR MAIN BUS NO.1 ARC PROTECTION	INCOMING LINE BREAKER FAILURE RELAYING	UNDER FREQUENCY RELAY	UNDER AND OVER VOLTAGE RELAY	OVERCURRENT PHASE AND GROUND RELAY	OUTGOING BREAKER FAILURE RELAYING	OVERCURRENT PHASE AND GROUND RELAY	OUTGOING BREAKER FAILURE RELAYING	OVERCURRENT PHASE AND GROUND RELAY	OUTGOING BREAKER FAILURE RELAYING	OVERCURRENT PHASE AND GROUND RELAY	BUS COUPLING BREAKER FAILURE RELAYING	OVERCURRENT PHASE AND GROUND RELAY	OUTGOING BREAKER FAILURE RELAYING	OVERCURRENT PHASE AND GROUND RELAY	OUTGOING BREAKER FAILURE RELAYING	OVERCURRENT PHASE AND GROUND RELAY	OUTGOING BREAKER FAILURE RELAYING	OVERCURRENT PHASE AND GROUND RELAY	22kV.SWITCHGEAR MAIN BUS NO.2 ARC PROTECTION	INCOMING LINE BREAKER FAILURE RELAYING	UNDER FREQUENCY RELAY	UNDER AND OVER VOLTAGE RELAY	OVERCURRENT PHASE AND GROUND RELAY	OUTGOING BREAKER FAILURE RELAYING	OVERCURRENT PHASE AND GROUND RELAY	OUTGOING BREAKER FAILURE RELAYING	OVERCURRENT PHASE AND GROUND RELAY	CAPACITOR BANK UNBALANCE SENSING RELAY	CAPACITOR BANK BREAKER FAILURE RELAYING			
LOCATION OF DEVICE (PNL.NO.)		C1			01		02		I1					03		04		05		BC1		06		07		08		I2					09		010		C2					
DEVICE NO.		50 ST	50N 5TN	60	50 BF	50 ST	50N 5TN	50 BF	50 ST	50N 5TN	50 BF	50 ST	50N 5TN	50 BF	81	27 59	50 ST	50N 5TN	50 BF	50 ST	50N 5TN	50 BF	50 ST	50N 5TN	50 BF	50 ST	50N 5TN	50 BF	50 ST	50N 5TN	50 ARC	50 BF	81	27 59	50 ST	50N 5TN	50 BF	50 ST	50N 5TN	50 BF	60	50 BF
AUXILIARY TIMING RELAY																																										
AUXILIARY TRIPPING RELAY				86 BF		86 BF		86 BF		86 ARC	86 BF	81X		86 BF		86 BF		86 BF		86 BF		86 BF		86 BF		86 BF		86 BF		86 ARC	86 BF	81X			86 BF		86 BF			86 BF		
TRIPPING RELAY CHARACTERISTICS				HS ER		HS ER		HS ER		HS ER	HS ER	SS SR		HS ER		HS ER		HS ER		HS ER		HS ER		HS ER		HS ER		HS ER		HS ER	HS ER	SS SR			HS ER		HS ER			HS ER		
OPERATION TARGET/AUDIBLE ALARM		Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y		
FUNCTION OF DEVICE	1CVB-01	T		T1		T1		T1		T1	T1		T1		T1		T1		T1																							
	01VB-01			T1	TR	T1		T1		T1	T1	T	T1		T1		T1		T1																							
	02VB-01			T1		T1	TR	T1		T1	T1	T	T1		T1		T1		T1																							
	1BVB-01			T1		T1		T1	T	T1	T1		T1		T1		T1		T1		T1																					
	03VB-01			T1		T1		T1		T1	T1	T	T1	TR	T1		T1		T1																							
	04VB-01			T1		T1		T1		T1	T1	T	T1		T1	TR	T1		T1																							
	05VB-01			T1		T1		T1		T1	T1	T	T1		T1		T1	TR	T1																							
	08VB-01			T1		T1		T1		T1	T1		T1		T1		T1		T	T1		T1					T1			T1	T1					T1				T1		
	06VB-01																					TR		T1		T1		T1		T1	T1	T				T1				T1		
	07VB-01																							TR	TL		T1		T1		T1	T1	T			T1				T1		
	08VB-01																									T1	TR	TL		T1	T1	T			T1				T1			
	2BVB-01																											TR	TL		T1	T1					T1				T1	
	09VB-01																														T1	T1	T		TR	T1		T1			T1	
	10VB-01																														T1	T1	T			T1	TR	T1			T1	
	2CVB-01																														T1	T1					T1				T	T1
	02YB-01										T1	T1																			T1	T1										
	03YB-01																															T1	T1									
C-BANK VACUUM SWITCHES-SWGR NO.1			T1											T1																												
C-BANK VACUUM SWITCHES-SWGR NO.2																																										T1

NOTES

1. EACH PANEL SHALL HAVE IT OWN AUXILIARY TRIPPING AND LOCKOUT RELAYS ;
ONE FOR EACH BREAKER FAILURE PROTECTION AND THE OTHER ONE FOR ARC PROTECTION.
IF ANY BREAKER FAILURE OCCURS, ITS BREAKER FAILURE RELAYING SHALL INITIATE ALL BREAKER
AUXILIARY TRIPPING AND LOCKOUT RELAYS TO TRIP ALL BREAKERS WHICH ARE CONNECTED
WITH THE SAME BUS INCLUDING THE BUS SECTION BREAKER, EXCEPT FOR THE INCOMING
BREAKER FAILS, THE INCOMING BREAKER FAILURE RELAYING SHALL, IN ADDITION TO THE ABOVE
FUNCTIONS, TRIP AND LOCKOUT 115 kV TRANSFORMER BREAKER. SIMILARY, THE ARC DETECTION
SHALL HAVE THE SAME TRIP AND LOCKOUT FUNCTIONS AS THOSE FOR THE BREAKER FAILURE PROTECTION.
2. EACH UNDER FREQUENCY RELAY SHALL BE FURNISHED TO PERFORM THE LOAD SHEDDING SCHEME
BY USING A CUT-OFF SWITCH (81CO) FOR TRIPPING THE OUTGOING LINE AS REQUIRED.
3. IN CASE OF OVERVOLTAGE TO THE CAPACITOR BANKS, THE OVERVOLTAGE RELAY (59) SHALL TRIP
ALL VACUUM SWITCHES OF THE CAPACITOR BANKS AND PROVIDE THE CONTACT TO RESET THE POWER
FACTOR CONTROLLER TO RETURN TO THE NEUTRAL STAGE TO PREVENT THE POWER FACTOR CONTROLLER
FROM RECLOSING THE VACUUM SWITCHES AGAIN.
4. BAY CONTROL UNIT (BCU) IS INTEGRATED IN PROTECTIVE RELAY.
5. FOR CIRCUIT BREAKER FAILURE FUNCTION (50BF) AND ARC PROTECTION FUNCTION (50ARC) SHALL BE TRIP VIA GOOSE.

LEGEND	EXPLANATION
Y	YES
HS	HIGH SPEED
SS	STANDARD SPEED
ER	ELECTRICAL RESET
SR	SELF RESET
Tr	3-POLE TRIP AND RECLOSE
T	3-POLE TRIP- NO RECLOSING
T _L	3-POLE TRIP AND LOCKOUT
T ₁	BREAKER TRIP FOR CB FAILURE AND ARC PROTECTIONTRIP BY GOOSE

REFERENCE DRAWING

– METERING AND RELAYING DIAGRAM.....DWG NO. FA4-011/63023

OYM-PP		
กองออกแบบสถานีไฟฟ้า ฝ่ายงานสถานีไฟฟ้า	การไฟฟ้าส่วนภูมิภาค	ใช้แบบ _____ ถูกแทนโดยแบบ _____
ผู้เขียน _____ ศุภชัย _____ ผู้สำรวจ _____ วิศวกร _____	ผู้ว่าการ _____ (แทน)	เขียนเสร็จวันที่ 3 มีค 2563 แก้แบบวันที่ _____
หัวหน้าแผนก วรรณพงษ์ ผู้อำนวยการกอง _____ ผู้อำนวยการฝ่าย _____ (แทน)	สถานีไฟฟ้าอ้อมใหญ่ 4 จ. นครปฐม ฟังก์ชันการทำงานของอุปกรณ์ป้องกัน	ชนิดเป็น _____ มาตรฐาน _____
รองผู้ว่าการวิศวกรรม _____	OM YAI 4 SUBSTATION PROTECTIVE DEVICE FUNCTION	แบบเลขที่ FA4-011/63024 แผ่นที่ 2 ของจำนวน 2 แผ่น