

MR Credit: PBT Source Reduction – Lead, Cadmium, and Copper

1–2 Points – BD+C: Healthcare only

This credit applies to

- BD+C: Healthcare

INTENT

To reduce the release of persistent, bioaccumulative, and toxic (PBT) chemicals associated with the life cycle of building materials.

REQUIREMENTS

Specify substitutes for materials manufactured with lead and cadmium, as follows.

Lead Requirements

- For water intended for human consumption, specify solder and flux to connect plumbing pipe on site that meets California AB1953 (solder no more than 0.2% lead; flux no more than 0.25% lead weighted average for wetted surfaces).
- For water intended for human consumption, specify pipes, pipe fittings, plumbing fittings, and faucets meeting California law AB1953 (weighted average lead content of wetted surface area of not more than 0.25% lead).
- Specify and use lead-free roofing and flashing.
- Specify and use electrical wire and cable with lead content less than 300 parts per million.
- Specify no use of interior or exterior paints containing lead.
- For renovation projects, ensure the removal and appropriate disposal of disconnected wires with lead stabilizers, consistent with 2002 National Electric Code requirements.

Lead used for radiation shielding and copper used for MRI shielding are exempt.

Cadmium Requirements

- Specify no use of interior or exterior paints containing intentionally added cadmium.

Copper Requirements

For copper pipe applications, reduce or eliminate joint-related sources of copper corrosion:

- Use mechanically crimped copper joint systems; OR
- Specify that all solder joints comply with ASTM B828 2002, and specify and use ASTM B813 2010 for flux.

GUIDANCE

There are no substantive changes to the credit requirements; refer to the LEED v4 reference guide, with the following addition:

Connection to Ongoing Performance

- LEED O+M MR credit Purchasing: This credit is a strategy that can help achieve the MR credit Purchasing in O+M v4.1 rating system.