

MR Credit: PBT Source Reduction – Mercury

1 Point – BD+C: Healthcare only

This credit applies to

- BD+C: Healthcare

INTENT

To reduce the release of persistent, bioaccumulative, and toxic (PBTs) chemicals associated with the life cycle of building materials.

REQUIREMENTS

Specify and install fluorescent lamps with both low mercury content (per MR Prerequisite PBT Source Reduction—Mercury) and long lamp life, as listed in Table 1.

Table 1. Criteria for rated life of low-mercury lamps

Lamp	Maximum content	Lamp life (hrs)
T-8 fluorescent, eight-foot	10 mg mercury	Standard output – 24,000 rated hours on instant start ballasts (3-hour starts) High output – 18,000 rated hours on instant or program start ballasts (3-hour starts)
T-8 fluorescent, four-foot	3.5 mg mercury	Both standard and high output – 30,000 hrs on instant start ballasts, or 36,000 hrs on program start ballasts (3-hour starts)
T-8 fluorescent, two-foot and three-foot	3.5 mg mercury	24,000 rated hours on instant start or program start ballasts (3-hour starts)
T-8 fluorescent, U-bent	6 mg mercury	18,000 hrs on instant start ballasts, or 24,000 hrs on program start ballasts (3-hour starts)
T-5 fluorescent, linear	2.5 mg mercury	Both standard and high-output – 25,000 rated hours on program start ballasts
T-5 fluorescent, circular	9 mg mercury	Both standard and high-output – 25,000 rated hours on program start ballasts
Compact fluorescent, nonintegral ballast	3.5 mg mercury	12,000 rated hours
Compact fluorescent, integral ballast, bare bulb	3.5 mg mercury, ENERGY STAR qualified	Bare bulb – 10,000 rated hours Covered models (globes, reflectors, A-19s) – 8,000 hours
High-pressure sodium, up to 400 watts	10 mg mercury	Use noncycling type or replace with LED lamps or induction lamps
High-pressure sodium, above 400 watts	32 mg mercury	Use noncycling type or replace with LED lamps or induction lamps

Do not specify or install circular fluorescent lamps or probe start metal halide lamps.

GUIDANCE

There are no substantive changes to the credit requirements; refer to the LEED v4 reference guide, with the following addition:

Connection to Ongoing Performance

- LEED O+M MR credit Purchasing: This credit is a strategy that can help achieve the MR credit Purchasing in O+M v4.1 rating system.