

WE Prerequisite: Building-Level Water Metering

This prerequisite applies to

- ▶ BD+C: New Construction
- ▶ BD+C: Core & Shell
- ▶ BD+C: Schools
- ▶ BD+C: Retail
- ▶ BD+C: Data Centers
- ▶ BD+C: Warehouses & Distribution Centers
- ▶ BD+C: Hospitality
- ▶ BD+C: Healthcare

INTENT

To conserve low cost potable water resources and support water management and identify opportunities for additional water savings by tracking water consumption.

REQUIREMENTS

NC, CS, SCHOOLS, RETAIL, DATA CENTERS, WAREHOUSES & DISTRIBUTION CENTERS, HOSPITALITY, HEALTHCARE

Install permanent water meters that measure the total potable water use for the building and associated grounds. Meter data must be compiled into monthly and annual summaries; meter readings can be manual or automated.

Commit to sharing with USGBC the resulting whole-project water usage data for a five-year period beginning on the date the project accepts LEED certification or typical occupancy, whichever comes first.

This commitment must carry forward for five years or until the building changes ownership or lessee.

GUIDANCE

There are no substantive changes to the prerequisite requirements; refer to the LEED v4 reference guide, with the following additions and modifications:

Further Explanation

Connection to Ongoing Performance

- ▶ LEED O+M WE credit Water Performance: Installing whole building water meters is a simple yet critical strategy for understanding total water use throughout the building life cycle. Tracking water consumption on a regular basis supports effective water management and provides performance data to help verify that building systems are operating as designed. Projects can submit data via the Arc platform to comply with the prerequisite requirement to share whole-project water usage data with USGBC and get started on the path to recertification.