

Success with 2012 Code: Checklists for Builders

AIR SEALING







JOB READY: AIR SEALING

Success with 2012 IECC for Builders

~	×	N/A	
			 For walls separating conditioned and unconditioned space, framing allows for the required R-value, has a top plate, bottom plate and an exterior air barrier.
			2. For walls that will not have an interior finish and are separating conditioned and unconditioned spaces, wall cavities are insulated and an interior air barrier is installed.
			3. All dropped ceilings/soffits, shafts and chases are capped with an air barrier.
			4. For cantilever floors, an air barrier is attached, insulated and air sealed at the underside. This air barrier can be the exterior finish material if it is airtight.
			 All floor systems within the conditioned envelope have a band or blocking separating conditioned and unconditioned space.
			6. All holes are cleanly cut and are no more than 1 inch larger than the penetrating object.
			7. Work site is clean and construction materials are properly stored before proceeding.
Builder	Verifica	ation	
✓	×		
			Stop work until details are corrected.
			Proceed without corrections.
		_	and completes this form is doing so to the best of his/her knowledge and should not be held legally responsible for work completed by other is form is to ensure job sites are ready before beginning work.
Signature	:		Date



JOB COMPLETE:

AIR SEALING

Success with 2012 IECC for Builders

~	×	N/A	
			1. Air seal all dropped ceilings/soffits, shafts and chases.
			2. For all floor systems within the conditioned envelope, air seal bands or blocking that separates conditioned and unconditioned space.
			3. Air seal all air barriers that enclose cantilevered floors.
			4. Air seal all gaps and voids between conditioned and unconditioned spaces.
			5. Air seal around windows and doors using backer rod, caulk or low expansion foam.
			6. Air seal all penetrations between conditioned and unconditioned spaces. Use fire-rated sealants where applicable.
			7. Air seal supply and return duct terminations to drywall and/or subfloor with caulk, foam or equivalent material. Use fire-rated sealants where applicable.
			8. Ensure work site is clean and construction materials are properly stored before proceeding.
Certific	ation		
		_	and completes this form is doing so to the best of his/her knowledge and should not be held legally responsible for work completed by other is to ensure job sites are ready before beginning work.
Name			
Company	,		
Signature			