

PROJECT SPECIFICATION - HVAC CLEARANCES

Document No: SPEC-HVAC-4.2 | Rev C | Metro Hub Expansion

1.0 Purpose

This section defines minimum clearances for ductwork, piping, and equipment relative to structural framing, ceilings, and other trades.

2.0 Duct clearance under beams

2.1 Supply and return ducts routed under structural steel shall maintain a minimum clear distance of 100 mm between the top of duct insulation and the bottom of steel (BOS), unless a written deviation is approved by the Structural Engineer of Record.

2.2 In Level 2 corridors C2-East and C2-West, the design soffit elevation assumes 800 x 400 mm ducts with 100 mm clearance under W18 beams.

3.0 Coordination

3.1 Level 2 MEP coordination is owned by the MEP Lead (HVAC) with Structural as co-reviewer for any clash involving primary framing members.

3.2 Soft clashes (clearance warnings between 0 and 100 mm) shall be logged in the clash register and resolved prior to shop drawing release.

3.3 Hard clashes (penetration of structural steel or concrete) require an RFI within 48 hours of discovery.

4.0 References

See Structural Grid Notes section 2 for beam depths and BOS elevations on Grid D-E.