

	RESIDUE HYDROTREATING PROJECT (RHU)			
	DOCUMENT TITLE: Surface Preparation and Painting Procedure		CON. NO.: PNA/73-98-1638	
	DOCUMENT NUMBER: VD-3607/32-00-4405-HE-PRC-0067		POI:	FA
		Rev. No:	5	

NATIONAL IRANIAN OIL COMPANY

RESIDUE HYDROTREATING PROJECT (RHU)

DOCUMENT TITLE:
Surface Preparation and Painting Procedure

DOCUMENT NUMBER:
VD-3607/32-00-4405-HE-PRC-0067

PURCHASER'S COMMENT/APPROVAL STATUS					Purchaser: NARGAN	
	1. AP: Approved (Released for Manufacturing)				Requisition No.: 3607-33-74-EP-HE-MR-4405	
	2. AN: Approved as Noted for Fabrication (Fabrication may Proceed)					
	3. NF: Approved as Noted for Re-Issue (Fabrication not Proceed)				Item No. (Tag No.): All Items	
	4. RE: Rejected					
	5. NR: Not Returned				Vendor Doc. No.: VD-3607/32-00-4405-HE-PRC-0067	
Date: XX.XX.XX		Signature:				
5	28-Jan-2023	FA	M.F	M.A	P. K	
4	20-Dec-2022	FA	M.F	M.A	P. K	
3	10-Sep-2022	FA	M.F	M.A	P. K	
2	02-Oct-2021	FA	M.F	M.A	P. K	
1	20-Jul-2021	FA	M.F	M.A	P. K	
0	04-Apr-2021	FA	M.F	M.A	P. K	
REV	DATE	DESCRIPTION	PREP'D	CHK'D	APP'D	





	RESIDUE HYDROTREATING PROJECT (RHU)			
	DOCUMENT TITLE: Surface Preparation and Painting Procedure		CON. NO.: PNA/73-98-1638	
			POI:	FA
DOCUMENT NUMBER: VD-3607/32-00-4405-HE-PRC-0067		Rev. No:	5	

Table of Contents

1	Scope	3
2	Definition	3
3	Reference	3
4	Requirement	3
5	General.....	3
6	Surface Preparation	4
7	Storage, mixing and thinning of products	5
8	Priming	5
9	Painting Application	5
10	Galvanizing	6
11	Inspection	6
12	Quality Control and testing.....	6
13	Repair of Defects and Damages	7
14	Paint System	8
15	Painting Reports	8

	RESIDUE HYDROTREATING PROJECT (RHU)		
	DOCUMENT TITLE: Surface Preparation and Painting Procedure	CON. NO.: PNA/73-98-1638	
		POI:	FA
DOCUMENT NUMBER: VD-3607/32-00-4405-HE-PRC-0067	Rev. No:	5	

1. Scope

The following procedure covers the minimum requirements for surface preparation and paint application for “RESIDUE HYDROTREATING PROJECT”.

2- Definition

Project: Residue Hydro Treating Project (RHU)

Purchaser: Nargan Company (NC)

Contractor: Nargan Company (NC)

MC: National Iranian Oli Engineering & Construction Co (NIOEC)

Vendor: Aban Air Cooler

3. Reference

Job Specification for painting, 3607-32-00-ED-PI-SP-8002

4. Requirement

4.1) Coating for the protection of air cooler shall be designed and applied; for the application over the specified minimum surface preparation standards detailed in this procedure.

4.2) The paint system shall generally be based on the operating temperature of the equipment and reference specification.

5. General

All surfaces shall receive an appropriate paint system as with the following exceptions:

- any equipment furnished completely painted by the manufacturer unless it is specially required to match a color scheme or to repair damage to the paint film;
- hot-dip galvanized steel, weathering steel, stainless steel and non-ferrous metals, monel, brass, copper, aluminum jacketing;
- nonmetallic surface;
- nameplates, code stampings and push-buttons;
- surfaces to be fireproofed;
- concrete, brickwork, tile, glass and plastics, unless specially required;
- machined surfaces;
- insulation weatherproofing material or sheeting;
- rubber, hoses, belts, flexible braided connectors, stainless steel tubing and fittings, gages, valves, and motor shafts;
- and any surface particularly indicated as not to be painted.

5.1) The manufacturer shall provide and maintain in good condition all plant, equipment and tools necessary to carry out the work in and tools necessary to carry out the work in an efficient manner.



5.2) The manufacturer shall provide, unless otherwise instructed, all paints and thinners necessary to carry out the work.

5.3) The manufacturer shall provide skilled and experienced personnel to carry out the work together with competent and qualified supervision.

5.4) The manufacturer shall comply fully with this specification unless otherwise approved by the contractor. Additionally, the work will be subject to continuous inspection by the inspector who will be at liberty to check at every stage that the work is being carried out in accordance with all aspects of this specification.

5.5) Prior to the commencement of work, the manufacturer shall submit for the approval of company, fully detailed procedure as to how he intends to carry out the work within the frame work of this specification & Document.

5.6) The equipment listed below shall be shielded to prevent: damage during surface preparation and painting operations. All opening, including those which are flanged or threaded. Shall be sealed to prevent entry of sand, dust, or coating materials

	RESIDUE HYDROTREATING PROJECT (RHU)			
	DOCUMENT TITLE: Surface Preparation and Painting Procedure		CON. NO.: PNA/73-98-1638	
	DOCUMENT NUMBER: VD-3607/32-00-4405-HE-PRC-0067		POI:	FA
		Rev. No:	5	

- Name plates and notices
- Packing glands
- Packing seal
- Pressure gauges
- Gauges glasses
- Instrument dials

5.7) All equipment which should be heat treated, shall be painted after heat treatment. Machined and threaded surfaces shall be protected with temporary rust preventative paint.

5.8) In case of any deviation between 3607-32-00-ED-PI-SP-8002 and current specification, Manufacturer shall write official letter to contractor for further clarification. The purchasing work cannot be done until obtaining contractor's reply.

6. Surface preparation

6.1) Paint life depends primarily on surface preparation. surface preparation should remove foreign bodies to allow the type of priming paint used to wet the surface thoroughly and develop adequate adhesion.

6.2) All rough-edged cuts & welds, weld spotters, indentations, all surfaces & protrusion must be ground to smooth out the contour before the surface is prepared for painting. Any grinding performed after blast cleaning, must be re-blast to required roughness.

6.3) All bolt holes shall be drilled and blunted before blasting.

6.4) Prior to surface preparation, the surface shall be inspected for spotting oil and grease deposits or pollution on the surface. If any, the deposits of oil or grease shall be removed from the surface by solvent cleaning prior to further surface preparation.

6.5) Required Cleanliness

All surfaces prepared for coatings shall satisfy:

- SA 2 1/2 for temperature up to 120 and SA 3 for above 120 °C according to Swedish Standard SIS 05 5900 or, SA 2 1/2: Near white blast cleaning

SA 3: White blast cleaning

6.6) Required Roughness

6.6.1) - All surfaces shall be blast cleaned to obtain a total angular roughness included:

- between 30 and 50 microns when total thickness of the coats of paint applied is less than 400 microns,
- between 50 and 80 microns when total thickness of the coats of the paint applied is greater than 400 microns.

6.6.2) The prepared surfaces should be cleaned using dry air or clean brush.

6.7) Surface preparation shall not take place in the following conditions:

a- At temperature below 10 °C

b- When the relative humidity is greater than 85%

If the air's relative humidity exceeds 80 %, the Applicator must obtain permission from the Company to proceed with or continue with surface preparation. The applicator must provide a hygrometer to measure the air's relative humidity.



c- When the metal surface temperature is less than 3 °C above the ambient dew point.

d- Paint material shall not be applied in rain, snow, fog or mist, nor to wet damp surfaces or to frosted or ice coated surfaces.

6.8) All abrasives shall be free of dust, dirt and other foreign matter. They shall be of a reusable type and to be kept dry at all times.

Abrasive material for blast cleaning, consisting solely of steel shot shall not be used. A mixture consisting of steel shot and at least 25% by weight steel grit is acceptable.

6.9) Chipping, scraping and steel wire brushing using manual or power-driven tools shall only be used where blast cleaning is impractical, with the approval of owner authorized inspector.

	RESIDUE HYDROTREATING PROJECT (RHU)			
	DOCUMENT TITLE: Surface Preparation and Painting Procedure		CON. NO.: PNA/73-98-1638	
			POI:	FA
DOCUMENT NUMBER: VD-3607/32-00-4405-HE-PRC-0067		Rev. No:	5	

7. Storage, mixing and thinning of products

7.1) STORAGE CONDITION

7.1.1)-All paints and thinner containers shall be kept closed before use and stored under shelter.

7.1.2)-The settlement of heavy paints shall be lessened by rolling the drums in which they are stored every six weeks. Turning the drums on their ends is not allowed. The normal finishing paints & drum paints do not require rolling during the storage period.

7.1.3)-Any paint for which the shelf life is expired shall not be used. The maximum storage time for paints shall be in accordance with manufacturer's recommendations. Paints shall not be stored in open containers, even for a short time.

7.1.4)-Paint shall be stored in a well-ventilated room, free from excessive heat or direct rays of the sun & maintained at a temperature of between 4 °C and 27 °C. Open air storage shall be avoided particularly of heavy paints such as primers and undercoats.

7.2) Mixing

7.2.1) Before opening the can, the paint should be checked if it complies with the specification.

7.2.2) Material inspection should be conducted on real paint, and when the vendor opens the can for the first time, the client's inspector should witness it as a rule. Client will inspect the batch.

7.2.3) Paint-can should be opened just before using as a rule: the paint-can once opened, should be securely closed for storage, and better finished early.

7.2.4) Any paint skin, which has formed in the container, shall be cut and removed, if the skin is thicker than 2 mm the paint shall not be used.

7.2.5) The paint in opened can should be stirred sufficiently until it becomes uniform. Up to 20 liters of paint should be stirred manually, and over 20 liters use a machine. No stirring is allowed with compressed air.

7.2.6) Special paints, such as "epoxy resin paint" and "zinc rich paint", which are supplied as two or more components in separate containers shall be mixed together immediately before their use. The mixed paints shall be applied within their pot life.

7.2.7) When thinner is necessary, unspecified thinner should not be used. Also, the amount should not be exceeded.

7.2.8) For color, it is necessary to use paints mixed to the specified color at the production plant.

7.3) Thinning

7.3.1) No thinners are to be added unless necessary for proper application, thinning must never exceed manufacture recommendations.

7.3.2) Thinners used must be those suggested by the manufacturer.

7.3.3) When use of thinner is authorized by the manufacture, it shall be added during mixing. Thinners must be added under the guidance of the specialist who is thoroughly familiar with the quantity and type of added thinner.

8. Priming

8.1) Prepared surface should be primed generally within four hours or before visible re-rusting occurs. Cleaned surface shall never be left overnight prior to coating, in such case re-blasting or re-cleaning is necessary.

8.2) In order to minimize contamination between successive coat of paint, over coating of the preceding coat shall be done as soon as it is permitted by the particular specification, and not delayed beyond the period specified.



8.3) The primer to finishing coat paint shall be from the same manufacturer for each system to ensure compatibility.

9. Painting application

9.1) Procurement and storage

The quantities of paint and thinners required to perform the entire job shall be procured before the work. The quantities of paint and thinners required to perform the entire job shall be procured before the work commences, except in cases where the shelf life of the product is less than the anticipated duration of the work.

Thinners, solvents, etc. shall be stored in a suitably ventilated fireproofed building, separate from other painting consumables.

	RESIDUE HYDROTREATING PROJECT (RHU)			
	DOCUMENT TITLE: Surface Preparation and Painting Procedure		CON. NO.: PNA/73-98-1638	
	DOCUMENT NUMBER: VD-3607/32-00-4405-HE-PRC-0067		POI:	FA
		Rev. No:	5	

The products shall be delivered in their original sealed packaging and stored in such conditions as to avoid their degradation. The packaging shall be clearly marked with the product description, the batch number, the fabrication date and the expiry date.

9.2) Application

9.2.1) General

Paint shall always be applied to surfaces that are dry, clean and degreased, for both coating on substrate and previous coat.

In the following cases, no painting work should be done as a rule.

- (1) Humidity: 85% or higher
- (2) Rainy weather
- (3) Temperature: below 5°C
- (4) Strong wind and severe sand dust
- (5) Painted surface temperature: 35 °C or higher
- (6) When the temperature of the surface is less than 3°C above the dew point of the surrounding air, and/ or the relative humidity is higher than 80%
- (7) When there is the likelihood of an unfavorable change in weather conditions within two hours after coating vendor shall keep a daily record of the dew point, relative humidity, ambient atmosphere and substrate temperatures (all measured before the work commences and twice per shift and when ambient conditions are obviously changing) to ensure that conditions are acceptable. These records shall be kept and made available to COMPANY. Application shall be by airless spray

10. Galvanizing



10.1) Hot -dip galvanizing shall be in accordance with ASTM A123 on products fabricated from rolled, pressed and forged steel snaps, plates, bars and strips except that pipes for hand railing shall meet ASTM A-153. INSPECTION

11. Inspection

- 11.1) Vendor shall advise the owner inspector before commencing specific paint applications.
- 11.2) Inspector shall have the right to inspect the paint work at all stages and to reject any and all tools, instruments, material, staging or equipment of work which do not conform to the specification.
- 11.3) Each coat paint shall be free from defects and damage. Finished paint shall have the correct shade, degree of gloss and evens and be free from tackiness after drying/curing and from cracks, holidays, runs, sags, wrinkles, patchiness brush or roller marks or any defects that may be deleterious to the quality of the coating.
- 11.4) Prior to final acceptance of completed work, a joint inspection shall be made by vendor and owner inspector and an agreed inspection report to be signed by both parties.
- 11.5) Inspection by the paint manufacture or an independent inspection service shall not relieve the vendor of responsibility for ensuring that the work is carried out in accordance with the specification.
- 11.6) Before commencement of shop preparation and painting, a meeting between the coating manufacturer, vendor and company's representative shall be convened, to establish and agree, when necessary, visible blast standard, blast profile, satisfactory application the coating and agreement and calibration of inspection equipment.
- 11.7) Each coat shall be inspected prior to application of the next coat, Areas found to contain runs, over spray, roughness, cracks or other signs of improper application shall be repaired or recoated in accordance with the authorized inspector recommendation.

12. Quality control and testing

- 12.1) Vendor shall submit his proposed quality control and testing procedures covering all phases of surface preparation and paint application to company for approval.
- 12.2) Manufacturers of all materials shall supply test certificates of all tests performed and certificate of compliance stating that the material meets the requirements of the applicable specification.

	RESIDUE HYDROTREATING PROJECT (RHU)			
	DOCUMENT TITLE: Surface Preparation and Painting Procedure		CON. NO.: PNA/73-98-1638	
			POI:	FA
DOCUMENT NUMBER: VD-3607/32-00-4405-HE-PRC-0067		Rev. No:	5	

12.3) Before paint application the prepared surface shall be inspected visually by Quality Control Inspector and if the result is satisfactory the parts can be released for painting.

12.4) After paint application following test shall be performed by Quality Control Departments:

- Visual check
- Thickness check
- Adhesion test

12.5) Visual Check

Coating film should be inspected visually after each application, before application and before application of the next coat in order to verify that the whole surface is free of defect as:

- Mud cracking
- Inclusion and cleanliness
- Holidays
- Bubble
- Mechanical damage
- Runs/Sags
- Over spray

12.6) Thickness Check

the minimal allowable thickness shall be at least 80% of the specified thickness, the maximum thickness shall not exceed 150% of the specified thickness unless the paint remained soft or shows mud crack or orange skin or wrinkling pinhole and inter coating delamination which cause rejection of the paint.

Dry film thickness measuring procedure:

(1) Checking equipment:

Micro tester

Electromagnetic film thickness gauge

(2) Checking procedure:

For paint coat accepted in dry-state test, thickness of specified number of coats should be measured in specified places separately. For measuring, the electromagnetic film thickness gauge should be used where applicable. When it is, however, difficult to measure in specific measurement conditions or installation conditions, a micro tester may be used. In any case, the same measuring instrument should be used in the whole process as a rule.

(3) Checking process and period

The paint coat should be measured when the coating film is in dry-hard state after completion of the undercoating and the final coating.

(4) Judgment method

It should be judged whether the measured film thickness is same to specified film thickness.

(5) Criterion

The average specified film thickness should be obtained.

- On each spot, make 5 measurements by moving the probe a short distance for each new gage reading. Take the average of the five gages reading as the spot measurement. Each coat thickness and total thickness shall be checked. Make five separate spot measurements spaced evenly over each section of the structure 10 m2 in area.

NOTE: Average of spot measurements \geq specified DFT

All individual measurements \geq 90% of specified DFT

12.7) Adherence Check

Adhesion test shall be performed according to ASTM D4541 or ASTM D3359.



12.8) Inspection Results

All quality control results shall be written up into reports.

All reports shall be submitted to the authorized inspector for approval.

13. Repair of Defects or Damage

Touch up work on damaged surfaces:

	RESIDUE HYDROTREATING PROJECT (RHU)			
	DOCUMENT TITLE: Surface Preparation and Painting Procedure		CON. NO.: PNA/73-98-1638	
			POI:	FA
DOCUMENT NUMBER: VD-3607/32-00-4405-HE-PRC-0067		Rev. No:	5	

Surface is damaged as substrate material is seen:

The surfaces shall then be prepared to the standard as originally specified (for large damaged areas), or prepared to the highest possible standard using mechanically operated tools (for small local damaged spots up to 1 square meter

After surface preparation, primer layer is applied and after considering required interval for recoating, top coat will be executed.

(2) Surface is scratched:

At first, all oil and grease shall be removed from the surface then top coat will be applied.

(3) Damaged surface touching up could be done with paint brush for small surfaces and spray for large surfaces (in this case, surrounding of damaged surfaces shall be covered to prevent from contacting with intact surfaces).

Where touching up prior to top coating of zinc-based primers is involved, this shall be preceded by thorough cleaning with solvent or an emulsion type cleaner or remove all oil and grease. This shall be followed by thoroughly hosing down with clean potable water which in the case of surfaces that have not been tie coated shall be carried out in conjunction with manual scrubbing with stiff brushes in order to remove all surface dirt and other contaminants, zinc corrosion products (with rust) etc.

14. Paint system

14.1) Organic zinc rich primer two components epoxy based zinc rich primer. The metallic zinc content is a minimum 80% by weight of total solids & provides sacrificial protection & high anti-corrosive stability to steel surfaces. Continuous heat resistance is achieved in the temperature range up to 150 °C.



Epoxy: Two component polyamide cured epoxy paint. Generally, it has good resistance to chemicals & exhibits good durability. Continuous heat resistance is achieved in the temperature range up to plus 120 °C.

Polyurethane: Two component isocyanate-free, aliphatic type polyurethane top coat. Generally, this paint product extremely hard & good chemical, weather resistance & excellent durability & gloss retention.

14.2) Paint system applicable shall be in accordance with A.

15. Painting reports

See Attachment 1.

	RESIDUE HYDROTREATING PROJECT (RHU)			
	DOCUMENT TITLE: Surface Preparation and Painting Procedure		CON. NO.: PNA/73-98-1638	
			POI:	FA
DOCUMENT NUMBER: VD-3607/32-00-4405-HE-PRC-0067		Rev. No:	5	

<i>Item No.</i>	<i>Material</i>	<i>Operating Temperature (°C)</i>	<i>Paint System</i>
E-74101 (Header box)	Incoloy UNS N08825	117	NA
E-74201 (Header box)	Incoloy UNS N08825	117	NA
Steel Structures (un-fireproof)	Carbon Steel	Ambient	A
Steel Structures (fireproof)	Carbon Steel	Ambient	B
Side Frame, Louver	Carbon Steel	Ambient	C
Plenum and fan ring, Grating	Carbon Steel	Ambient	Hot dip galvanized
Steam Coil	Carbon Steel	190	D

Side Frame DWG: VD-360732-74-4405-HE-DWG-0029&0030

Steel Structure DWG: VD-3607-32-74-4405-HE-DWG-0031&0032

Paint System: A

Item: Steel Structures (un-fireproof)			Operating Temperature:	Up to 120 °C
Minimum surface preparation				SA 2 1/2
Paint and DFT (microns)	Primer	Zinc-rich epoxy		75
	Intermediate	Epoxy polyamide		150
	Finishing	Two-pack polyurethane		50
Total DFT (microns)				275
Finishing RAL	Hand Rail (Toe plate and mid-rail, Post), safety gate, Safety Cage			2003, Orange
	Hand Rail (top rail & Post), ladder			9005, Black
	Bearing Block, Motor Support, Main Steel Structure			1011, Brown beige



5

Paint System: B

Item: Steel Structures (fireproof)			Operating Temperature:	Up to 120 °C
Minimum surface preparation				SA 2 1/2
Paint and DFT (microns)	Primer	Zinc Rich Epoxy		75
	Intermediate	-		-
	Finishing	-		-
Total DFT (microns)				75
Finishing RAL	Main Steel Structure (Column, Brace ,Beam)			-

Paint System: C*

Item: Side Frame, Louver			Operating Temperature:	Up to 120 °C
Minimum surface preparation				SA 2 1/2
Paint and DFT (microns)	Primer	Polyamide Cured Epoxy Primer		75
	Intermediate	Epoxy Polyamide		150
	Finishing	Two Pack Polyurethane		50
Total DFT (microns)				275
Finishing RAL				9010



	RESIDUE HYDROTREATING PROJECT (RHU)			
	DOCUMENT TITLE: Surface Preparation and Painting Procedure		CON. NO.: PNA/73-98-1638	
			POI:	FA
DOCUMENT NUMBER: VD-3607/32-00-4405-HE-PRC-0067		Rev. No:	5	

Paint System: D

Item: Steam Coil		Operating Temperature: 121 °C to 200 °C	
Minimum surface preparation			SA 2 1/2
Paint and DFT (microns)	Primer	Zinc Silicate (IPS-M-TP-205)	75
	Intermediate	Silicon Acrylic (IPS-M-TP-168)	25
	Finishing	Silicon Acrylic (IPS-M-TP-168)	25
Total DFT (microns)			125
Finishing RAL			9006

*According to API 661 Galvanized materials or zinc-containing paints, etc., shall not be used in direct contact with or directly above exposed austenitic stainless steel or high-nickel alloy pressure components.

Note: Please refer to the attached files for paint data sheets.

	RESIDUE HYDROTREATING PROJECT (RHU)			
	DOCUMENT TITLE: Surface Preparation and Painting Procedure		CON. NO.: PNA/73-98-1638	
	DOCUMENT NUMBER: VD-3607/32-00-4405-HE-PRC-0067		POI:	FA
		Rev. No:	5	

Attachment

	Quality Control		Report No.:
	Painting Report		Date Of Exam. :

PROCEDURE No. :
DOCUMENT NO. :
SAND BLAST : **TOTAL**
PRIMER : **THK :**
INTERMEDIATE : **THK :**
FINISHING : **THK :**
FINISH COLOR :
Temperature : **Humidity :** **Dew point temp :**

ITEM NO:

SR. No.	Description	THK(mic)	Result	Date	TIME	Curing & adhesion
1	Sand Blast					
2	Primer					
3	Intermediate					
4	Finish					

Note:

Inspector	A.A.C Inspector	Purchaser	TPI Inspector
NAME & SIGNATURE			
Qualification			
DATE			