









GENERATOR HARMONIC DASHBOARD

Turbine #1	
Voltage	10426.63 V
THD Voltage Phase R-S	1.05 %
THD Voltage Phase S-T	1.02 %
THD Voltage Phase R-T	1.17 %
Current	403.43 A
THD Current Phase R	0.89 %
THD Current Phase S	0.91 %
THD Current Phase T	0.97 %
Load	7151.59 kW
Reactive Power (kVAR)	1388.89 kW

Turbine #2	
Voltage	10402.62 V
THD Voltage Phase R-S	1.02 %
THD Voltage Phase S-T	0.99 %
THD Voltage Phase R-T	1.07 %
Current	389.14 A
THD Current Phase R	0.97 %
THD Current Phase S	0.97 %
THD Current Phase T	1.03 %
Load	6956.31 kW
Reactive Power (kVAR)	872.23 kW

Turbine #3	
Voltage	10548.17 V
THD Voltage Phase R-S	1.01 %
THD Voltage Phase S-T	0.97 %
THD Voltage Phase R-T	1.07 %
Current	400.27 A
THD Current Phase R	0.92 %
THD Current Phase S	0.88 %
THD Current Phase T	0.94 %
Load	7194.41 kW
Reactive Power (kVAR)	1309.52 kW

Real Time Data



Spectrum Data

