Sr.No.			Logic
1	Date		received date
2	Structure application		extract from doc/ mail / attachement
3	Proposal Id		if mail is there should be extract from subject line neither from attachment
4	Building No.	1	default to 1
5	Option	1	
6	Revision	0	
7	Area (sqm)	0	calculate using dimensions given L * W * H
8	Design Software	MBS	by default MBS
Sr.No.	**Parameter**	**Details**	
1	Building type	Clear Span	as mentioned by client, introduce interior columns for spans greater than 30m
2	Length in m (o/o of steel)		given by clients (should be in meters). Convert to meters if the dimensions are in ft or inch
3	Width in m (o/o of steel)		
4	Left eave height in m		If client gives clear height then extract it directly. For clear height assume depth of rafter + 200mm purlin depth
5	Right eave height in m		
6	Ridge line distance	0	Span / 2 for most of the PEB structures. The distance should be calculated from the backside wall
7	Roof slope (?:100)	10/100	bydefault 10/100 , may vary as per client requirements
8	Left end wall bay spacing in m		Create rule in master database
9	Right end wall bay spacing in m	0	
10	Side wall bay spacing		
11	Wall bracing type	Rod	Consider rod by default if not mentioned in client documents. If its mentioned then extract the value
12	Roof bracing type	Rod	
13	Roof sheeting	0.45mm aluzinc	should be in mm , by default 0.45 mm.If its mentioned in client documents then extract the value
14	Wall sheeting	0.45mm aluzinc	
15	Doors	3x3	use default - 3x3 if not specified by the client
16	Windows		as per client requirements, skip if not specifically mentioned
17	Block wall in m		consider 3m by default if not specified
18	Rigid frames interior column locations		Divide equally if not mentioned. For e.g: 35m MS 1 should have interior column at center i.e. 17.5m
Sr no.	**Item**	**Details**	
1	Canopy Extension in m		Canopy width as per docuemnts, skip if not mentioned specifically
2	Slope	10/100	bydefault 10/100 , may vary as per client requirements
3	Clear top height in m		Always 500mm above the door
Sr no.	Accessories		
1	Braced bays (Bay id)		Maximum distance between 2 braced bay should be 40m & not more than 5 bays
2	Skylights (FRP 3.25m x 1m)		Consider 2/bay for spans between 15 to 30m, 4/bay above 30m span
3	Turbo Ventilators (600 mm throat diameter)		Consider 2/bay for spans between 15 to 30m, 4/bay above 30m span
4	Base Elevation		As mentioned by client
5	Bay Id @ Left end wall (Doors/windows)	NA	
6	Bay Id @ Front side wall (Doors/windows)	NA	
7	Bay Id @ Right end wall (Doors/windows)	NA	
8	Bay Id @ Back side wall (Doors/windows)	NA	

Sr no.	Parameter	Details	Logic
1	Desing code	AISC code	AISC by default if not specifically mentioned
1	Dead Load in kN/m2	0.1	AISC=0.1, I=:0.15 if not specifically mentioned
2	Live Load in kN/m2	0.57	AISC=0.57, I=:0.75 if not specifically mentioned
3	Collateral load kN/m2	0	0 by default if not specifically mentioned
4	Max wind speed in m/s	39	Refer wind map data
5	Max rainfall intensity in mm/hr	150	Refer wind map data
6	Exposure category	B	B by default if not specifically mentioned
7	Seismic zone co-efficient (III)	0.16	Refer wind map data
8	Maximum temperate variation	20	20 by default
Sr no.	**Parameter**	**Details**	Refer AISC & IS code values
1	Frames Vertical deflection	Span/150	Refer AISC & IS code values
2	Frames Horizontal deflection	Height/100	Refer AISC & IS code values
3	Purlins	Span/150	Refer AISC & IS code values
4	Girts	Span/120	Refer AISC & IS code values
5	Crane beams	Span/600	Refer AISC & IS code values
6	Mezzanine beams	Span/240	Refer AISC & IS code values
7	Misc		
Sr no.	**Assumption/Remark**	**Details**	
1	Hot rolled sections grade (Mpa)	250	250 by default
2	Cold form sections grade (Mpa)	350	350 by default if not specifically mentioned
3	Primary sections grade (Mpa)	350	350 by default if not specifically mentioned
4	Building design condition	Enclosed	Create rule in master database
4	Minimum web thickness in mm	4	4 by default if not specifically mentioned
5	Minimum flange thickness in mm	5	5 by default if not specifically mentioned
6	Minimum flange width in mm	125	125 by default if not specifically mentioned
7	Minimum web depth in mm	250	250 by default if not specifically mentioned
8	Minimum cold form thickness in mm	1.5	1.5 by default if not specifically mentioned
9	Sheeting profile width & length in m	1.22 & 7.65	1.22 & 7.65 by default if not specifically mentioned
10	Connection bolts grade	High strength bolts (ASTM A325 or equivalent)	High strength bolts (ASTM A325 or equivalent) by default if not specifically mentioned