

OUTLINE SPECIFICATIONS

Date	24 November 2025	Client					Project Location	Ghana																																					
Proposal Id	Q-1392	Project	Parking Structure				Building No.	1	Option	1	Revision	3																																	
Sr.No.	Description	PEB SPECIFICATIONS																																											
1.	Building type	Mezzanine Building				Area in m²		3740																																					
2.	Length in m (c/c of steel)	Ref.Dwg				Length wise bay spacing		Ref.Dwg																																					
3.	Width in m (c/c of steel)	Ref.Dwg				End wall column spacing		Ref.Dwg																																					
4.	Width modules in m	Ref.Dwg				No. of interior columns per frame		0																																					
5.	Clear height in m	Ref.Dwg				Frames symmetrical		Yes																																					
6.	Roof	Slope: NA		Cladding: NA				Rainwater drainage: Eave Gutters and Down spouts																																					
7.	Future Expansion	NA																																											
8.	Block Wall	NA																																											
9.	Column base elevations	NA (At FFL)																																											
10.	Wall Cladding	NA																																											
11.	Insulation	Roof: NA				Outer Walls: NA				Partition walls: NA																																			
12.	Openings	<table><tr><td>Outer side only</td><td colspan="4">Numbers</td><td colspan="3">Type</td><td colspan="3">Size in m (w x h)</td></tr><tr><td>Doors</td><td colspan="4">NA</td><td colspan="3">NA</td><td colspan="3">NA</td></tr><tr><td>Windows</td><td colspan="4">NA</td><td colspan="3">NA</td><td colspan="3">NA</td></tr></table>											Outer side only	Numbers				Type			Size in m (w x h)			Doors	NA				NA			NA			Windows	NA				NA			NA		
		Outer side only	Numbers				Type			Size in m (w x h)																																			
		Doors	NA				NA			NA																																			
		Windows	NA				NA			NA																																			
		Location of doors & bracing																																											
		Side Wall Gridlines	1-2	2-3	3-4	4-5	5-6	6-7	7-8	8-9	9-10	10-11	11-12	Right End Wall																															
		Front Side Wall		XP				XP				XP																																	
		Back Side Wall		XP				XP				XP																																	
		End Wall Axes		A-B	B-C	C-D	D-E	E-F	F-G	G-H	H-I	Back Side Wall																																	
		Right End Wall																																											
		Left End Wall																																											
		13.	Extensions	Eave: NA	Gable: NA	Canopies:								Parapet: NA																															
Extension in m: NA						Location: NA																																							
Clear height in m: NA						Rainwater drainage: NA																																							
Slope: NA						Soffit panels: NA																																							
14.	Accessories	Wall Lights:		NA						Roof Monitor		NA	Any other: NA																																
		Skylights:		NA						Cage ladder		NA																																	
		Turbo Ventilators:		NA						Ridge Ventilators:		NA																																	
15.	For Frames (Standard codes and manuals used in design - 2010 Metal Building Systems Manual,	DESIGN LOADS			LOCATION - CLIMATIC DATA					SERVICEBILITY CRITERIA																																			
		Dead Load in kN/m²		0.10	Max wind speed in m/s			36.11	Frames		H/100, L/150																																		
		Live Load in kN/m²		0.575	Exposure category			B	Purlins		Span/150																																		
		Collateral load in kN/m²		0.05	Max rainfall intensity in mm/hr.			150	Girts		Span/120																																		
		Any other		NA	Seismic Design category (Coefficient)			II (0.33)	Crane Beams		Span/600																																		

	NAUS07, AISC05, UBC 1997) Design Software: MBS			Max Temperature variation in °C	20	Mezzanine Beams	Span/240
16.	Mezzanine	Location: Ref.Dwg. Loading: Live load in kN/m²: 5 Dead load in kN/m²: 2.5 Collateral load in kN/m²: 0		Dimensions: Length in m: Ref.Dwg. Width in m: Ref.Dwg. Top of the Mezzanine Floor in m: Ref.Dwg. Depth of mezzanine slab in mm: 100 Deck sheeting thickness: 0.7mm		Accessories: Staircase Nos.: 2 Location: Ref.Dwg. Type: Double staircase with intermediate landing Handrail: All round	
17.	Partition Walls	NA					
18.	Jack Beam	NA					
19.	Assumptions & Remarks	Built-up sections are made from hot rolled plates conforming to ASTM A-572 Gr50 (345MPa) steel. The plates are joined together with double side welding. Sections consist of minimum 5mm for flange & minimum 4mm for web thickness. Cold formed sections thickness 1.5 mm or more are made of hot rolled sheet of Gr50 (345 MPa) steel. Primary structural connections are high strength machine bolts conforming to ASTM A325 or equivalent. Sheeting profile considered is of 1 m standard width, formed from a coil of 1.220 m. Single colour sheeting of up to maximum 9 m lengths is considered. Not considered in scope: Foundation, Block wall (Civil work). Crane Bridge, Trolley, Rail and its installation.					