

# CERTIFICATE OF CONFORMITY

This Certificate is issued to

**INDUSTRIAL LINKS INTERNATIONAL PTE LTD**

**(UEN No.: 201310098N)**

**22 Woodlands Walk, Singapore 738390**

**For Product Certification Scheme: Type 2**

**Product : Thermal Insulation Material**

**Brand : Pete-Flex Flexible Duct**

**Model : Pete-Flex Flexible Duct**

**Country of Origin : Malaysia**

**Product Details : Aluminium flexible duct with spring wire insulated with glasswool and external aluminium foil.**  
**Mass per unit area: 1.05 kg/m<sup>2</sup>**  
**Fire Classification: Class 0**

which has complied with the requirements of the scheme based on the following:

## STANDARD(S)

BS 476 Part 6: 1989 + A1: 2009

BS 476 Part 7: 1997

## TEST REPORT(S)

SIRIM QAS Test Report No.: 2023FE0438

SIRIM QAS Test Report No.: 2023FE0439

**Detailed configuration and installation shall be referenced to the certified report(s) stated above.**



**Fiona Leong (Ms)**  
Program Manager  
SETSCO Services Pte Ltd  
531 Bukit Batok Street 23  
Singapore 659547

**Certificate No**

**FSP-2023-1419**

**Date of Issue**

**29/09/2023**

**Date of Expiry**

**28/09/2028**

This Certificate is part of full report and should be read in conjunction with it. This Certificate remains the property of SETSCO Services Pte Ltd (SETSCO) and shall be returned upon request. The use of this Certificate is subjected to the terms and conditions of the SETSCO Product Certification Scheme. The manufacturer is solely responsible for the compliance of any product that has the same designation as the product type-tested. Persons relying on this Certificate should verify its validity by checking it at [www.setsco.com](http://www.setsco.com)

The use of the SAC accreditation mark indicates accreditation in respect of those activities covered by the accreditation certificate number PD-2010-10.