



PSB Singapore

CERTIFICATE OF CONFORMITY

No. CLS1B 080936 0017 Rev. 01

Initial No. CLS1B 080936 0017 Rev. 00

Certificate Holder:

Wong Brothers Pte Ltd
7 Toa Payoh Industrial Park #01-1245
Singapore 319059
SINGAPORE

UEN - 200002094H

Certification Mark:



Product:

Fire Dampers

Brand Name:

WB AIR

Model(s):

WB-FD (H)

Product Details:

Integrity: 240mins

Galvanised steel curtain type horizontal single module fire damper of 980mm (L) x 1000mm (W) mounted on concrete floor
Max size for single module: 1150mm (L) x 1026mm (W) or 1047mm (L) x 1127mm (W) subject to total area not exceeding 1.18m²

Standard(s):

SS 333:2012 CI 6.3, 6.4, 6.5 & 6.6

Country of Origin:

Singapore

Test Report(s):

7191302655-MEC23-CCN, 7191311363-MEC23-FA, PSB Assess
7191314093-MEC23-MW

Valid until:

2028-07-26

Products listed under Class 1B must have TÜV SÜD PSB PLS mark as shown above affixed/printed on them. Failure to comply with this requirement may result in revocation of this certificate.

Page 1 of 2

Issued on: 2023-10-25

Vice-President (Certification Department)
TÜV SÜD PSB



This Certificate is the property of TÜV SÜD PSB Pte Ltd. Reports listed in this certificate is an integral part of the certificate and should be read in conjunction with it. The use of this Certificate is subjected to TÜV SÜD Group Testing and Certification Regulations; TÜV SÜD PSB Pte Ltd (PSB) General Terms and Conditions of Business and PSB Product Listing Scheme (PLS) Application Fact Sheet. The manufacturer is solely responsible for compliance of any product that has the same designation as the product type-tested. Persons relying on this Certificate should verify its validity by checking the e-directory: www.tuvsud.com/ps-cert. For more information on TÜV SÜD PSB Pte Ltd product certification: www.tuvsud.com/sg



PSB Singapore

CERTIFICATE OF CONFORMITY

No. CLS1B 080936 0017 Rev. 01

Initial No. CLS1B 080936 0017 Rev. 00

Replacement History:

Predecessor Certificate (Issue Date)
CLS1B 080936 0017 Rev. 00 (2023-10-04)

Page 2 of 2

Issued on: 2023-10-25

Vice-President (Certification Department)
TÜV SÜD PSB



This Certificate is the property of TÜV SÜD PSB Pte Ltd. Reports listed in this certificate is an integral part of the certificate and should be read in conjunction with it. The use of this Certificate is subjected to TÜV SÜD Group Testing and Certification Regulations; TÜV SÜD PSB Pte Ltd (PSB) General Terms and Conditions of Business and PSB Product Listing Scheme (PLS) Application Fact Sheet. The manufacturer is solely responsible for compliance of any product that has the same designation as the product type-tested. Persons relying on this Certificate should verify its validity by checking the e-directory: www.tuvsud.com/ps-cert. For more information on TÜV SÜD PSB Pte Ltd product certification: www.tuvsud.com/sg



PSB Singapore

CERTIFICATE OF CONFORMITY

No. CLS1B 080936 0015 Rev. 00

Initial No. -

Certificate Holder:

Wong Brothers Pte Ltd
7 Toa Payoh Industrial Park #01-1245
Singapore 319059
SINGAPORE

UEN - 200002094H

Certification Mark:



Product:

Fire Dampers

Brand Name:

WB AIR

Model(s):

WB-FD (V)

Product Details:

Integrity: 240mins

Galvanised steel curtain type vertical fire damper mounted on masonry wall

Max Size for single module : 1373mm (w) x 1254mm (h) or 1254mm (w) x 1373mm (h);

Max Size for multiple modules: 3000mm (w) x 3000mm (h) for 3(w) x 3(h) modules

Standard(s):

SS 333:2022 CI 6.3, 6.4 & 6.5

Country of Origin:

Singapore

Test Report(s):

Refer to following page(s)

Valid until:

2027-10-21

Products listed under Class 1B must have TÜV SÜD PSB PLS mark as shown above affixed/printed on them. Failure to comply with this requirement may result in revocation of this certificate.

Page 1 of 2

Issued on: 2023-02-10

Vice-President (Certification Department)
TÜV SÜD PSB



This Certificate is the property of TÜV SÜD PSB Pte Ltd. Reports listed in this certificate is an integral part of the certificate and should be read in conjunction with it. The use of this Certificate is subjected to TÜV SÜD Group Testing and Certification Regulations; TÜV SÜD PSB Pte Ltd (PSB) General Terms and Conditions of Business and PSB Product Listing Scheme (PLS) Application Fact Sheet. The manufacturer is solely responsible for compliance of any product that has the same designation as the product type-tested. Persons relying on this Certificate should verify its validity by checking the e-directory: www.tuvsud.com/ps-cert. For more information on TÜV SÜD PSB Pte Ltd product certification: www.tuv-sud-psb.sg



PSB Singapore

CERTIFICATE OF CONFORMITY

No. CLS1B 080936 0015 Rev. 00

Initial No. -

Test Report(s):

7191282921-MEC22-LC, 7191288815-MEC22/01A-DA, 7191280431-MEC22/03-LCM

PSB Supplemental 7191282921, PSB Supplementary 7191288815-MEC22/01A-DA, PSB

Supplementary 7191280431-MEC22/03-LCM

PSB Assess 7191295534-MEC22-JC

Page 2 of 2

Issued on: 2023-02-10

Vice-President (Certification Department)
TÜV SÜD PSB



This Certificate is the property of TÜV SÜD PSB Pte Ltd. Reports listed in this certificate is an integral part of the certificate and should be read in conjunction with it. The use of this Certificate is subjected to TÜV SÜD Group Testing and Certification Regulations; TÜV SÜD PSB Pte Ltd (PSB) General Terms and Conditions of Business and PSB Product Listing Scheme (PLS) Application Fact Sheet. The manufacturer is solely responsible for compliance of any product that has the same designation as the product type-tested. Persons relying on this Certificate should verify its validity by checking the e-directory: www.tuvsud.com/ps-cert. For more information on TÜV SÜD PSB Pte Ltd product certification: www.tuv-sud-psb.sg