

Device Details

Project : **DB CAMP**

Page 1

Panel: **10** Name: **BLK 2 SUB ALARM PANEL - 010**

Type : **ZP3 EN54 1 Loop/128 Zone**

Panel: **10** Line: **1**

Addr	Device Type	Zone	Device Message	Sensitivity		Sensitivity		Disable (Pri)	Disable (Sec)	Base Sounder	AVF	Self Test	Radio Sndr Group
1001	Callpoint ZP785	1	BLK2 1STY Z1-1 LIFT LOBBY - MCP	Standard				Enabled		No	Off	No	
1002	Callpoint ZP785	1	BLK2 1STY Z1-2 CORRIDOR NEAR HR - MCP	Standard				Enabled		No	Off	No	0
1003	Callpoint ZP785	1	BLK2 1STY Z1-3 CORRIDOR NEAR HR - MCP	Standard				Enabled		No	Off	No	0
1004	Callpoint ZP785	1	BLK2 1STY Z1-4 CORRIDOR NEAR HR - MCP	Standard				Enabled		No	Off	No	0
1005	Optical Smoke ZP730	1	BLK2 1STY Z1-5 LT SWITCH ROOM - SD	Standard				Enabled		No	Off	No	
1006	Optical Smoke ZP730	1	BLK2 1STY Z1-6 NCR ROOM(#01-02) - SD	Standard				Enabled		No	Off	No	0
1007	Optical Smoke ZP730	1	BLK2 1STY Z1-7 NCR ROOM(#01-03) - SD	Standard				Enabled		No	Off	No	0
1008	Optical Smoke ZP730	1	BLK2 1STY Z1-8 NCR ROOM(#01-05) - SD	Standard				Enabled		No	Off	No	0
1009	Optical Smoke ZP730	1	BLK2 1STY Z1-9 NCR ROOM(#01-06) - SD	Standard				Enabled		No	Off	No	0
1010	Heat ZP720-3	1	BLK2 1STY Z10 A RISER - HD	2: 58C RR				Enabled		No	Off	No	
1011	Optical Smoke ZP730	1	BLK2 1STY Z1-11 OT RISER - SD	Standard				Enabled		No	Off	No	0
1012	Optical Smoke ZP730	1	BLK2 1STY Z1-12 TEL RISER - SD	Standard				Enabled		No	Off	No	0
1013	Optical Smoke ZP730	1	BLK2 1STY Z1-13 UC-COMMS RISER - SD	Standard				Enabled		No	Off	No	0
1014	Optical Smoke ZP730	1	BLK2 1STY Z1-14 C-COMMS RISER - SD	Standard				Enabled		No	Off	No	0
1015	Optical Smoke ZP730	1	BLK2 1STY Z1-15 S-COMMS RISER - SD	Standard				Enabled		No	Off	No	0
1016	Heat ZP720-3	1	BLK2 1STY Z16 LIFT LOBBY - HD	2: 58C RR				Enabled		No	Off	No	0
1017	Optical Smoke ZP730	1	BLK2 1STY Z1-17 ELECT RISER - SD	Standard				Enabled		No	Off	No	0
1018	Emulated Fire	1	BLK2 1STY Z1-18 OT SERVER ROOM (FIRE)	Standard				Enabled		No	Off	No	
1019	Emulated Security Latch	1	BLK 2 1STY Z1-10 OT SERVER RM (FAULT)	Standard				Enabled					
1020	Emulated Fire	1	BLK2 1STY Z1-19 BATTERY ROOM (FIRE)	Standard				Enabled		No	Off	No	0
1021	Emulated Security Latch	1	BLK2 1STY Z1-19 BATTERY ROOM (FAULT)	Standard				Enabled					0
1022	Emulated Fire	1	BLK2 1STY Z1-20 NRC(S) RM (FIRE)	Standard				Enabled		No	Off	No	0
1023	Emulated Security Latch	1	BLK2 1STY Z1-20 NRC(S) RM (FAULT)	Standard				Enabled					0
1024	Emulated Sprinkler	1	BLK2 1STY Z1-21 FLOWSWITCH - IF	Standard				Enabled		No	Off	No	
1028	Optical Smoke ZP730	1	BLK2 1STY Z1-22 COMM RISER - SD	Standard				Enabled		No	Off	No	0
1029	Optical Smoke ZP730	1	BLK2 1STY Z1-23 COMM RISER - SD	Standard				Enabled		No	Off	No	0
1030	Callpoint ZP785	2	BLK2 2STY Z2-1 CORRIDOR NEAR HR - MCP	Standard				Enabled		No	Off	No	0
1031	Callpoint ZP785	2	BLK2 2STY Z2-2 CORRIDOR NEAR HR - MCP	Standard				Enabled		No	Off	No	0
1032	Callpoint ZP785	2	BLK2 2STY Z2-3 CORRIDOR NEAR HR - MCP	Standard				Enabled		No	Off	No	0
1033	Callpoint ZP785	2	BLK2 2STY Z2-4 CORRIDOR NEAR HR - MCP	Standard				Enabled		No	Off	No	0
1034	Heat ZP720-3	2	BLK2 2STY Z2-5 A RISER - HD	2: 58C RR				Enabled		No	Off	No	
1035	Optical Smoke ZP730	2	BLK2 2STY Z2-6 OT RISER - SD	Standard				Enabled		No	Off	No	

Device Details

Project : **DB CAMP**

Page 2

Panel:10 **Line: 1** (Continued from Page 1)

Addr	Device Type	Zone	Device Message	Sensitivity		Sensitivity		Disable (Pri)	Disable (Sec)	Base Sounder	AVF	Self Test	Radio Sndr Group
1036	Optical Smoke ZP730	2	BLK2 2STY Z2-7 TEL RISER - SD	Standard				Enabled		No	Off	No	0
1037	Optical Smoke ZP730	2	BLK2 2STY Z2-8 ELECT RISER 1 - SD	Standard				Enabled		No	Off	No	0
1038	Optical Smoke ZP730	2	BLK2 2STY Z2-9 UC-COMMS RISER - SD	Standard				Enabled		No	Off	No	0
1039	Optical Smoke ZP730	2	BLK2 2STY Z2-10 C-COMMS RISER - SD	Standard				Enabled		No	Off	No	0
1040	Optical Smoke ZP730	2	BLK2 2STY Z2-11 S-COMMS RISER - SD	Standard				Enabled		No	Off	No	0
1041	Heat ZP720-3	2	BLK2 2STY Z2-12 LIFT LOBBY - HD	2: 58C RR				Enabled		No	Off	No	0
1042	Optical Smoke ZP730	2	BLK2 2STY Z2-13 ELECT RISER 2 - SD	Standard				Enabled		No	Off	No	0
1043	Emulated Sprinkler	2	BLK2 2STY Z2-14 FLOWSWITCH - IF	Standard				Enabled		No	Off	No	
1044	Callpoint ZP785	3	BLK2 3STY Z3-1 CORRIDOR NEAR HR - MCP	Standard				Enabled		No	Off	No	0
1045	Callpoint ZP785	3	BLK2 3STY Z3-2 CORRIDOR NEAR HR - MCP	Standard				Enabled		No	Off	No	0
1046	Callpoint ZP785	3	BLK2 3STY Z3-3 CORRIDOR NEAR HR - MCP	Standard				Enabled		No	Off	No	0
1047	Callpoint ZP785	3	BLK2 3STY Z3-4 CORRIDOR NEAR HR - MCP	Standard				Enabled		No	Off	No	0
1048	Heat ZP720-3	3	BLK2 3STY Z3-5 A RISER - HD	2: 58C RR				Enabled		No	Off	No	0
1049	Optical Smoke ZP730	3	BLK2 3STY Z3-6 OT RISER - SD	Standard				Enabled		No	Off	No	0
1050	Optical Smoke ZP730	3	BLK2 3STY Z3-7 TEL RISER - SD	Standard				Enabled		No	Off	No	0
1051	Optical Smoke ZP730	3	BLK2 3STY Z3-8 ELECT RISER 1 - SD	Standard				Enabled		No	Off	No	0
1052	Optical Smoke ZP730	3	BLK2 3STY Z3-9 UC-COMMS RISER - SD	Standard				Enabled		No	Off	No	0
1053	Optical Smoke ZP730	3	BLK2 3STY Z3-10 C-COMMS RISER - SD	Standard				Enabled		No	Off	No	0
1054	Optical Smoke ZP730	3	BLK2 3STY Z3-11 S-COMMS RISER - SD	Standard				Enabled		No	Off	No	0
1055	Optical Smoke ZP730	3	BLK2 3STY Z3-12 ELECT RISER 2 - SD	Standard				Enabled		No	Off	No	0
1056	Optical Smoke ZP730	3	BLK2 3STY Z3-13 NCR ROOM(#03-13) - SD	Standard				Enabled		No	Off	No	0
1057	Optical Smoke ZP730	3	BLK2 3STY Z3-14 NCR ROOM (#03-12) - SD	Standard				Enabled		No	Off	No	0
1058	Optical Smoke ZP730	3	BLK2 3STY Z3-15 NCR ROOM(#03-11) - SD	Standard				Enabled		No	Off	No	0
1059	Optical Smoke ZP730	3	BLK2 3STY Z3-16 NCR ROOM(#03-14) - SD	Standard				Enabled		No	Off	No	0
1060	Heat ZP720-3	3	BLK2 3STY Z3-17 LIFT LOBBY - HD	2: 58C RR				Enabled		No	Off	No	0
1061	Emulated Sprinkler	3	BLK2 3STY Z3-18 FLOWSWITCH - IF	Standard				Enabled		No	Off	No	0
1062	Callpoint ZP785	4	BLK2 ROOF Z4-1 STARCASE 1 NEAR HR - MCP	Standard				Enabled		No	Off	No	0
1063	Callpoint ZP785	4	BLK2 ROOF Z4-2 STARCASE 2 NEAR HR - MCP	Standard				Enabled		No	Off	No	0
1064	Optical Smoke ZP730	4	BLK2 ROOF Z4-3 ELECT RISER - SD	Standard				Enabled		No	Off	No	
1065	Heat ZP720-3	4	BLK2 ROOF Z4-4 OT RISER - HD	2: 58C RR				Enabled		No	Off	No	0
1066	Address Relay ZP750/A51	128	BLK 2 3STY PL LIFT HOMMING(COM) - RLY	n/a				Enabled		No	Off	No	
1067	Address Relay ZP750/A51	128	BLK 2 3STY PL LIFT HOMMING(ALT) - RLY	n/a				Enabled		No	Off	No	0
1068	Optical Smoke ZP730	1	BLK2 1STY Z1-25 EVC/ELECT DB ROOM- MCP	Standard				Enabled		No	Off	No	
1069	Emulated Fire	1	BLK2 1STY Z1-24 NRC(C) ROOM (FIRE)- IF	Standard				Enabled		No	Off	No	0

Device Details

Project : **DB CAMP**

Panel:10 **Line: 1** (Continued from Page 2)

Addr	Device Type	Zone	Device Message	Sensitivity		Sensitivity		Disable (Pri)	Disable (Sec)	Base Sounder	AVF	Self Test	Radio Sndr Group
1070	Emulated Security NL	101	BLK2 1STY NRC(C) ROOM (FAULT) -IF	Standard				Enabled		No	Off	No	0
1071	Address Relay ZP750/A51	128	BLK 2 1STY HVLS FAN - RLY	n/a				Enabled		No	Off		
1072	Address Relay ZP750/A51	128	BLK 2 1STY HVLS FAN - RLY	n/a				Enabled		No	Off	No	0