

Air Conditioning Equipment Schedule - Level 2

Designation	Area Served	Brand / Model Offered		Type	Designed Capacity (kW)	Offered Capacity (kW)	Qty	No of Set	Power Input (kW)	Running Current (Amp)	Maximum Circuit (Amp)	Isolator Size (A/Ph)	Qty	Pipe Size Liquid	Pipe Size Gas	Airflow Rate (CMH)	Dimension (HxWxD)	Control Panel Designation	Control Panel Power Requirement
CU-2-5	ROOF	MITSUBISHI	PUCY-EP450YSKD	VRF - 410A	48.70	50.4		1											
			PUCY-P200YKD						4.66	7.40	11.10	20A(3ø)	1	ø 9.52	ø 22.22	10500	1650 x 920 x 740		
			PUCY-P250YKD				1		5.95	9.50	14.25	32A(3ø)	1	ø 9.52	ø 22.22	10500	1650 x 920 x 740		
FCU-5-1	02-01 CS & OPS ROOM	MITSUBISHI	PLFY-P50VEM-PA	4-WAY CEILING CASSETTE	5.20	5.6	1	1	0.03	0.32	0.48	13A(1ø)	1	ø 6.35	ø 12.70	1140	258 x 840 x 840		
FCU-5-2		MITSUBISHI	PLFY-P50VEM-PA	4-WAY CEILING CASSETTE	5.20	5.6	1		0.03	0.32	0.48	13A(1ø)	1	ø 6.35	ø 12.70	1140	258 x 840 x 840		
FCU-5-3	02-01B Hd Ops	MITSUBISHI	PLFY-P32VFM-E	4-WAY CEILING CASSETTE	3.19	3.6	1		0.02	0.23	0.35	13A(1ø)	1	ø 6.35	ø 12.70	570	208 x 570 x 570		
FCU-5-4	02-01A Hd GS	MITSUBISHI	PLFY-P32VFM-E	4-WAY CEILING CASSETTE	3.26	3.6	1	1	0.02	0.23	0.35	13A(1ø)	1	ø 6.35	ø 12.70	570	208 x 570 x 570		
FCU-5-5	02-01 ATO	MITSUBISHI	PLFY-P32VFM-E	4-WAY CEILING CASSETTE	1.66	3.6	1		0.02	0.23	0.35	13A(1ø)	1	ø 6.35	ø 12.70	570	208 x 570 x 570		
FCU-5-6	02-01 ARTY OPS	MITSUBISHI	PLFY-P32VFM-E	4-WAY CEILING CASSETTE	2.86	3.6	1		0.02	0.23	0.35	13A(1ø)	1	ø 6.35	ø 12.70	570	208 x 570 x 570		
FCU-5-7	02-01 FMSO	MITSUBISHI	PLFY-P32VFM-E	4-WAY CEILING CASSETTE	2.86	3.6	1	1	0.02	0.23	0.35	13A(1ø)	1	ø 6.35	ø 12.70	570	208 x 570 x 570		
FCU-5-8	02-02 O-ROOM	MITSUBISHI	PLFY-P63VEM-PA	4-WAY CEILING CASSETTE	7.09	7.1	1		0.03	0.36	0.54	13A(1ø)	1	ø 9.52	ø 15.88	1140	258 x 840 x 840		
FCU-5-9	02-03 TRAINING	MITSUBISHI	PLFY-P63VEM-PA	4-WAY CEILING CASSETTE	7.07	7.1	1		0.03	0.36	0.54	13A(1ø)	1	ø 9.52	ø 15.88	1140	258 x 840 x 840		
FCU-5-10	02-04 INT BRANCH	MITSUBISHI	PLFY-P32VFM-E	4-WAY CEILING CASSETTE	2.58	3.6	1	1	0.02	0.23	0.35	13A(1ø)	1	ø 6.35	ø 12.70	570	208 x 570 x 570		
FCU-5-11		MITSUBISHI	PLFY-P32VFM-E	4-WAY CEILING CASSETTE	2.58	3.6	1		0.02	0.23	0.35	13A(1ø)	1	ø 6.35	ø 12.70	570	208 x 570 x 570		
FCU-5-12		MITSUBISHI	PLFY-P32VFM-E	4-WAY CEILING CASSETTE	2.58	3.6	1		0.02	0.23	0.35	13A(1ø)	1	ø 6.35	ø 12.70	570	208 x 570 x 570		
FCU-5-13		MITSUBISHI	PLFY-P32VFM-E	4-WAY CEILING CASSETTE	2.58	3.6	1		0.02	0.23	0.35	13A(1ø)	1	ø 6.35	ø 12.70	570	208 x 570 x 570		
CU-2-6	ROOF	MITSUBISHI	PUCY-EP650YSKD	VRF - 410A	73.3	73.5		1											
			PUCY-P350YKD						9.66	14.40	23.10	32A(3ø)	1	ø 12.70	ø 28.58	12600	1650 x 1220 x 740		
			PUCY-P300YKD				1		7.82	12.50	18.75	32A(3ø)	1	ø 12.70	ø 22.22	10500	1650 x 920 x 740		
FCU-6-1	02-01 CS & OPS ROOM	MITSUBISHI	PLFY-P100VEM-PA	4-WAY CEILING CASSETTE	10.41	11.2	1	1	0.07	0.67	1.01	13A(1ø)	1	ø 9.52	ø 15.88	1740	298 x 840 x 840		
FCU-6-2	02-01 NSF	MITSUBISHI	PLFY-P32VFM-E	4-WAY CEILING CASSETTE	3.26	3.6	1		0.02	0.23	0.35	13A(1ø)	1	ø 6.35	ø 12.70	570	208 x 570 x 570		
PFUC-6-3	02-01 CS & OPS ROOM	MITSUBISHI	PEFY-P200VMHS-E-F	FRESH AIR INTAKE	11.55	22.4	1		0.26	1.66	2.49	13A(1ø)	1	ø 9.52	ø 19.05	1680	470 x 1250 x 1120		
FCU-6-4	02-01 Hd TRG	MITSUBISHI	PLFY-P32VFM-E	4-WAY CEILING CASSETTE	1.90	3.6	1	1	0.02	0.23	0.35	13A(1ø)	1	ø 6.35	ø 12.70	570	208 x 570 x 570		
FCU-6-5	02-01 OPS/TRG WD	MITSUBISHI	PLFY-P32VFM-E	4-WAY CEILING CASSETTE	1.90	3.6	1		0.02	0.23	0.35	13A(1ø)	1	ø 6.35	ø 12.70	570	208 x 570 x 570		
FCU-6-6	02-01C Hd AP	MITSUBISHI	PLFY-P32VFM-E	4-WAY CEILING CASSETTE	3.14	3.6	1		0.02	0.23	0.35	13A(1ø)	1	ø 6.35	ø 12.70	570	208 x 570 x 570		
FCU-6-7	02-01 ENGR OPS	MITSUBISHI	PLFY-P32VFM-E	4-WAY CEILING CASSETTE	2.90	3.6	1	1	0.02	0.23	0.35	13A(1ø)	1	ø 6.35	ø 12.70	570	208 x 570 x 570		
FCU-6-8	02-02 O-ROOM	MITSUBISHI	PLFY-P32VFM-E	4-WAY CEILING CASSETTE	2.54	3.6	1		0.02	0.23	0.35	13A(1ø)	1	ø 6.35	ø 12.70	570	208 x 570 x 570		
FCU-6-9	02-03 TRAINING	MITSUBISHI	PLFY-P63VEM-PA	4-WAY CEILING CASSETTE	7.07	7.1	1		0.03	0.36	0.54	13A(1ø)	1	ø 9.52	ø 15.88	1140	258 x 840 x 840		
FCU-6-10	02-04 INT BRANCH	MITSUBISHI	PLFY-P32VFM-E	4-WAY CEILING CASSETTE	2.58	3.6	1	1	0.02	0.23	0.35	13A(1ø)	1	ø 6.35	ø 12.70	570	208 x 570 x 570		
FCU-6-11		MITSUBISHI	PLFY-P32VFM-E	4-WAY CEILING CASSETTE	2.58	3.6	1		0.02	0.23	0.35	13A(1ø)	1	ø 6.35	ø 12.70	570	208 x 570 x 570		
FCU-6-12		MITSUBISHI	PLFY-P32VFM-E	4-WAY CEILING CASSETTE	2.58	3.6	1		0.02	0.23	0.35	13A(1ø)	1	ø 6.35	ø 12.70	570	208 x 570 x 570		
FCU-6-13	02-04 DY Hd INT OFFICE	MITSUBISHI	PLFY-P32VFM-E	4-WAY CEILING CASSETTE	2.58	3.6	1	1	0.02	0.23	0.35	13A(1ø)	1	ø 6.35	ø 12.70	570	208 x 570 x 570		
CU-2-7	ROOF	MITSUBISHI	PUCY-EP600YSKD	VRF - 410A	55.9	68.0		1											
			PUCY-P350YKD						9.66	15.40	18.75	32A(3ø)	1	ø 12.70	ø 28.58	12600	1650 x 1220 x 740		
			PUCY-P250YKD				1		5.95	9.50	14.25	32A(3ø)	1	ø 9.52	ø 22.22	10500	1650 x 920 x 740		
FCU-7-1	02-05 BF ROOM	MITSUBISHI	PLFY-P125VEM-PA	4-WAY CEILING CASSETTE	11.59	14.0	1	1	0.11	1.06	1.59	13A(1ø)	1	ø 9.52	ø 15.88	2100	298 x 840 x 840		
FCU-7-2	02-06 R-ROOM	MITSUBISHI	PLFY-P50VEM-PA	4-WAY CEILING CASSETTE	4.68	5.6	1		0.03	0.32	0.48	13A(1ø)	1	ø 6.35	ø 12.70	1140	258 x 840 x 840		
FCU-7-3	02-12 INTERVIEW ROOM	MITSUBISHI	PLFY-P50VEM-PA	4-WAY CEILING CASSETTE	4.18	5.6	1		0.03	0.32	0.48	13A(1ø)	1	ø 6.35	ø 12.70	1140	258 x 840 x 840		
FCU-7-4	02-11 INTERVIEW ROOM	MITSUBISHI	PLFY-P50VEM-PA	4-WAY CEILING CASSETTE	3.92	5.6	1	1	0.03	0.32	0.48	13A(1ø)	1	ø 6.35	ø 12.70	1140	258 x 840 x 840		
FCU-7-5	02-08 CAMP OPS	MITSUBISHI	PLFY-P50VEM-PA	4-WAY CEILING CASSETTE	4.61	5.6	1		0.03	0.32	0.48	13A(1ø)	1	ø 6.35	ø 12.70	1140	258 x 840 x 840		
FCU-7-6	02-09 LOG BRANCH	MITSUBISHI	PLFY-P50VEM-PA	4-WAY CEILING CASSETTE	4.38	5.6	1		0.03	0.32	0.48	13A(1ø)	1	ø 6.35	ø 12.70	1140	258 x 840 x 840		
FCU-7-7	02-09 LOG BRANCH	MITSUBISHI	PLFY-P50VEM-PA	4-WAY CEILING CASSETTE	4.38	5.6	1	1	0.03	0.32	0.48	13A(1ø)	1	ø 6.35	ø 12.70	1140	258 x 840 x 840		
PFUC-7-8	02-07 STORE OUTSIDE	MITSUBISHI	PEFY-P125VMHS-E-F	FRESH AIR INTAKE	11.55	14.0	1		0.22	1.43	2.49	13A(1ø)	1	ø 9.52	ø 15.88	1080	380 x 1195 x 900		
FCU-7-9	02-09 DY HD LOG	MITSUBISHI	PLFY-P32VFM-E	4-WAY CEILING CASSETTE	3.43	3.6	1		0.02	0.23	0.35	13A(1ø)	1	ø 6.35	ø 12.70	570	208 x 570 x 570		
FCU-7-10	02-09 FMEQ	MITSUBISHI	PLFY-P32VFM-E	4-WAY CEILING CASSETTE	3.05	3.6	1	1	0.02	0.23	0.35	13A(1ø)	1	ø 6.35	ø 12.70	570	208 x 570 x 570		
CU-2-8	ROOF	MITSUBISHI	PUCY-EP400YSKD	VRF - 410A	44.78	44.8		1											
			PUCY-P200YKD						4.66	7.40	11.10	20A(3ø)	1	ø 9.52	ø 22.22	10500	1650 x 920 x 740		
			PUCY-P200YKD				1		4.66	7.40	11.10	20A(3ø)	1	ø 9.52	ø 22.22	10500	1650 x 920 x 740		
FCU-8-1	02-05 BF ROOM	MITSUBISHI	PLFY-P125VEM-PA	4-WAY CEILING CASSETTE	11.59	14.0	1	1	0.11	1.06	1.59	13A(1ø)	1	ø 9.52	ø 15.88	2100	298 x 840 x 840		
FCU-8-2	02-06 R-ROOM	MITSUBISHI	PLFY-P50VEM-PA	4-WAY CEILING CASSETTE	4.68	5.6	1		0.03	0.32	0.48	13A(1ø)	1	ø 6.35	ø 12.70	1140	258 x 840 x 840		
FCU-8-3	02-08 CAMP OPS	MITSUBISHI	PLFY-P50VEM-PA	4-WAY CEILING CASSETTE	4.61	5.6	1		0.03	0.32	0.48	13A(1ø)	1	ø 6.35	ø 12.70	1140	258 x 840 x 840		
FCU-8-4	02-10 SMC	MITSUBISHI	PLFY-P50VEM-PA	4-WAY CEILING CASSETTE	3.95	5.6	1	1	0.03	0.32	0.48	13A(1ø)	1	ø 6.35	ø 12.70	1140	258 x 840 x 840		
FCU-8-5	02-09 LOG BRANCH	MITSUBISHI	PLFY-P50VEM-PA	4-WAY CEILING CASSETTE	4.38	5.6	1		0.03	0.32	0.48	13A(1ø)	1	ø 6.35	ø 12.70	1140	258 x 840 x 840		
FCU-8-6		MITSUBISHI	PLFY-P50VEM-PA	4-WAY CEILING CASSETTE	4.38	5.6	1		0.03	0.32	0.48	13A(1ø)	1	ø 6.35	ø 12.70	1140	258 x 840 x 840		
FCU-8-7	02-09 FINANCE	MITSUBISHI	PLFY-P32VFM-E	4-WAY CEILING CASSETTE	3.50	3.6	1	1	0.02	0.23	0.35	13A(1ø)	1	ø 6.35	ø 12.70	570	208 x 570 x 570		
FCU-8-8	02-09 RESOURCE	MITSUBISHI	PLFY-P32VFM-E	4-WAY CEILING CASSETTE	3.00	3.6	1		0.02	0.23	0.35	13A(1ø)	1	ø 6.35	ø 12.70	570	208 x 570 x 570		
FCU-8-9	02-09 Hd LOG	MITSUBISHI	PLFY-P50VEM-PA	4-WAY CEILING CASSETTE	4.68	5.6	1		0.03	0.32	0.48	13A(1ø)	1	ø 6.35	ø 12.70	1140	258 x 840 x 840		

M&E CONSULTANTS
PdcConsultants Pte Ltd
23 NEW INDUSTRIAL ROAD #06-03
SOLISICE BUSINESS CENTER SINGAPORE 536209
TEL: 6444 7748
FAX: 6444 7141

DATE RECEIVED: _____ RECEIVED BY: _____
DATE RETURNED: _____
☐ NO EXCEPTION TAKEN ☐ MAKE CORRECTIONS NOTED PRIOR TO GENERAL USE
☐ TO REVISE & RESUBMIT ☐ REJECTED & RESUBMIT

SIGNATURE: _____

- WHERE RESUBMISSION IS REQUIRED, SUBMIT REVISED DRAWINGS FOR REVIEW PRIOR TO PROCEEDING WITH WORK
- THIS REVIEW IS FOR GENERAL ARRANGEMENT ONLY AND DOES NOT EXTEND TO DIMENSIONS OF SETTING OUT OF THE WORKS AND DOES NOT RELEASE THE CONTRACTOR OF HIS RESPONSIBILITIES TO ENSURE FULL COMPLIANCE
- THIS REVIEW DOES NOT RELEASE THE CONTRACTOR OF HIS RESPONSIBILITIES TO ENSURE WORKS IN COMPLIANCE TO CONTRACT SPECIFICATION, OTHER DRAWINGS AND STATUTORY REQUIREMENT HAVING JURISDICTION OVER THE INSTALLATION.

AS-BUILT DRAWING
Project Ref. No. : A2105-00599-2022


Defence Science & Technology Agency


INNOVATION EXCELLENCE
A S.M.A.R.T. 2014 WINNER


CERTIFICATION INTERNATIONAL
ISO 9001:2008
CERT No. CCB 0070


SINGAPORE QUALITY STANDARD
STAR

PEH SEOH CHIN
Hd (Army Camp)

EDMUND TEO KUAN WEI
Senior Programme Manager

D&B Main Contractor:

DEENN ENGINEERING PTE LTD
29 Harrison Road, Lian Beng Building, Singapore 369648
TEL. No. 6283 1468 FAX No. 6280 9360
e-mail : lianbengconstrn@pacific.net.sg
Website: www.lianbeng.com.sg

Architect:
ID ARCHITECTS PTE LTD
3 HarbourFront Place, #03-01,
HarbourFront Tower Two,
Singapore 099254
Tel: 6225 6011
Fax: 6225 6022
general@idarchitects.com.sg
www.idarch