

# CERTIFICATE OF CONFORMITY

This Certificate is issued to

**LINGJACK ENGINEERING WORKS PTE LTD**

**(UEN No.: 199103053M)**

**No. 1 Woodlands Terrace, #03-01 Lingjack Industrial Building, Singapore 738471**

**For Product Certification Scheme: Type 5**

**Product : Landing Valve**

**Brand : COMBAT**

**Model : LV-DR25, LV-OF25, LV-RA25, LV-RAF25, LV-HS25,  
LV-HF25, LV-BNS25, LV-BNF25**

**Country of Origin : Singapore**

**Product Details : Low pressure type of landing valve.  
Refer to Appendix for details.**

which has complied with the requirements of the scheme based on the following:

<b>STANDARD(S)</b>	<b>TEST REPORT(S)</b>
BS 5041 Part 1: 1987	BRE Test Report No.: 255924
	BRE Test Report No.: 257781
	BRE Test Report No.: 257782
	BRE Test Report No.: 257783

**Detailed configuration and installation shall be referenced to the certified report(s) stated above.**



**Dixon Ng (Mr)**  
Program Manager  
SETSCO Services Pte Ltd  
531 Bukit Batok Street 23,  
Singapore 659547

**Certificate No**  
**FSP-2010-0009**

**Date of Issue**  
**07/02/2022**

**Date of Expiry**  
**06/02/2027**

This Certificate is part of full report and should be read in conjunction with it. This Certificate remains the property of SETSCO Services Pte Ltd (SETSCO) and shall be returned upon request. The use of this Certificate is subjected to the terms and conditions of the SETSCO Product Certification Scheme. The manufacturer is solely responsible for the compliance of any product that has the same designation as the product type-tested. Persons relying on this Certificate should verify its validity by checking it at [www.setsco.com](http://www.setsco.com)

The use of the SAC accreditation mark indicates accreditation in respect of those activities covered by the accreditation certificate number PD-2010-10.

Model	Description	Test Report
LV-DR25	2½" PN16, oblique, screwed inlet, low pressure	255924
LV-OF25	2½" PN16, oblique, flanged inlet, low pressure	
LV-RA25	2½" PN16, right angle, screwed inlet, low pressure	257781
LV-RAF25	2½" PN16, right angle, flanged inlet, low pressure	
LV-HS25	2½" PN16, horizontal, screwed inlet, low pressure	257782
LV-HF25	2½" PN16, horizontal, flanged inlet, low pressure	
LV-BNS25	2½" PN16, bib nosed, screwed inlet, low pressure	257783
LV-BNF25	2½" PN16, bib nosed, flanged inlet, low pressure	



**Dixon Ng (Mr)**  
Program Manager  
SETSCO Services Pte Ltd  
531 Bukit Batok Street 23,  
Singapore 659547

**Certificate No**  
**FSP-2010-0009**

**Date of Issue**  
**07/02/2022**

**Date of Expiry**  
**06/02/2027**

*Amendments or additions to this appendix other than those authorized by SETSCO render the appendix invalid.*