



**MITSUBISHI
ELECTRIC**

SPLIT-TYPE, HEAT PUMP AIR CONDITIONERS

December 2018

No. TCH031

TECHNICAL & SERVICE MANUAL

Series PLFY Ceiling Cassettes R410A

Indoor unit


[Model names]	[Service Ref.]
PLFY-P32VEM-A/-PA/-DA/-TH	PLFY-P32VEM-A/-PA/-DA/-TH.TH
PLFY-P40VEM-A/-PA/-DA/-TH	PLFY-P40VEM-A/-PA/-DA/-TH.TH
PLFY-P50VEM-A/-PA/-DA/-TH	PLFY-P50VEM-A/-PA/-DA/-TH.TH
PLFY-P63VEM-A/-PA/-DA/-TH	PLFY-P63VEM-A/-PA/-DA/-TH.TH
PLFY-P80VEM-A/-PA/-DA/-TH	PLFY-P80VEM-A/-PA/-DA/-TH.TH
PLFY-P100VEM-A/-PA/-DA/-TH	PLFY-P100VEM-A/-PA/-DA/-TH.TH
PLFY-P125VEM-A/-PA/-DA/-TH	PLFY-P125VEM-A/-PA/-DA/-TH.TH

Notes:


- This manual describes service data of the indoor units only.
- RoHS compliant products have <G> mark on the spec name plate.

Grille model


[Model names]	[Service Ref.]	
PLP-6EA	PLP-6EAR1	PLP-6EAR1-TH/-DA
PLP-6EAE	PLP-6EAER1	
PLP-6EAL	PLP-6EALR1	
PLP-6EALE	PLP-6EALER1	
PLP-6EAJ	PLP-6EAJ	PLP-6EAJ-TH
PLP-6EAJE	PLP-6EAJE	
PLP-6EALM	PLP-6EALM	
PLP-6EALME	PLP-6EALME	PLP-6EALM-TH/-DA
PLP-6EALCM	PLP-6EALCM	PLP-6EALCM-TH/-DA
PLP-6EAMD	PLP-6EAMD	PLP-6EAMD-TH



INDOOR UNIT



WIRELESS REMOTE
CONTROLLER
(Option)



WIRED REMOTE
CONTROLLER
(Option)

CONTENTS

1. SAFETY PRECAUTION.....	2
2. PARTS NAMES AND FUNCTIONS.....	4
3. SPECIFICATIONS.....	13
4. 4-WAY AIR FLOW SYSTEM.....	18
5. OUTLINES AND DIMENSIONS.....	21
6. WIRING DIAGRAM.....	22
7. REFRIGERANT SYSTEM DIAGRAM.....	26
8. TROUBLESHOOTING.....	27
9. SPECIAL FUNCTION.....	36
10. DISASSEMBLY PROCEDURE.....	39

PARTS CATALOG (TCB031)

CITY MULTI

Cautions for units utilizing refrigerant R410A**Do not use the existing refrigerant piping.**

The old refrigerant and lubricant in the existing piping contain a large amount of chlorine which may cause the lubricant deterioration of the new unit.

Use "low residual oil piping"

If there is a large amount of residual oil (hydraulic oil, etc.) inside the piping and joints, deterioration of the lubricant will result.

**Store the piping indoors, and both ends of the piping sealed until just before brazing.
(Leave elbow joints, etc. in their packaging.)**

If dirt, dust or moisture enters into refrigerant cycle, that can cause deterioration of refrigerant oil or malfunction of compressor.

The refrigerant oil applied to flare and flange connections must be ester oil, ether oil or alkylbenzene oil in a small amount.

If large amount of mineral oil enters, that can cause deterioration of refrigerant oil, etc.

Charge refrigerant from liquid phase of gas cylinder.

If the refrigerant is charged from gas phase, composition change may occur in refrigerant and the efficiency will be lowered.

Do not use refrigerant other than R410A.

If other refrigerant (R22, etc.) is used, chlorine in refrigerant can cause deterioration of refrigerant oil, etc.

Use a vacuum pump with a reverse flow check valve.

Vacuum pump oil may flow back into refrigerant cycle and that can cause deterioration of refrigerant oil, etc.

Use the following tools specifically designed for use with R410A refrigerant.

The following tools are necessary to use R410A refrigerant.

Tools for R410A	
Gauge manifold	Flare tool
Charge hose	Size adjustment gauge
Gas leak detector	Vacuum pump adaptor
Torque wrench	Electronic refrigerant charging scale

Handle tools with care.

If dirt, dust or moisture enters into refrigerant cycle, that can cause deterioration of refrigerant oil or malfunction of compressor.

Do not use a charging cylinder.

If a charging cylinder is used, the composition of refrigerant will change and the efficiency will be lowered.

Use the specified refrigerant only.**Never use any refrigerant other than that specified.**

Doing so may cause a burst, an explosion, or fire when the unit is being used, serviced, or disposed of.

Correct refrigerant is specified in the manuals and on the spec labels provided with our products.

We will not be held responsible for mechanical failure, system malfunction, unit breakdown or accidents caused by failure to follow the instructions.

Ventilate the room if refrigerant leaks during operation. If refrigerant comes into contact with a flame, poisonous gases will be released.


[1] Cautions for service

- (1) Perform service after recovering the refrigerant left in unit completely.
- (2) Do not release refrigerant in the air.
- (3) After completing service, charge the cycle with specified amount of refrigerant.
- (4) When performing service, install a filter drier simultaneously.
Be sure to use a filter drier for new refrigerant.

[2] Additional refrigerant charge

When charging directly from cylinder

- (1) Check that cylinder for R410A available on the market is syphon type.
- (2) Charging should be performed with the cylinder of syphon stood vertically. (Refrigerant is charged from liquid phase.)




[3] Service tools

Use the below service tools as exclusive tools for R410A refrigerant.


No.	Tool name	Specifications
①	Gauge manifold	·Only for R410A
		·Use the existing fitting specifications. (UNF1/2)
		·Use high-tension side pressure of 5.3MPa·G or over.
②	Charge hose	·Only for R410A
		·Use pressure performance of 5.09MPa·G or over.
③	Electronic weighing scale	—
④	Gas leak detector	·Use the detector for R134a, R407C or R410A.
⑤	Adaptor for reverse flow check	·Attach on vacuum pump.
⑥	Refrigerant charge base	—
⑦	Refrigerant cylinder	·Only for R410A ·Top of cylinder (Pink) ·Cylinder with syphon
⑧	Refrigerant recovery equipment	—

2-1. Indoor unit



2-2. WIRED REMOTE CONTROLLER <PAR-32/33MAA>

Wired remote controller function



① ON/OFF button

Press to turn ON/OFF the indoor unit.

② SELECT button

Press to save the setting.

③ RETURN button

Press to return to the previous screen.

④ MENU button

Press to bring up the Main menu.

⑤ Backlit LCD

Operation settings will appear.


When the backlight is off, pressing any button turns the backlight on and it will stay lit for a certain period of time depending on the screen.

When the backlight is off, pressing any button turns the backlight on and does not perform its function. (except for the (ON/OFF) button)

The functions of the function buttons change depending on the screen. Refer to the button function guide that appears at the bottom of the LCD for the functions they serve on a given screen.

When the system is centrally controlled, the button function guide that corresponds to the locked button will not appear.

<Main display>



<Main menu>



Function guide

⑥ ON/OFF lamp

This lamp lights up in green while the unit is in operation. It blinks while the remote controller is starting up or when there is an error.

⑦ Function button F1

Main display : Press to change the operation mode.
Main menu : Press to move the cursor down.

⑧ Function button F2

Main display : Press to decrease temperature.
Main menu : Press to move the cursor up.

⑨ Function button F3

Main display : Press to increase temperature.
Main menu : Press to go to the previous page.


⑩ Function button F4

Main display : Press to change the fan speed.
Main menu : Press to go to the next page.


The main display can be displayed in 2 different modes: "Full" and "Basic".
The initial setting is "Full". To switch to the "Basic" mode, change the setting on the Main display setting.

<Full mode>

All icons are displayed for explanation.



<Basic mode>



① Operation mode

Indoor unit operation mode appears here.

② Preset temperature

Preset temperature appears here.

③ Clock (See the Installation Manual.)

Current time appears here.

④ Fan speed

Fan speed setting appears here.

⑤ Button function guide

Functions of the corresponding buttons appear here.



Appears when the ON/OFF operation is centrally controlled.



Appears when the operation mode is centrally controlled.



Appears when the preset temperature is centrally controlled.



Appears when the filter reset function is centrally controlled.



Indicates when filter needs maintenance.

⑪ Room temperature (See the Installation Manual.)

Current room temperature appears here.



Appears when the buttons are locked.

⑬

Appears when the On/Off timer or Night setback function is enabled.



Appears when the Weekly timer is enabled.



Appears while the units are operated in the energy-save mode.



Appears while the outdoor units are operated in the silent mode.



Appears when the built-in thermistor on the remote controller is activated to monitor the room temperature.

□ appears when the thermistor on the indoor unit is activated to monitor the room temperature.



Appears when the units are operated in the energy-saving mode with 3D i-see Sensor.



Indicates the vane setting.



Indicates the louver setting.




Indicates the ventilation setting.



Appears when the preset temperature range is restricted.

Most settings (except ON/OFF, mode, fan speed, temperature) can be made from the Menu screen.

Menu structure




Main menu list

Setting and display items		Setting details
Vane · Louver · Vent. (Lossnay)		<p>Use to set the vane angle. • Select a desired vane setting from 5 different settings.</p> <p>Use to turn ON/OFF the louver. • Select a desired setting from "ON" and "OFF."</p> <p>Use to set the amount of ventilation. • Select a desired setting from "Off," "Low," and "High."</p>
High power		<p>Use to reach the comfortable room temperature quickly. • Units can be operated in the High-power mode for up to 30 minutes.</p>
Timer	ON/OFF timer*	<p>Use to set the operation ON/OFF times. • Time can be set in 5-minute increments.</p>
	Auto-Off timer	<p>Use to set the Auto-Off time. • Time can be set to a value from 30 to 240 in 10-minute increments.</p>
Weekly timer*		<p>Use to set the weekly operation ON/OFF times. • Up to 8 operation patterns can be set for each day. (Not valid when the ON/OFF timer is enabled.)</p>
OU silent mode*		<p>Use to set the time periods in which priority is given to quiet operation of outdoor units over temperature control. Set the Start/Stop times for each day of the week. • Select the desired silent level from "Normal", "Middle" and "Quiet".</p>
Restriction	Temp. range	<p>Use to restrict the preset temperature range. • Different temperature ranges can be set for different operation modes.</p>
	Operation lock	<p>Use to lock selected functions. • The locked functions cannot be operated.</p>
Energy-saving	Auto return	<p>Use to get the units to operate at the preset temperature after performing energy-saving operation for a specified time period. • Time can be set to a value from 30 and 120 in 10-minute increments. (This function will not be valid when the preset temperature ranges are restricted.)</p>
	Schedule*	<p>Set the start/stop times to operate the units in the energy-save mode for each day of the week, and set the energy-saving rate. • Up to 4 energy-saving operation patterns can be set for each day. • Time can be set in 5-minute increments. • Energy-saving rate can be set to a value from 0% or 50 to 90% in 10% increments.</p>
Night setback*		<p>Use to make Night setback settings. • Select "Yes" to enable the setting, and "No" to disable the setting. The temperature range and the start/stop times can be set.</p>
Filter information		<p>Use to check the filter status. • The filter sign can be reset.</p>
Error information		<p>Use to check error information when an error occurs. • Check code, error source, refrigerant address, unit model, manufacturing number, contact information (dealer's phone number) can be displayed. (The unit model, manufacturing number, and contact information need to be registered in advance to be displayed.)</p>
Maintenance	Auto descending panel	<p>Auto descending panel (Optional parts) UP/DOWN you can do.</p>
	Manual vane angle	<p>Use to set the vane angle for each vane to a fixed position.</p>
	3D i-see Sensor	<p>Use to set the following functions for 3D i-see Sensor. • Air distribution • Energy saving option • Seasonal airflow</p>


* Clock setting is required.

Continue to the next page





Setting and display items		Setting details
Initial setting	Main/Sub	When connecting 2 remote controllers, one of them needs to be designated as a sub controller.
	Clock	Use to set the current time.
	Main display	Use to switch between "Full" and "Basic" modes for the Main display. • The initial setting is "Full."
	Contrast	Use to adjust screen contrast.
	Display details	Make the settings for the remote controller related items as necessary. Clock: The initial settings are "Yes" and "24h" format. Temperature: Set either Celsius (°C) or Fahrenheit (°F). Room temp. : Set Show or Hide. Auto mode: Set the Auto mode display or Only Auto display.
	Auto mode	Whether or not to use the AUTO mode can be selected by using the button. This setting is valid only when indoor units with the AUTO mode function are connected.
	Administrator password	The administrator password is required to make the settings for the following items. • Timer setting • Energy-saving setting • Weekly timer setting • Restriction setting • Outdoor unit silent mode setting • Night set back
	Language selection	Use to select the desired language.
Service	Test run	Select "Test run" from the Service menu to bring up the Test run menu. • Test run • Drain pump test run
	Input maintenance info.	Select "Input maintenance Info." from the Service menu to bring up the Maintenance information screen. The following settings can be made from the Maintenance Information screen. • Model name input • Serial No. input • Dealer information input
	Function setting (City Multi)	Make the settings for the indoor unit functions via the remote controller as necessary.
	LOSSNAY (City Multi only)	This setting is required only when the operation of City Multi units is interlocked with LOSSNAY units.
	Check	Error history: Display the error history and execute delete error history. Refrigerant leak check: Refrigerant leaks can be judged. Smooth maintenance: The indoor and outdoor maintenance data can be displayed. Request code: Details of the operation data including each thermistor temperature and error history can be checked.
	Self check	Error history of each unit can be checked via the remote controller.
	Maintenance password	Use to change the maintenance password.
	Remote controller check	When the remote controller does not work properly, use the remote controller checking function to troubleshoot the problem.


2-3. WIRELESS REMOTE CONTROLLER <PAR-SL97A-E>



2-4. WIRELESS REMOTE CONTROLLER <PAR-SL100A-E>



2-5. WIRED REMOTE CONTROLLER <PAR-21MAA>



Note:

- “PLEASE WAIT” message
This message is displayed for approximately 3 minutes when power is supplied to the indoor unit or when the unit is recovering from a power failure.
- “NOT AVAILABLE” message
This message is displayed if an invalid button is pressed (to operate a function that the indoor unit does not have).
If a single remote controller is used to operate multiple indoor units simultaneously that are different types, this message will not be displayed as far as any of the indoor units is equipped with the function.

3-1. SPECIFICATIONS

Model	PLFY-P32VEM-A/-PA/-DA/-TH	PLFY-P40VEM-A/-PA/-DA/-TH	PLFY-P50VEM-A/-PA/-DA/-TH	PLFY-P63VEM-A/-PA/-DA/-TH		
Power source	1-phase 220–240V 50Hz, 1-phase 220–230V 60Hz					
Cooling capacity (Nominal)	*1 kW	3.6	4.5	5.6		
	*1 kcal/h	3,100	3,900	4,800		
	*1 BTU/h	12,300	15,400	19,100		
	*2 kcal/h	3,150	4,000	5,000		
	Power input kW	0.03	0.03	0.03		
	Current input A	0.32	0.32	0.36		
Heating capacity (Nominal)	*3 kW	4.0	5.0	6.3		
	*3 kcal/h	3,400	4,300	5,400		
	*3 BTU/h	13,600	17,100	21,500		
	Power input kW	0.03	0.03	0.03		
	Current input A	0.25	0.25	0.29		
External finish	Galvanized steel sheet					
External dimension H × W × D	mm	258 × 840 × 840				
	inch	10-3/16 × 33-3/32 × 33-3/32				
Net weight	kg (lb)	19 (42)	19 (42)	19 (42)		
Grille	model	PLP-6EA	PLP-6EA	PLP-6EA		
External finish		MUNSELL (1.0Y 9.2/0.2)				
Dimension H × W × D	mm	40 × 950 × 950				
	inch	1-9/16 × 37-13/32 × 37-13/32				
Net weight	kg (lb)	5 (11)				
Heat exchanger	Micro slit fin (Aluminum fin and copper tube)					
FAN		Turbo fan × 1	Turbo fan × 1	Turbo fan × 1		
	External static press.	Pa	0	0		
		mmH ₂ O	0	0		
	Motor type					
	Motor output	kW	0.050	0.050		
	Driving mechanism					
Airflow rate (Low-Mid2-Mid1-High)	m ³ /min	13 - 14 - 16 - 17	13 - 14 - 16 - 18	13 - 14 - 16 - 19		
	L/s	217 - 233 - 267 - 283	217 - 233 - 267 - 300	217 - 233 - 267 - 317		
	cfm	459 - 494 - 565 - 600	459 - 494 - 565 - 636	459 - 494 - 565 - 671		
Sound pressure level (Low-Mid-High) (measured in anechoic room)	dB <A>	26 - 27 - 29 - 31	26 - 27 - 29 - 31	26 - 27 - 29 - 31		
Insulation material		PS				
Air filter		PP honeycomb				
Protection device		Fuse				
Refrigerant control device		LEV				
Connectable outdoor unit		R410A CITY MULTI				
Diameter of refrigerant pipe	Liquid (R410A) mm (inch)	ø6.35 (ø1/4) Flare	ø6.35 (ø1/4) Flare	ø6.35 (ø1/4) Flare		
	Gas (R410A) mm (inch)	ø12.7 (ø1/2) Flare	ø12.7 (ø1/2) Flare	ø12.7 (ø1/2) Flare		
Field drain pipe size	mm (inch)	O.D. ø32 (VP-25)				
Standard attachment	Document Accessory	Installation Manual, Instruction Book				
Remark	Optional parts					
	Grille **1		PLP-6EA	PLP-6EA		
	Air outlet shutter plate		PAC-SJ37SP-E	PAC-SJ37SP-E		
	High efficiency filter element **2		PAC-SH59KF-E	PAC-SH59KF-E		
	Multi-function casement		PAC-SJ41TM-E	PAC-SJ41TM-E		
			**1. PLFY-P-VEM-A/-PA/-DA/-TH should be used together with PLP-6EA. **2. PAC-SJ41TM-E is necessary to use with filter PAC-SH59KF-E.			
Installation		Details on foundation work, duct work, insulation work, electrical wiring, power source switch, and other items shall be referred to the Installation Manual.				
*1 Nominal cooling condition Indoor : 27°CDB/19°CWB (81°FDB/66°FWB) Outdoor : 35°CDB (95°FDB) Pipe length : 7.5 m (24-9/16 ft) Level difference : 0 m (0 ft)		*2 Nominal cooling condition 27°CDB/19.5°CWB (81°FDB/67°FWB) 35°CDB (95°FDB) 5 m (16-3/8 ft) 0 m (0 ft)		*3 Nominal heating condition 20°CDB (68°FDB) 7°CDB/6°CWB (45°FDB/43°FWB) 7.5 m (24-9/16 ft) 0 m (0 ft)		Unit converter
Notes: 1. Nominal conditions *1 and *3 are subject to JIS B8615-1. 2. Due to continuing improvement, above specification may be subject to change without notice.		kcal/h = kW × 860 Btu/h = kW × 3,412 cfm = m ³ /min × 35.31 lb = kg/0.4536 *Above specification data is subject to rounding variation.				

Product specification								
Model		PLFY-P80VEM-A-PA-DA/TH	PLFY-P100VEM-A-PA-DA/TH	PLFY-P125VEM-A-PA-DA/TH				
Power source		1-phase 220-240V 50Hz, 1-phase 220-230V 60Hz						
Cooling capacity (Nominal)		*1 kW *1 kcal/h *1 BTU/h *2 kcal/h	9.0 7,700 30,700 8,000	11.2 9,600 38,200 10,000	14.0 12,000 47,800 12,500			
Power input Current input		kW A	0.05 0.50	0.07 0.67	0.11 1.06			
Heating capacity (Nominal)		*3 kW *3 kcal/h *3 BTU/h	10.0 8,600 34,100	12.5 10,800 42,700	16.0 13,800 54,600			
Power input Current input		kW A	0.05 0.43	0.07 0.60	0.11 0.99			
External finish								
External dimension H × W × D		mm inch	258 × 840 × 840 10-3/16 × 33-3/32 × 33-3/32	298 × 840 × 840 11-3/4 × 33-13/32 × 33-13/32				
Net weight		kg (lb)	21(46)	24(53)	24(53)			
Grille	model		PLP-6EA	PLP-6EA	PLP-6EA			
	External finish		MUNSELL (1.OY 9.2/0.2)					
	Dimension H × W × D	mm inch	40 × 950 × 950 1-9/16 × 37-13/32 × 37-13/32					
	Net weight	kg (lb)	5 (11)					
Heat exchanger								
FAN	Type × Quantity		Turbo fan × 1	Turbo fan × 1	Turbo fan × 1			
	External static press.	Pa mmH ₂ O	0 0	0 0	0 0			
	Motor type		DC motor					
	Motor output	kW	0.050	0.120	0.120			
	Driving mechanism		Direct-drive					
	Airflow rate (Low-Mid2-Mid1-High)	m ³ /min L/s cfm	15 - 18 - 20 - 23 250 - 300 - 333 - 383 530 - 636 - 706 - 812	20 - 23 - 26 - 29 333 - 383 - 433 - 483 706 - 812 - 918 - 1024	24 - 26 - 30 - 35 400 - 433 - 500 - 583 847 - 918 - 1060 - 1236			
	Sound pressure level (Low-Mid-High) (measured in anechoic room)	dB <A>	28 - 31 - 34 - 37	34 - 37 - 39 - 41	35 - 39 - 42 - 45			
	Insulation material		PS					
	Air filter		PP honeycomb					
Protection device								
Refrigerant control device								
Connectable outdoor unit								
Diameter of refrigerant pipe	Liquid (R410A) Gas (R410A)	mm (inch)	ø9.52 (ø3/8) Flare ø15.88 (ø5/8) Flare	ø9.52 (ø3/8) Flare ø15.88 (ø5/8) Flare	ø9.52 (ø3/8) Flare ø15.88 (ø5/8) Flare			
Field drain pipe size		mm (inch)	O.D. ø32 (VP-25)					
Standard attachment	Document Accessory		Installation Manual, Instruction Book					
Remark	Optional parts							
	Grille **1		PLP-6EA	PLP-6EA	PLP-6EA			
	Air outlet shutter plate		PAC-SJ37SP-E	PAC-SJ37SP-E	PAC-SJ37SP-E			
	High efficiency filter element **2		PAC-SH59KF-E	PAC-SH59KF-E	PAC-SH59KF-E			
	Multi-function casement		PAC-SJ41TM-E	PAC-SJ41TM-E	PAC-SJ41TM-E			
			**1. PLFY-P-VEM-A-PA-DA/TH should be used together with PLP-6EA. **2. PAC-SJ41TM-E is necessary to use with filter PAC-SH59KF-E.					
	Installation		Details on foundation work, duct work, insulation work, electrical wiring, power source switch, and other items shall be referred to the Installation Manual.					
*1 Nominal cooling condition Indoor : 27°CDB/19°CWB (81°FDB/66°FWB) Outdoor : 35°CDB (95°FDB) Pipe length : 7.5 m (24-9/16 ft) Level difference : 0 m (0 ft)								
*2 Nominal cooling condition Indoor : 27°CDB/19.5°CWB (81°FDB/67°FWB) Outdoor : 35°CDB (95°FDB) 5 m (16-3/8 ft) 0 m (0 ft)								
*3 Nominal heating condition Indoor : 20°CDB (68°FDB) 7°CDB/6°CWB (45°FDB/43°FWB) 7.5 m (24-9/16 ft) 0 m (0 ft)								
Unit converter kcal/h = kW × 860 Btu/h = kW × 3,412 cfm = m ³ /min × 35.31 lb = kg/0.4536 *Above specification data is subject to rounding variation.								

Notes:

1. Nominal conditions *1 and *3 are subject to JIS B8615-1.

2. Due to continuing improvement, above specification may be subject to change without notice.


3-2. ELECTRICAL PARTS SPECIFICATIONS

Service Ref. Parts name	Symbol	PLFY-P32VEM-A-PA-DA-TH.TH	PLFY-P40VEM-A-PA-DA-TH.TH	PLFY-P50VEM-A-PA-DA-TH.TH	PLFY-P63VEM-A-PA-DA-TH.TH
Room temperature thermistor	TH21	Resistance 0°C/15kΩ, 10°C/9.6kΩ, 20°C/6.3kΩ, 25°C/5.4kΩ, 30°C/4.3kΩ, 40°C/3.0kΩ			
Liquid pipe thermistor	TH22	Resistance 0°C/15kΩ, 10°C/9.6kΩ, 20°C/6.3kΩ, 25°C/5.4kΩ, 30°C/4.3kΩ, 40°C/3.0kΩ			
Gas pipe thermistor	TH23	Resistance 0°C/15kΩ, 10°C/9.6kΩ, 20°C/6.3kΩ, 25°C/5.4kΩ, 30°C/4.3kΩ, 40°C/3.0kΩ			
Fuse (Indoor controller board)	FUSE		250V 6.3A		
Fan motor	MF		8-pole OUTPUT 50W		
Vane motor	MV		MSBPC20M13 DC12V 300Ω/phase		
Drain pump	DP		PMD-12D13ME INPUT 3W 24ℓ /Hr		
Drain float switch	FS		Open / Short detection		
Linear expansion valve	LEV		DC12V Stepping motor drive port dimension φ3.2 (0~2000pulse) EFM-40YGME		
Power supply terminal block	TB2		(L, N) Rated to 330V 30A *		
Transmission terminal block	TB5		(M1, M2, S) Rated to 250V 20A *		
MA remote controller terminal block	TB15		(1, 2) Rated to 250V 10A *		

*Refer to WIRING DIAGRAM for the supplied voltage.


Service Ref. Parts name	Symbol	PLFY-P80VEM-A-PA-DA-TH.TH	PLFY-P100VEM-A-PA-DA-TH.TH	PLFY-P125VEM-A-PA-DA-TH.TH
Room temperature thermistor	TH21	Resistance 0°C/15kΩ, 10°C/9.6kΩ, 20°C/6.3kΩ, 25°C/5.4kΩ, 30°C/4.3kΩ, 40°C/3.0kΩ		
Liquid pipe thermistor	TH22	Resistance 0°C/15kΩ, 10°C/9.6kΩ, 20°C/6.3kΩ, 25°C/5.4kΩ, 30°C/4.3kΩ, 40°C/3.0kΩ		
Gas pipe thermistor	TH23	Resistance 0°C/15kΩ, 10°C/9.6kΩ, 20°C/6.3kΩ, 25°C/5.4kΩ, 30°C/4.3kΩ, 40°C/3.0kΩ		
Fuse (Indoor controller board)	FUSE		250V 6.3A	
Fan motor	MF	8-pole OUTPUT 50W	8-pole OUTPUT 120W	
Vane motor	MV		MSBPC20M13 DC12V 300Ω/phase	
Drain pump	DP		PMD-12D13ME INPUT 3W 24R/Hr	
Drain float switch	FS		Open / Short detection	
Linear expansion valve	LEV		DC12V Stepping motor drive port dimension φ5.2 (0~2000pulse) EFM-80YGME	
Power supply terminal block	TB2		(L, N) Rated to 330V 30A *	
Transmission terminal block	TB5		(M1, M2, S) Rated to 250V 20A *	
MA remote controller terminal block	TB15		(1, 2) Rated to 250V 10A *	

*Refer to WIRING DIAGRAM for the supplied voltage.



3-3. SOUND PRESSURE LEVEL

PLFY-P-VEM-A/-PA/-DA/-TH.TH








Sound pressure level at anechoic room : Low-Mid2-Mid1-High

Service Ref.	Sound pressure level dB (A)
PLFY-P32VEM-A/-PA/-DA/-TH.TH	26-27-29-31
PLFY-P40VEM-A/-PA/-DA/-TH.TH	28-29-30-32
PLFY-P50VEM-A/-PA/-DA/-TH.TH	28-31-34-37
PLFY-P63VEM-A/-PA/-DA/-TH.TH	34-37-39-41
PLFY-P80VEM-A/-PA/-DA/-TH.TH	35-39-42-45
PLFY-P100VEM-A/-PA/-DA/-TH.TH	
PLFY-P125VEM-A/-PA/-DA/-TH.TH	

Note: Measured in anechoic room.

3-4. NC CURVES





4-1. PLACEMENT OF THE AIR OUTLETS

- For this grille, the blowout direction comes in 11 patterns.

Also, by setting switch on the controller board to the appropriate settings, you can adjust the airflow and speed. Select the settings from Table1 according to the location in which you want to install the unit.

- Decide on the pattern of the airflow direction.

<Table 1>	4-direction	3-direction	2-direction
Blowout direction pattern	Pattern 1 Initial setting 	Pattern 4 1 air outlet fully closed 	Pattern 6 2 air outlet fully closed 

Note1.

For 3- and 2-direction settings, please use the air outlet shutter plate (option).

- According to the number of air outlets and height of the ceiling to install the unit, be sure to set up the switch (SW21) on the circuit board to the appropriate setting.

- Correspondence of ceiling heights to the number of air outlets

SW21	SW14	SW12	SW11	SW22	SW1	SW2	SW3
ON OFF 1 6	ON OFF 1 6	ON OFF 1 6	ON OFF 1 6	ON OFF 1 4	1 0	1 6	1 0

			PLFY-P32/40/50/63/80VEM-A-PA-DA-TH						PLFY-P100/125VEM-A-PA-DA-TH						
			Silent		Standard		High ceiling		Silent		Standard		High ceiling		
			SW21-1	SW21-2	SW21-1	SW21-2	SW21-1	SW21-2	SW21-1	SW21-2	SW21-1	SW21-2	SW21-1	SW21-2	
4 direction	SW21-3	OFF	2.5 m			2.7 m			3.5 m			2.7 m			
	SW21-4	ON													
3 direction	SW21-3	OFF	2.7 m			3.0 m			3.5 m			3.0 m			
	SW21-4	OFF													
2 direction	SW21-3	ON	3.0 m			3.3 m			3.5 m			3.3 m			
	SW21-4	OFF													

4-2. BRANCH DUCT HOLE AND FRESH AIR INTAKE HOLE

At the time of installation, use the duct holes (cut out) located at the positions shown in following diagram, as and when required.

- A fresh air intake hole for the optional multi-functional casement can also be made.

Note:


The figures marked with * in the drawing below represent the dimensions of the main unit excluding those of the optional multifunctional casement.

When installing the optional multifunctional casement, add 135 mm to the dimensions marked on the figure.

When installing the branch ducts, be sure to insulate adequately.

Otherwise, condensation and dripping may occur.

Unit : mm




4-3. OPERATION IN CONJUNCTION WITH DUCT FAN (Booster fan)

- Whenever the indoor unit is operating, the duct fan also operates.

- (1) Connect the optional multiple remote controller adapter (PAC-SA88HA-E) to the connector CN51 on the indoor controller board.
- (2) Drive the relay after connecting the 12 V DC relay between the Yellow and Orange connector lines.

MB: Electromagnetic switch power relay for duct fan.


X: Auxiliary relay (For 12 V DC, coil rating: 1.0W or smaller)




4-4. FRESH AIR INTAKE AMOUNT & STATIC PRESSURE CHARACTERISTICS

① PLFY-P32/40/50/63/80VEM-A/-PA/-DA/-TH.TH


Taking air into the unit



Multi-functional casement + Standard filter




Multi-functional casement + High efficiency filter




② PLFY-P100/125VEM-A/-PA/-DA/-TH.TH


Taking air into the unit




Multi-functional casement + Standard filter



Multi-functional casement + High efficiency filter



How to read curves




- Q...Designed amount of fresh air intake $<\text{m}^3/\text{min}>$
- A...Static pressure loss of fresh air intake air duct system with airflow amount Q $<\text{Pa}>$
- B...Forced static pressure at air conditioner inlet with airflow amount Q $<\text{Pa}>$
- C...Static pressure of booster fan with airflow amount Q $<\text{Pa}>$
- D...Static pressure loss increase amount of fresh air intake duct system for airflow amount Q $<\text{Pa}>$
- E...Static pressure of indoor unit with airflow amount Q $<\text{Pa}>$
- Qa...Estimated amount of fresh air intake without D $<\text{m}^3/\text{min}>$

OUTLINES AND DIMENSIONS

**PLFY-P32VEM-A/-PA/-DA/-TH.TH
PLFY-P50VEM-A/-PA/-DA/-TH.TH
PLFY-P80VEM-A/-PA/-DA/-TH.TH
PLFY-P125VEM-A/-PA/-DA/-TH.TH**

**PLFY-P40VEM-A/-PA/-DA/-TH.TH
PLFY-P63VEM-A/-PA/-DA/-TH.TH
PLFY-P100VEM-A/-PA/-DA/-TH.TH**

Unit: mm



PLFY-P32VEM-A.TH PLFY-P40VEM-A.TH PLFY-P50VEM-A.TH PLFY-P63VEM-A.TH
 PLFY-P80VEM-A.TH PLFY-P100VEM-A.TH PLFY-P125VEM-A.TH

[LEGEND]

SYMBOL	NAME	SYMBOL	NAME
DP	DRAIN PUMP	OPTION PART	
FS	DRAIN FLOAT SWITCH	MT	I-SEE SENSOR MOTOR
I.B	INDOOR CONTROLLER BOARD	W.B	PCB FOR WIRELESS REMOTE CONTROLLER
CN27	CONNECTOR	BZ	BUZZER
CN32	DAMPER	LED1	LED (OPERATION INDICATION : GREEN)
CN51	REMOTE SWITCH	LED2	LED (PREPARATION FOR HEATING : ORANGE)
CN52	CENTRALLY CONTROL	RU	RECEIVING UNIT
F1	REMOTE INDICATION	SW1	EMERGENCY OPERATION (HEAT/DOWN)
SW1	FUSE (T 6.3AL 250V)	SW2	EMERGENCY OPERATION (COOL/UP)
SW11	SWITCH	TB15	TERMINAL BLOCK
SW12	MODE SELECTION	BLOCK	MA-REMOTE CONTROLLER
SW14	ADDRESS SETTING 1s DIGIT		POWER SUPPLY
SW2	ADDRESS SETTING 10s DIGIT		TRANSMISSION
SW21	BRANCH NO.	TH21	THERMISTOR
	CAPACITY CODE		ROOM TEMP. DETECTION (0°C / 15kΩ, 25°C / 5.4kΩ)
	CEILING HEIGHT	TH22	PIPE TEMP. DETECTION/LIQUID (0°C / 15kΩ, 25°C / 5.4kΩ)
	DISCHARGE OUTLET NUMBER		PIPE TEMP. DETECTION/GAS (0°C / 15kΩ, 25°C / 5.4kΩ)
SW22	OPTION SELECTOR	TH23	
SW23	PAIR NO. SETTING		
SW24	MODE SELECTION		
	DRAIN PUMP (TEST MODE)		
LEV	LINEAR EXPANSION VALVE		
MF	FAN MOTOR		
MV	VANE MOTOR		

NOTES:


- At servicing for outdoor unit, always follow the wiring diagram of outdoor unit.
- In case of using MA-Remote controller, please connect to TB15. (Remote controller wire is non-polar.)
- In case of using ME-Remote controller, please connect to TB5. (Transmission line is non-polar.)
- Symbol [S] of TB5 is the shield wire connection.
- Symbols used in wiring diagram above are,
[] : terminal block, [o o o] : connector.
- The setting of SW2 differs in the capacity and model.
For the detail, refer to the table 1.
- Make sure to turn off the indoor and the outdoor units before replacing indoor controller board.
- is the switch position.

LED on indoor board for service

Mark	Meaning	Function
LED1	Main power supply	Main Power supply (Indoor unit:220-240V AC) power on → lamp is lit
LED2	Power supply for MA-Remote controller	Power supply for MA-Remote controller on → lamp is lit

<Table 1> SW2 (CAPACITY CODE)

MODELS	SW2	MODELS	SW2	MODELS	SW2
32	ON OFF 1 2 3 4 5 6	63	ON OFF 1 2 3 4 5 6	125	ON OFF 1 2 3 4 5 6
40	ON OFF 1 2 3 4 5 6	80	ON OFF 1 2 3 4 5 6		
50	ON OFF 1 2 3 4 5 6	100	ON OFF 1 2 3 4 5 6		



PLFY-P32VEM-PA.TH PLFY-P40VEM-PA.TH PLFY-P50VEM-PA.TH PLFY-P63VEM-PA.TH
PLFY-P80VEM-PA.TH PLFY-P100VEM-PA.TH PLFY-P125VEM-PA.TH

[LEGEND]

SYMBOL	NAME	SYMBOL	NAME
DP	DRAIN PUMP	OPTION PART	
FS	DRAIN FLOAT SWITCH	MT	I-SEE SENSOR MOTOR
I. B	INDOOR CONTROLLER BOARD	W.B	PCB FOR WIRELESS REMOTE CONTROLLER
CN27	CONNECTOR	BZ	BUZZER
CN32	DAMPER	LED1	LED (OPERATION INDICATION : GREEN)
CN51	REMOTE SWITCH	LED2	LED (PREPARATION FOR HEATING : ORANGE)
CN52	CENTRALLY CONTROL	RU	RECEIVING UNIT
F1	REMOTE INDICATION	SW1	EMERGENCY OPERATION (HEAT/DOWN)
SW1	FUSE (T 6.3AL 250V)	SW2	EMERGENCY OPERATION (COOL/UP)
SW11	SWITCH	TB15	TERMINAL BLOCK
SW12	MODE SELECTION	TB2	MA-REMOTE CONTROLLER
SW14	ADDRESS SETTING 1s DIGIT	TB5	POWER SUPPLY
SW2	ADDRESS SETTING 10s DIGIT	TH21	TRANSMISSION
SW21	BRANCH NO.	TH22	ROOM TEMP. DETECTION (0°C / 15kΩ, 25°C / 5.4kΩ)
SW22	CAPACITY CODE	TH23	PIPE TEMP. DETECTION/LIQUID (0°C / 15kΩ, 25°C / 5.4kΩ)
SW3	CEILING HEIGHT		PIPE TEMP. DETECTION/GAS (0°C / 15kΩ, 25°C / 5.4kΩ)
SWE	DISCHARGE OUTLET NUMBER		
LEV	OPTION SELECTOR		
MF	PAIR NO. SETTING		
MV	SW2		
	MODE SELECTION		
	DRAIN PUMP (TEST MODE)		

NOTES:


- At servicing for outdoor unit, always follow the wiring diagram of outdoor unit.
- In case of using MA-Remote controller, please connect to TB15. (Remote controller wire is non-polar.)
- In case of using ME-Remote controller, please connect to TB5. (Transmission line is non-polar.)
- Symbol [S] of TB5 is the shield wire connection.
- Symbols used in wiring diagram above are,
[] : terminal block, [o o o] : connector.
- The setting of SW2 differs in the capacity and model.
For the detail, refer to the table 1.
- Make sure to turn off the indoor and the outdoor units before replacing indoor controller board.
- is the switch position.

LED on indoor board for service

Mark	Meaning	Function
LED1	Main power supply	Main Power supply (Indoor unit:220-240V AC) power on → lamp is lit
LED2	Power supply for MA-Remote controller	Power supply for MA-Remote controller on → lamp is lit

<Table 1> SW2 (CAPACITY CODE)

MODELS	SW2	MODELS	SW2	MODELS	SW2
32	ON OFF 1 2 3 4 5 6	63	ON OFF 1 2 3 4 5 6	125	ON OFF 1 2 3 4 5 6
40	ON OFF 1 2 3 4 5 6	80	ON OFF 1 2 3 4 5 6		
50	ON OFF 1 2 3 4 5 6	100	ON OFF 1 2 3 4 5 6		



**PLFY-P32VEM-DA.TH PLFY-P40VEM-DA.TH PLFY-P50VEM-DA.TH PLFY-P63VEM-DA.TH
PLFY-P80VEM-DA.TH PLFY-P100VEM-DA.TH PLFY-P125VEM-DA.TH**

[LEGEND]

SYMBOL	NAME	SYMBOL	NAME
DP	DRAIN PUMP	OPTION PART	
FS	DRAIN FLOAT SWITCH	MT	I-SEE SENSOR MOTOR
I. B	INDOOR CONTROLLER BOARD	W.B	PCB FOR WIRELESS REMOTE CONTROLLER
CN27	CONNECTOR DAMPER	BZ	BUZZER
CN32	REMOTE SWITCH	LED1	LED (OPERATION INDICATION : GREEN)
CN51	CENTRALLY CONTROL	LED2	LED (PREPARATION FOR HEATING : ORANGE)
CN52	REMOTE INDICATION	RU	RECEIVING UNIT
F1	FUSE (T 6.3AL 250V)	SW1	EMERGENCY OPERATION (HEAT/DOWN)
SW1	SWITCH MODE SELECTION	SW2	EMERGENCY OPERATION (COOL/UP)
SW11	ADDRESS SETTING 1s DIGIT	TB15	TERMINAL BLOCK
SW12	ADDRESS SETTING 10s DIGIT	TB2	MA-REMOTE CONTROLLER
SW14	BRANCH NO.	TB5	POWER SUPPLY
SW2	CAPACITY CODE	TH21	TRANSMISSION
SW21	CEILING HEIGHT	TH22	ROOM TEMP. DETECTION (0°C / 15kΩ, 25°C / 5.4kΩ)
	DISCHARGE OUTLET NUMBER	TH23	PIPE TEMP. DETECTION/LIQUID (0°C / 15kΩ, 25°C / 5.4kΩ)
SW22	OPTION SELECTOR		PIPE TEMP. DETECTION/GAS (0°C / 15kΩ, 25°C / 5.4kΩ)
SW3	PAIR NO. SETTING		
SW4	MODE SELECTION		
SW5	DRAIN PUMP (TEST MODE)		
LEV	LINEAR EXPANSION VALVE		
MF	FAN MOTOR		
MV	VANE MOTOR		

NOTES:


- At servicing for outdoor unit, always follow the wiring diagram of outdoor unit.
- In case of using MA-Remote controller, please connect to TB15. (Remote controller wire is non-polar.)
- In case of using ME-Remote controller, please connect to TB5. (Transmission line is non-polar.)
- Symbol [S] of TB5 is the shield wire connection.
- Symbols used in wiring diagram above are,
[] : terminal block, [o o o] : connector.
- The setting of SW2 differs in the capacity and model. For the detail, refer to the table 1.
- Make sure to turn off the indoor and the outdoor units before replacing indoor controller board.
- is the switch position.

LED on indoor board for service

Mark	Meaning	Function
LED1	Main power supply	Main Power supply (Indoor unit:220-240V AC) power on → lamp is lit
LED2	Power supply for MA-Remote controller	Power supply for MA-Remote controller on → lamp is lit

<Table 1> SW2 (CAPACITY CODE)

MODELS	SW2	MODELS	SW2	MODELS	SW2
32	ON OFF 1 2 3 4 5 6	63	ON OFF 1 2 3 4 5 6	125	ON OFF 1 2 3 4 5 6
40	ON OFF 1 2 3 4 5 6	80	ON OFF 1 2 3 4 5 6		
50	ON OFF 1 2 3 4 5 6	100	ON OFF 1 2 3 4 5 6		



PLFY-P32VEM-TH.TH PLFY-P40VEM-TH.TH PLFY-P50VEM-TH.TH PLFY-P63VEM-TH.TH

PLFY-P80VEM-TH.TH PLFY-P100VEM-TH.TH PLFY-P125VEM-TH.TH

คำอธิบายสัญลักษณ์

สัญลักษณ์	ชื่อ	สัญลักษณ์	ชื่อ
DP	ปั๊มน้ำทึบตื้ง	อุปกรณ์เสริม	
FS	สวิตซ์กูล์เบร์บาน้ำทึบตื้ง	MT	มอเตอร์สำหรับ I-SEE เซ็นเซอร์
I. B	แม่ควบคุมเครื่องภายนอกอาคาร	W.B	แผ่นวงจรสำหรับรีโมทคอนโทรลแบบไร้สาย
CN27	คอนเนคเตอร์	BZ	กริ๊งสัญญาณ
CN32	คอมเพรสเซอร์	LED1	ไฟสัญญาณ LED แสดงการทำงาน (ไฟสีเขียว)
CN51	อินดิกเตอร์ไฟ	LED2	ไฟสัญญาณ LED แสดงการทำงาน (ไฟสีเหลือง)
CN52	ควบคุมส่วนกลาง	RU	ชุดรีเซ็ตสัญญาณ
F1	สเปรย์ (T6.3AL250V)	SW1	การทำงานระบบอุกเดิน (หัวความร้อน/คงคลัง)
SW1	สวิตซ์	SW2	การทำงานระบบอุกเดิน (หัวความร้อน/ไฟฟ้า)
SW11	การตั้งค่าที่ต่ำ 1s หลัก	TB15	ฐานสีขาว MA-รีโมทคอนโทรล
SW12	การตั้งค่าที่ต่ำ 10s หลัก	TB2	สายไฟ
SW14	การตัดแยกเครื่องภายนอกอาคาร	TB5	ส่งสัญญาณ
SW2	ความสมารถดักความร้อนตามรุ่น	TH21	เทอร์มิสเตอร์
SW21	ความสูงเพดาน	TH22	เทอร์มิสเตอร์ตัวร้อนวัดอุณหภูมิห้อง (0°C / $15\text{k}\Omega$, 25°C / $5.4\text{k}\Omega$)
SW22	ระหว่างทางทั้งสองห้องท่ออัด	TH23	เทอร์มิสเตอร์ตัวร้อนห้อง (0°C / $15\text{k}\Omega$, 25°C / $5.4\text{k}\Omega$)
SW3	การเลือกกระแสไฟ		
SWE	ปั๊มน้ำทึบตื้ง (ให้หมดทดสอบ)		
LEV	วาล์วขยายทัวเร็วตัวเดี่ยว		
MF	มอเตอร์พัดลม		
MV	มอเตอร์สำหรับปรับระดับลม		

ไฟสัญญาณ LED บนแผงควบคุมเครื่องภายนอกอาคารสำหรับการบำรุงรักษา


เครื่องหมาย	ความหมาย	การใช้งาน
LED1	แหล่งจ่ายไฟหลัก	แหล่งจ่ายไฟหลัก (เครื่องภายนอกอาคาร 220-240V AC) เปิด → ไฟสว่าง
LED2	แหล่งจ่ายไฟ สำหรับ MA-รีโมทคอนโทรล	แหล่งจ่ายไฟ สำหรับ MA-รีโมทคอนโทรล เปิด → ไฟสว่าง

หมายเหตุ :

- ในการบำรุงรักษาเครื่องภายนอกอาคาร ควรปฏิบัติตามแผนผังวงจรไฟฟ้า ของเครื่องภายนอกอาคารเสมอ
- ในกรณีที่ใช้ MA-รีโมทคอนโทรล กรุณาเชื่อมต่อสายไฟที่ TB15 (การต่อสายไฟของรีโมทคอนโทรล ไม่ต้องคำนึงถึงขั้วสายไฟ)
- ในกรณีที่ใช้ ME-รีโมทคอนโทรล กรุณาเชื่อมต่อสายไฟที่ TB15 (การต่อสายส่งสัญญาณไม่ต้องคำนึงถึงขั้วสายไฟ)
- สัญลักษณ์ [S] ของ TB5 คือการเชื่อมต่อด้วยสาย Shield
- สัญลักษณ์ที่ใช้ในแผนผังจะไฟฟ้า : ฐานเสียบขั้วสายไฟ : คอนเนคเตอร์
- การตั้งค่าของ SW2 แตกต่างกันในการสามารถ ในการทำความเย็นและรุ่น สำหรับรายละเอียด ดังอ้างอิงตารางที่ 1
- ตรวจสอบให้แน่ใจว่าได้ปิดการทำงาน เครื่องภายนอกอาคาร และ เครื่องภายนอกอาคาร ก่อนทำการเปลี่ยนแผงควบคุมภายนอกอาคาร
- คือตำแหน่งของสวิตซ์


<ตาราง 1> SW2 (รหัสความสามารถทำความเย็นตามรุ่น)

รุ่น	SW2	รุ่น	SW2	รุ่น	SW2
32	ON OFF 1 2 3 4 5 6	63	ON OFF 1 2 3 4 5 6	125	ON OFF 1 2 3 4 5 6
40	ON OFF 1 2 3 4 5 6	80	ON OFF 1 2 3 4 5 6		
50	ON OFF 1 2 3 4 5 6	100	ON OFF 1 2 3 4 5 6		



REFRIGERANT SYSTEM DIAGRAM


PLFY-P32VEM-A/-PA/-DA/-TH.TH PLFY-P40VEM-A/-PA/-DA/-TH.TH PLFY-P50VEM-A/-PA/-DA/-TH.TH
 PLFY-P63VEM-A/-PA/-DA/-TH.TH PLFY-P80VEM-A/-PA/-DA/-TH.TH PLFY-P100VEM-A/-PA/-DA/-TH.TH
 PLFY-P125VEM-A/-PA/-DA/-TH.TH



Unit : mm (inch)		
Service Ref. Item	PLFY-P32/40/50VEM-A/-PA/-DA/-TH.TH	PLFY-P63/80/100/125VEM-A/-PA/-DA/-TH.TH
Gas pipe	$\phi 12.7$ (1/2)	$\phi 15.88$ (5/8)
Liquid pipe	$\phi 6.35$ (1/4)	$\phi 9.52$ (3/8)

8-1. HOW TO CHECK THE PARTS

PLFY-P32VEM-A/-PA/-DA/-TH.TH PLFY-P40VEM-A/-PA/-DA/-TH.TH PLFY-P50VEM-A/-PA/-DA/-TH.TH
 PLFY-P63VEM-A/-PA/-DA/-TH.TH PLFY-P80VEM-A/-PA/-DA/-TH.TH PLFY-P100VEM-A/-PA/-DA/-TH.TH
 PLFY-P125VEM-A/-PA/-DA/-TH.TH


Parts name	Check points											
Room temperature detection thermistor (TH21) Pipe temperature detection thermistor/liquid (TH22) Pipe temperature detection thermistor/gas (TH23)	Disconnect the connectors, then measure the resistance with a tester. (At ambient temperatures of 10 to 30°C) <table border="1" style="margin-left: auto; margin-right: auto;"> <tr> <td>Normal</td> <td>Abnormal</td> </tr> <tr> <td>4.3–9.6 kΩ</td> <td>Open or short</td> </tr> </table> (Refer to "8-1-1. Thermistor".)			Normal	Abnormal	4.3–9.6 kΩ	Open or short					
Normal	Abnormal											
4.3–9.6 kΩ	Open or short											
Vane motor (MV)	Measure the resistance between the terminals with a tester. (At ambient temperatures of 20 to 30°C) <table border="1" style="margin-left: auto; margin-right: auto;"> <tr> <th>Connector</th> <th>Normal</th> <th>Abnormal</th> </tr> <tr> <td>Red - Yellow (⑤-③, ⑩-⑧, ⑯-⑬, ⑳-⑲)</td> <td rowspan="4" style="text-align: center;">300 Ω</td> <td rowspan="4" style="text-align: center;">Open or short</td> </tr> <tr> <td>Red - Blue (⑤-①, ⑩-⑥, ⑯-⑪, ⑳-⑯)</td> </tr> <tr> <td>Red - Orange (⑤-④, ⑩-⑨, ⑯-⑭, ⑳-⑯)</td> </tr> <tr> <td>Red - White (⑤-②, ⑩-⑦, ⑯-⑫, ⑳-⑰)</td> </tr> </table>			Connector	Normal	Abnormal	Red - Yellow (⑤-③, ⑩-⑧, ⑯-⑬, ⑳-⑲)	300 Ω	Open or short	Red - Blue (⑤-①, ⑩-⑥, ⑯-⑪, ⑳-⑯)	Red - Orange (⑤-④, ⑩-⑨, ⑯-⑭, ⑳-⑯)	Red - White (⑤-②, ⑩-⑦, ⑯-⑫, ⑳-⑰)
Connector	Normal	Abnormal										
Red - Yellow (⑤-③, ⑩-⑧, ⑯-⑬, ⑳-⑲)	300 Ω	Open or short										
Red - Blue (⑤-①, ⑩-⑥, ⑯-⑪, ⑳-⑯)												
Red - Orange (⑤-④, ⑩-⑨, ⑯-⑭, ⑳-⑯)												
Red - White (⑤-②, ⑩-⑦, ⑯-⑫, ⑳-⑰)												
Drain pump (DP)	① Check if the drain float switch works properly. ② Check if the drain pump works and drains water properly in cooling operation. ③ If no water drains, confirm that the check code 2502 will not be displayed 10 minutes after the operation starts. Note: The drain pump for this model is driven by the internal DC motor of controller board, so it is not possible to measure the resistance between the terminals. Normal Red-Black: Input 13 V DC → The fan starts to rotate. Purple-Black: Abnormal (check code 2502) if it outputs 0–13 V square wave (5 pulses/rotation), and the number of rotation is not normal.											
Drain float switch (FS)	Measure the resistance between the terminals with a tester. <table border="1" style="margin-left: auto; margin-right: auto;"> <tr> <th>State of moving part</th> <th>Normal</th> <th>Abnormal</th> </tr> <tr> <td>UP</td> <td>Short</td> <td>Other than short</td> </tr> <tr> <td>DOWN</td> <td>Open</td> <td>Other than open</td> </tr> </table> 			State of moving part	Normal	Abnormal	UP	Short	Other than short	DOWN	Open	Other than open
State of moving part	Normal	Abnormal										
UP	Short	Other than short										
DOWN	Open	Other than open										
i-see Sensor	Turn the power ON while the i-see Sensor connector is connected to the CN4Z on indoor controller board. A communication between the indoor controller board and i-see Sensor board is made to detect the connection. Normal: When the operation starts, the motor for i-see Sensor is driven to rotate the i-see Sensor. Abnormal: The motor for i-see Sensor is not driven when the operation starts. Note: The voltage between the terminals cannot be measured accurately since it is pulse output.											
i-see Sensor motor (MT) (Option)	Measure the resistance between the terminals with a tester. (At ambient temperatures of 20 to 30°C) <table border="1" style="margin-left: auto; margin-right: auto;"> <tr> <th>Connector</th> <th>Normal</th> <th>Abnormal</th> </tr> <tr> <td>Red - Yellow</td> <td rowspan="4" style="text-align: center;">250 Ω</td> <td rowspan="4" style="text-align: center;">Open or short</td> </tr> <tr> <td>Red - Blue</td> </tr> <tr> <td>Red - Orange</td> </tr> <tr> <td>Red - White</td> </tr> </table>			Connector	Normal	Abnormal	Red - Yellow	250 Ω	Open or short	Red - Blue	Red - Orange	Red - White
Connector	Normal	Abnormal										
Red - Yellow	250 Ω	Open or short										
Red - Blue												
Red - Orange												
Red - White												
Linear expansion valve (LEV)	Disconnect the connector then measure the resistance valve with a tester. (At the coil temperatures of 10 to 30°C) <table border="1" style="margin-left: auto; margin-right: auto;"> <tr> <th>Connector</th> <th>Normal</th> <th>Abnormal</th> </tr> <tr> <td>White-Red</td> <td rowspan="4" style="text-align: center;">200 Ω ± 10%</td> <td rowspan="4" style="text-align: center;">Open or short</td> </tr> <tr> <td>Yellow-Brown</td> </tr> <tr> <td>Orange-Red</td> </tr> <tr> <td>Blue-Brown</td> </tr> </table>			Connector	Normal	Abnormal	White-Red	200 Ω ± 10%	Open or short	Yellow-Brown	Orange-Red	Blue-Brown
Connector	Normal	Abnormal										
White-Red	200 Ω ± 10%	Open or short										
Yellow-Brown												
Orange-Red												
Blue-Brown												
Refer to "8-1-2. Linear expansion valve".												

8-1-1. Thermistor

<Thermistor characteristic graph>

Thermistor for lower temperature

- Room temperature detection thermistor (TH21)
- Pipe temperature detection thermistor/liquid (TH22)
- Pipe temperature detection thermistor/gas (TH23)



Thermistor $R_0=15 \text{ k}\Omega \pm 3\%$

Fixed number of $B=3480 \pm 2\%$

$$R_t = 15 \exp \left\{ 3480 \left(\frac{1}{273+t} - \frac{1}{273} \right) \right\}$$


0°C	15 kΩ
10°C	9.6 kΩ
20°C	6.3 kΩ
25°C	5.4 kΩ
30°C	4.3 kΩ
40°C	3.0 kΩ

8-1-2. Linear expansion valve

① Operation summary of the linear expansion valve

- Linear expansion valves open/close through the use of a stepping motor after receiving the pulse signal from the indoor controller board.
- Valve position can be changed in proportion to the number of pulse signals.


<Connection between the indoor controller board and the linear expansion valve>





<Output pulse signal and the valve operation>

Output (Phase)	Output			
	1	2	3	4
$\phi 1$	ON	OFF	OFF	ON
$\phi 2$	ON	ON	OFF	OFF
$\phi 3$	OFF	ON	ON	OFF
$\phi 4$	OFF	OFF	ON	ON

② Linear expansion valve operation



③ Troubleshooting

Symptom	Check points	Countermeasures
Operation circuit failure of the micro processor	Disconnect the connector on the controller board, then connect LED for checking.  When power is turned on, pulse signals will output for 10 seconds. There must be some defects in the operation circuit if the LED does not light while the signals are output or keeps lighting even after the signals stop.	Exchange the indoor controller board at drive circuit failure.
Linear expansion valve mechanism is locked.	Motor will idle and make a ticking noise when the motor is operated while the linear expansion valve is locked. This ticking sound is a sign of abnormality.	Exchange the linear expansion valve.
Short or breakage of the motor coil of the linear expansion valve	Measure the resistance between each coil (white-red, yellow-brown, orange-red, blue-brown) using a tester. It is normal if the resistance is in the range of $200\Omega \pm 10\%$.	Exchange the linear expansion valve.
Valve does not close completely.	To check the linear expansion valve, operate the indoor unit in fan mode and at the same time operate the other indoor units in cooling mode, then check the pipe temperature <liquid pipe temperature> of the indoor unit by the outdoor multi controller board operation monitor. During fan operation, linear expansion valve is closed completely and if there is any leaking, detecting temperature of the thermistor will go lower. If the detected temperature is much lower than the temperature indicated on the remote controller, it means the valve is not closed all the way.  It is not necessary to exchange the linear expansion valve, if the leakage is small and not affecting normal operation.	If a large amount of refrigerant is leaked, exchange the linear expansion valve.
Wrong connection of the connector or contact failure	Check the color of lead wire and missing terminal of the connector.	Disconnect the connector on the controller board, then check for continuity.

8-1-3. DC Fan motor (fan motor/indoor controller board)


Check method of indoor fan motor (fan motor/indoor controller board)

① Notes

- High voltage is applied to the connector (CNMF) for the fan motor. Pay attention to the service.
- Do not pull out the connector (CNMF) for the motor with the power supply on.
(It causes trouble of the indoor controller board and fan motor)

② Self check

Conditions : The indoor fan cannot rotate.



8-2. FUNCTION OF DIP SWITCH

The black square (■) indicates a switch position.

<PLFY-P32/40/50/63/80/100/125VEM-A.TH>

Switch	Pole	Function	Operation by switch		Effective timing	Remarks																						
			ON	OFF																								
SW1 Function Selection	1	Thermistor <Room temperature detection> position	Built-in remote controller	Indoor unit	Under suspension	<p>Address board</p> <p><Initial setting></p> <p>ON [] [■] [] [] [] [] [] [] [] [] OFF [■] [] [] [] [] [] [] [] [] [] 1 2 3 4 5 6 7 8 9 0</p> <p>*1 Refer to <Table A> below.</p>																						
	2	Filter clogging detection	Provided	Not provided																								
	3	Filter cleaning	2,500 hr	100 hr																								
	4	Fresh air intake	Effective	Not effective																								
	5	Switching remote display	Thermo-ON signal display	Indicating fan operation ON/OFF																								
	6	—	—	—																								
	7	Air flow set in case of thermo-OFF at heating mode	Low*1	Extra low*1																								
	8		Setting airflow*1	Depends on SW1-7																								
	9	Auto restart function	Effective	Not effective																								
	0	Power ON/OFF by breaker	Effective	Not effective																								
SW2 Capacity code setting	1–6	<table border="1"> <tr> <td>MODELS</td> <td>SW2</td> <td>MODELS</td> <td>SW2</td> <td>MODELS</td> <td>SW2</td> </tr> <tr> <td>32</td> <td>ON [] [■] [] [] [] OFF [] [] [] [] [] 1 2 3 4 5 6</td> <td>40</td> <td>ON [] [] [■] [] [] OFF [] [] [] [] [] 1 2 3 4 5 6</td> <td>50</td> <td>ON [] [] [■] [] [] OFF [] [] [] [] [] 1 2 3 4 5 6</td> </tr> <tr> <td>63</td> <td>ON [] [■] [] [] [] OFF [] [] [] [] [] 1 2 3 4 5 6</td> <td>80</td> <td>ON [] [] [] [■] [] OFF [] [] [] [] [] 1 2 3 4 5 6</td> <td>100</td> <td>ON [] [] [] [] [■] OFF [] [] [] [] [] 1 2 3 4 5 6</td> </tr> <tr> <td>125</td> <td>ON [] [] [■] [] [] OFF [] [] [] [] [] 1 2 3 4 5 6</td> <td></td> <td></td> <td></td> <td></td> </tr> </table>			MODELS	SW2	MODELS	SW2	MODELS	SW2	32	ON [] [■] [] [] [] OFF [] [] [] [] [] 1 2 3 4 5 6	40	ON [] [] [■] [] [] OFF [] [] [] [] [] 1 2 3 4 5 6	50	ON [] [] [■] [] [] OFF [] [] [] [] [] 1 2 3 4 5 6	63	ON [] [■] [] [] [] OFF [] [] [] [] [] 1 2 3 4 5 6	80	ON [] [] [] [■] [] OFF [] [] [] [] [] 1 2 3 4 5 6	100	ON [] [] [] [] [■] OFF [] [] [] [] [] 1 2 3 4 5 6	125	ON [] [] [■] [] [] OFF [] [] [] [] [] 1 2 3 4 5 6				
MODELS	SW2	MODELS	SW2	MODELS	SW2																							
32	ON [] [■] [] [] [] OFF [] [] [] [] [] 1 2 3 4 5 6	40	ON [] [] [■] [] [] OFF [] [] [] [] [] 1 2 3 4 5 6	50	ON [] [] [■] [] [] OFF [] [] [] [] [] 1 2 3 4 5 6																							
63	ON [] [■] [] [] [] OFF [] [] [] [] [] 1 2 3 4 5 6	80	ON [] [] [] [■] [] OFF [] [] [] [] [] 1 2 3 4 5 6	100	ON [] [] [] [] [■] OFF [] [] [] [] [] 1 2 3 4 5 6																							
125	ON [] [] [■] [] [] OFF [] [] [] [] [] 1 2 3 4 5 6																											
<table border="1"> <tr> <td>MODELS</td> <td>SW2</td> <td>MODELS</td> <td>SW2</td> <td>MODELS</td> <td>SW2</td> </tr> <tr> <td>32</td> <td>ON [] [■] [] [] [] OFF [] [] [] [] [] 1 2 3 4 5 6</td> <td>40</td> <td>ON [] [] [■] [] [] OFF [] [] [] [] [] 1 2 3 4 5 6</td> <td>50</td> <td>ON [] [] [■] [] [] OFF [] [] [] [] [] 1 2 3 4 5 6</td> </tr> <tr> <td>63</td> <td>ON [] [■] [] [] [] OFF [] [] [] [] [] 1 2 3 4 5 6</td> <td>80</td> <td>ON [] [] [] [■] [] OFF [] [] [] [] [] 1 2 3 4 5 6</td> <td>100</td> <td>ON [] [] [] [] [■] OFF [] [] [] [] [] 1 2 3 4 5 6</td> </tr> <tr> <td>125</td> <td>ON [] [] [■] [] [] OFF [] [] [] [] [] 1 2 3 4 5 6</td> <td></td> <td></td> <td></td> <td></td> </tr> </table>			MODELS	SW2	MODELS	SW2	MODELS	SW2	32	ON [] [■] [] [] [] OFF [] [] [] [] [] 1 2 3 4 5 6	40	ON [] [] [■] [] [] OFF [] [] [] [] [] 1 2 3 4 5 6	50	ON [] [] [■] [] [] OFF [] [] [] [] [] 1 2 3 4 5 6	63	ON [] [■] [] [] [] OFF [] [] [] [] [] 1 2 3 4 5 6	80	ON [] [] [] [■] [] OFF [] [] [] [] [] 1 2 3 4 5 6	100	ON [] [] [] [] [■] OFF [] [] [] [] [] 1 2 3 4 5 6	125	ON [] [] [■] [] [] OFF [] [] [] [] [] 1 2 3 4 5 6						
MODELS	SW2	MODELS	SW2	MODELS	SW2																							
32	ON [] [■] [] [] [] OFF [] [] [] [] [] 1 2 3 4 5 6	40	ON [] [] [■] [] [] OFF [] [] [] [] [] 1 2 3 4 5 6	50	ON [] [] [■] [] [] OFF [] [] [] [] [] 1 2 3 4 5 6																							
63	ON [] [■] [] [] [] OFF [] [] [] [] [] 1 2 3 4 5 6	80	ON [] [] [] [■] [] OFF [] [] [] [] [] 1 2 3 4 5 6	100	ON [] [] [] [] [■] OFF [] [] [] [] [] 1 2 3 4 5 6																							
125	ON [] [] [■] [] [] OFF [] [] [] [] [] 1 2 3 4 5 6																											
<table border="1"> <tr> <td>MODELS</td> <td>SW2</td> <td>MODELS</td> <td>SW2</td> <td>MODELS</td> <td>SW2</td> </tr> <tr> <td>32</td> <td>ON [] [■] [] [] [] OFF [] [] [] [] [] 1 2 3 4 5 6</td> <td>40</td> <td>ON [] [] [■] [] [] OFF [] [] [] [] [] 1 2 3 4 5 6</td> <td>50</td> <td>ON [] [] [■] [] [] OFF [] [] [] [] [] 1 2 3 4 5 6</td> </tr> <tr> <td>63</td> <td>ON [] [■] [] [] [] OFF [] [] [] [] [] 1 2 3 4 5 6</td> <td>80</td> <td>ON [] [] [] [■] [] OFF [] [] [] [] [] 1 2 3 4 5 6</td> <td>100</td> <td>ON [] [] [] [] [■] OFF [] [] [] [] [] 1 2 3 4 5 6</td> </tr> <tr> <td>125</td> <td>ON [] [] [■] [] [] OFF [] [] [] [] [] 1 2 3 4 5 6</td> <td></td> <td></td> <td></td> <td></td> </tr> </table>			MODELS	SW2	MODELS	SW2	MODELS	SW2	32	ON [] [■] [] [] [] OFF [] [] [] [] [] 1 2 3 4 5 6	40	ON [] [] [■] [] [] OFF [] [] [] [] [] 1 2 3 4 5 6	50	ON [] [] [■] [] [] OFF [] [] [] [] [] 1 2 3 4 5 6	63	ON [] [■] [] [] [] OFF [] [] [] [] [] 1 2 3 4 5 6	80	ON [] [] [] [■] [] OFF [] [] [] [] [] 1 2 3 4 5 6	100	ON [] [] [] [] [■] OFF [] [] [] [] [] 1 2 3 4 5 6	125	ON [] [] [■] [] [] OFF [] [] [] [] [] 1 2 3 4 5 6						
MODELS	SW2	MODELS	SW2	MODELS	SW2																							
32	ON [] [■] [] [] [] OFF [] [] [] [] [] 1 2 3 4 5 6	40	ON [] [] [■] [] [] OFF [] [] [] [] [] 1 2 3 4 5 6	50	ON [] [] [■] [] [] OFF [] [] [] [] [] 1 2 3 4 5 6																							
63	ON [] [■] [] [] [] OFF [] [] [] [] [] 1 2 3 4 5 6	80	ON [] [] [] [■] [] OFF [] [] [] [] [] 1 2 3 4 5 6	100	ON [] [] [] [] [■] OFF [] [] [] [] [] 1 2 3 4 5 6																							
125	ON [] [] [■] [] [] OFF [] [] [] [] [] 1 2 3 4 5 6																											
<table border="1"> <tr> <td>MODELS</td> <td>SW2</td> <td>MODELS</td> <td>SW2</td> <td>MODELS</td> <td>SW2</td> </tr> <tr> <td>32</td> <td>ON [] [■] [] [] [] OFF [] [] [] [] [] 1 2 3 4 5 6</td> <td>40</td> <td>ON [] [] [■] [] [] OFF [] [] [] [] [] 1 2 3 4 5 6</td> <td>50</td> <td>ON [] [] [■] [] [] OFF [] [] [] [] [] 1 2 3 4 5 6</td> </tr> <tr> <td>63</td> <td>ON [] [■] [] [] [] OFF [] [] [] [] [] 1 2 3 4 5 6</td> <td>80</td> <td>ON [] [] [] [■] [] OFF [] [] [] [] [] 1 2 3 4 5 6</td> <td>100</td> <td>ON [] [] [] [] [■] OFF [] [] [] [] [] 1 2 3 4 5 6</td> </tr> <tr> <td>125</td> <td>ON [] [] [■] [] [] OFF [] [] [] [] [] 1 2 3 4 5 6</td> <td></td> <td></td> <td></td> <td></td> </tr> </table>			MODELS	SW2	MODELS	SW2	MODELS	SW2	32	ON [] [■] [] [] [] OFF [] [] [] [] [] 1 2 3 4 5 6	40	ON [] [] [■] [] [] OFF [] [] [] [] [] 1 2 3 4 5 6	50	ON [] [] [■] [] [] OFF [] [] [] [] [] 1 2 3 4 5 6	63	ON [] [■] [] [] [] OFF [] [] [] [] [] 1 2 3 4 5 6	80	ON [] [] [] [■] [] OFF [] [] [] [] [] 1 2 3 4 5 6	100	ON [] [] [] [] [■] OFF [] [] [] [] [] 1 2 3 4 5 6	125	ON [] [] [■] [] [] OFF [] [] [] [] [] 1 2 3 4 5 6						
MODELS	SW2	MODELS	SW2	MODELS	SW2																							
32	ON [] [■] [] [] [] OFF [] [] [] [] [] 1 2 3 4 5 6	40	ON [] [] [■] [] [] OFF [] [] [] [] [] 1 2 3 4 5 6	50	ON [] [] [■] [] [] OFF [] [] [] [] [] 1 2 3 4 5 6																							
63	ON [] [■] [] [] [] OFF [] [] [] [] [] 1 2 3 4 5 6	80	ON [] [] [] [■] [] OFF [] [] [] [] [] 1 2 3 4 5 6	100	ON [] [] [] [] [■] OFF [] [] [] [] [] 1 2 3 4 5 6																							
125	ON [] [] [■] [] [] OFF [] [] [] [] [] 1 2 3 4 5 6																											
<table border="1"> <tr> <td>MODELS</td> <td>SW2</td> <td>MODELS</td> <td>SW2</td> <td>MODELS</td> <td>SW2</td> </tr> <tr> <td>32</td> <td>ON [] [■] [] [] [] OFF [] [] [] [] [] 1 2 3 4 5 6</td> <td>40</td> <td>ON [] [] [■] [] [] OFF [] [] [] [] [] 1 2 3 4 5 6</td> <td>50</td> <td>ON [] [] [■] [] [] OFF [] [] [] [] [] 1 2 3 4 5 6</td> </tr> <tr> <td>63</td> <td>ON [] [■] [] [] [] OFF [] [] [] [] [] 1 2 3 4 5 6</td> <td>80</td> <td>ON [] [] [] [■] [] OFF [] [] [] [] [] 1 2 3 4 5 6</td> <td>100</td> <td>ON [] [] [] [] [■] OFF [] [] [] [] [] 1 2 3 4 5 6</td> </tr> <tr> <td>125</td> <td>ON [] [] [■] [] [] OFF [] [] [] [] [] 1 2 3 4 5 6</td> <td></td> <td></td> <td></td> <td></td> </tr> </table>			MODELS	SW2	MODELS	SW2	MODELS	SW2	32	ON [] [■] [] [] [] OFF [] [] [] [] [] 1 2 3 4 5 6	40	ON [] [] [■] [] [] OFF [] [] [] [] [] 1 2 3 4 5 6	50	ON [] [] [■] [] [] OFF [] [] [] [] [] 1 2 3 4 5 6	63	ON [] [■] [] [] [] OFF [] [] [] [] [] 1 2 3 4 5 6	80	ON [] [] [] [■] [] OFF [] [] [] [] [] 1 2 3 4 5 6	100	ON [] [] [] [] [■] OFF [] [] [] [] [] 1 2 3 4 5 6	125	ON [] [] [■] [] [] OFF [] [] [] [] [] 1 2 3 4 5 6						
MODELS	SW2	MODELS	SW2	MODELS	SW2																							
32	ON [] [■] [] [] [] OFF [] [] [] [] [] 1 2 3 4 5 6	40	ON [] [] [■] [] [] OFF [] [] [] [] [] 1 2 3 4 5 6	50	ON [] [] [■] [] [] OFF [] [] [] [] [] 1 2 3 4 5 6																							
63	ON [] [■] [] [] [] OFF [] [] [] [] [] 1 2 3 4 5 6	80	ON [] [] [] [■] [] OFF [] [] [] [] [] 1 2 3 4 5 6	100	ON [] [] [] [] [■] OFF [] [] [] [] [] 1 2 3 4 5 6																							
125	ON [] [] [■] [] [] OFF [] [] [] [] [] 1 2 3 4 5 6																											
SW3 Function setting	1	Heat pump/Cooling only	Cooling only	Heat pump	Under suspension	<p>Indoor controller board</p> <p>Set while the unit is off.</p> <p><Initial setting></p> <p>Set for each capacity.</p>																						
	2	—	—	—																								
	3	3D i-see Sensor positioning	The setting depends on the combination of SW3-3 and SW3-4. Refer to <Table B> below.																									
	4				Before power supply ON																							
	5	Vane horizontal angle ①	Second setting*2	First setting*2																								
	6	Vane horizontal angle ②	Third setting*2	Depends on SW3-5	Under suspension																							
	7	Changing the opening of linear expansion valve	Effective	Not effective																								
	8	Heat 4 degrees up	Not effective	Effective	Under suspension																							
	9	3D i-see Sensor ceiling height setting	The setting depends on the combination of SW3-9 and SW3-10. Refer to <Table C> below.																									
	0																											

<Table A>

SW1-7	SW1-8	
OFF	OFF	Extra low
ON	OFF	Low
OFF	ON	Setting air flow
ON	ON	stop

<Table B>

SW3-3	SW3-4	
OFF	OFF	Setting ①
ON	OFF	Setting ②
OFF	ON	Setting ③
ON	ON	Setting ④

<Table C>

SW3-9	SW3-10	
OFF	OFF	Low ceiling
ON	OFF	Standard
OFF	ON	High ceiling
ON	ON	(High ceiling)

<Table D>

SW3-5	SW3-6	Vane setting	Initial setting	Setting	Vane position
OFF	OFF	Setting ①		Less smudging	Downward position than the standard
ON	OFF	Setting ②	●	Less draft*3	Upward position than the standard
OFF	ON	Setting ③		Standard	Standard
ON	ON	Unused		—	—

*3 Be careful of the smudge on ceiling.

Continue to the next page

<PLFY-P32/40/50/63/80/100/125VEM-PA/-DA/-TH.TH> The black square (■) indicates a switch position.

Switch	Pole	Function	Operation by switch		Effective timing	Remarks																								
			ON	OFF																										
SW1 Function Selection	1	Thermistor <Room temperature detection> position	Built-in remote controller	Indoor unit	Under suspension	Address board																								
	2	Filter clogging detection	Provided	Not provided		<Initial setting>																								
	3	Filter cleaning	2,500 hr	100 hr																										
	4	Fresh air intake	Effective	Not effective																										
	5	Switching remote display	Thermo-ON signal display	Indicating fan operation ON/OFF																										
	6	—	—	—																										
	7	Air flow set in case of thermo-OFF at heating mode	Low*1	Extra low*1																										
	8	Setting airflow*1	Depends on SW1-7			*1 Refer to <Table A> below.																								
	9	Auto restart function	Effective	Not effective																										
	0	Power ON/OFF by breaker	Effective	Not effective																										
SW2 Capacity code setting	1-6	<table border="1"> <tr> <th>MODELS</th> <th>SW2</th> <th>MODELS</th> <th>SW2</th> <th>MODELS</th> <th>SW2</th> </tr> <tr> <td>32</td> <td>ON [■] [■] [■] OFF [■] [■] [■] 1 2 3 4 5 6</td> <td>40</td> <td>ON [■] [■] [■] OFF [■] [■] [■] 1 2 3 4 5 6</td> <td>50</td> <td>ON [■] [■] [■] OFF [■] [■] [■] 1 2 3 4 5 6</td> </tr> <tr> <td>63</td> <td>ON [■] [■] [■] OFF [■] [■] [■] 1 2 3 4 5 6</td> <td>80</td> <td>ON [■] [■] [■] OFF [■] [■] [■] 1 2 3 4 5 6</td> <td>100</td> <td>ON [■] [■] [■] OFF [■] [■] [■] 1 2 3 4 5 6</td> </tr> <tr> <td>125</td> <td>ON [■] [■] [■] OFF [■] [■] [■] 1 2 3 4 5 6</td> <td></td> <td></td> <td></td> <td></td> </tr> </table>				MODELS	SW2	MODELS	SW2	MODELS	SW2	32	ON [■] [■] [■] OFF [■] [■] [■] 1 2 3 4 5 6	40	ON [■] [■] [■] OFF [■] [■] [■] 1 2 3 4 5 6	50	ON [■] [■] [■] OFF [■] [■] [■] 1 2 3 4 5 6	63	ON [■] [■] [■] OFF [■] [■] [■] 1 2 3 4 5 6	80	ON [■] [■] [■] OFF [■] [■] [■] 1 2 3 4 5 6	100	ON [■] [■] [■] OFF [■] [■] [■] 1 2 3 4 5 6	125	ON [■] [■] [■] OFF [■] [■] [■] 1 2 3 4 5 6					<p>Indoor controller board</p> <p>Set while the unit is off.</p> <p><Initial setting></p> <p>Set for each capacity.</p>
MODELS	SW2	MODELS	SW2	MODELS	SW2																									
32	ON [■] [■] [■] OFF [■] [■] [■] 1 2 3 4 5 6	40	ON [■] [■] [■] OFF [■] [■] [■] 1 2 3 4 5 6	50	ON [■] [■] [■] OFF [■] [■] [■] 1 2 3 4 5 6																									
63	ON [■] [■] [■] OFF [■] [■] [■] 1 2 3 4 5 6	80	ON [■] [■] [■] OFF [■] [■] [■] 1 2 3 4 5 6	100	ON [■] [■] [■] OFF [■] [■] [■] 1 2 3 4 5 6																									
125	ON [■] [■] [■] OFF [■] [■] [■] 1 2 3 4 5 6																													
SW3 Function setting	1	Heat pump/Cooling only	Cooling only	Heat pump	Under suspension	<p>Indoor controller board</p> <p><Initial setting></p> <p>ON [■] [■] [■] [■] [■] [■] OFF [■] [■] [■] [■] [■] [■] 1 2 3 4 5 6 7 8 9 0</p>																								
	2	—	—	—																										
	3	3D i-see Sensor positioning	The setting depends on the combination of SW3-3 and SW3-4. Refer to <Table B> below.																											
	4		Second setting*2	First setting*2	Before power supply ON																									
	5	Vane horizontal angle ①	Second setting*2	First setting*2																										
	6	Vane horizontal angle ②	Third setting*2	Depends on SW3-5	Under suspension																									
	7	Changing the opening of linear expansion valve	Effective	Not effective																										
	8	Heat 4 degrees up	Not effective	Effective	Under suspension																									
	9	3D i-see Sensor ceiling height setting	The setting depends on the combination of SW3-9 and SW3-10. Refer to <Table C> below.																											
	0																													

<Table A>

SW1-7	SW1-8	
OFF	OFF	Extra low
ON	OFF	Low
OFF	ON	Setting air flow
ON	ON	stop

<Table B>

SW3-3	SW3-4	
OFF	OFF	Setting ①
ON	OFF	Setting ②
OFF	ON	Setting ③
ON	ON	Setting ④

<Table C>

SW3-9	SW3-10	
OFF	OFF	Low ceiling
ON	OFF	Standard
OFF	ON	High ceiling
ON	ON	(High ceiling)




<Table D>

SW3-5	SW3-6	Vane setting	Initial setting	Setting	Vane position
OFF	OFF	Setting ①	●	Less smudging	Downward position than the standard
ON	OFF	Setting ②		Less draft*3	Upward position than the standard
OFF	ON	Setting ③		Standard	Standard
ON	ON	Unused		—	—

*3 Be careful of the smudge on ceiling.

Continue to the next page

<PLFY-P32/40/50/63/80/100/125VEM-A.TH>
<PLFY-P32/40/50/63/80/100/125VEM-PA/-DA/-TH.TH>






Switch	Pole	Function	Operation by switch		Effective timing	Remarks		
			ON	OFF				
SW11 1s digit address setting SW12 10s digit address setting	Rotary switch	SW12 SW11 	Address setting should be done when M-NET remote controller is being used.		Before power supply ON	Indoor controller board <Initial setting> SW12 SW11 		
SW14 Connection No. setting	Rotary switch	SW14 	This is the switch to be used when the indoor unit is operated with R2 series outdoor unit as a set.			Indoor controller board <Initial setting> SW14 		
SW21 Function Selection	1	Setting the ceiling height	Depending on the combination of SW21-1 and SW21-2. Refer to <Table E> below.			Indoor controller board <Initial setting> ON  OFF 1 2 3 4 5 6		
	2	Setting the ceiling height						
	3	Setting the number of air outlet	Depending on the combination of SW21-3 and SW21-4. Refer to <Table E> below.					
	4	Setting the number of air outlet						
	5	Setting for optional parts	Option	Standard				
	6	Not used	Not used	Not used				

<Table E>

Blowout directions		Ceiling height		PLFY-P32/40/50/63/80VEM-A/-PA/-DA/-TH.TH				PLFY-P100/125VEM-A/-PA/-DA/-TH.TH			
		Silent	Standard	High ceiling	Silent	Standard	High ceiling	Silent	Standard	High ceiling	Silent
		SW21-1	SW21-2	SW21-1	SW21-2	SW21-1	SW21-2	SW21-1	SW21-2	SW21-1	SW21-2
4 directions	SW21-3 OFF SW21-4 ON	OFF ON		OFF OFF		ON OFF		OFF ON		OFF OFF	
3 directions	SW21-3 OFF SW21-4 OFF	2.5 m 2.7 m		2.7 m 3.0 m		3.5 m 3.5 m		2.7 m 3.0 m		3.2 m 3.6 m	
2 directions	SW21-3 ON SW21-4 OFF	3.0 m 3.3 m		3.3 m 3.5 m		3.5 m 4.0 m		4.0 m 4.5 m		4.5 m 4.5 m	

Note: The setting with  indicates the initial setting; To change it to other than , switch setting is necessary.

<PLFY-P32/40/50/63/80/100/125VEM-A.TH>
<PLFY-P32/40/50/63/80/100/125VEM-PA/-DA/-TH.TH>

Switch	Pole	Function	Operation by switch		Effective timing	Remarks																																										
			ON	OFF																																												
SW22 Function selection	Switch	<table border="1"> <thead> <tr> <th colspan="2">Function</th> <th>ON</th> <th>OFF</th> </tr> </thead> <tbody> <tr> <td>1</td> <td>—</td> <td>—</td> <td>—</td> </tr> <tr> <td>2</td> <td>—</td> <td>—</td> <td>—</td> </tr> <tr> <td>3</td> <td>Pair No. of wireless remote controller</td> <td colspan="2">Depends on the combination of SW22-3 and 22-4</td></tr> <tr> <td>4</td> <td>Pair No. of wireless remote controller</td> <td colspan="2"></td></tr> </tbody> </table> <ul style="list-style-type: none"> To operate each indoor unit by each remote controller when installed 2 indoor units or more are near, Pair No. setting is necessary. •Pair No. setting is available with the 4 patterns. •Make setting for SW22-3, 22-4 of indoor controller board and the Pair No. of wireless remote controller. You may not set it when operating it by one remote controller. ① Setting for indoor unit •Set SW22-3, 22-4 on the indoor controller board according to the table below. ② Wireless remote controller pair number: <ul style="list-style-type: none"> •Setting operation (Fig. 1 ①) 1. Press the  button ① to stop the air conditioner. 2. Press the  button ②. 3. Check that function No."1" is displayed, and then press the  button ③. The Screen display setting screen will be displayed. (Fig. 2.) •Pair No. changing operation (Fig. 2 ④) 1. Press the  button ④. 2. Each time the  button ④ is pressed, the pair No.0–3 changes. 3. Press the  button ③ to check the setting. 4. Press the  button ②. <table border="1"> <thead> <tr> <th colspan="2">Indoor unit SW22</th> <th>Pair No. of wireless remote controller</th> <th></th> </tr> <tr> <th>SW22-3</th> <th>SW22-4</th> <td></td> <td></td> </tr> </thead> <tbody> <tr> <td>ON</td> <td>ON</td> <td>0</td> <td>Initial setting</td> </tr> <tr> <td>OFF</td> <td>ON</td> <td>1</td> <td>—</td> </tr> <tr> <td>ON</td> <td>OFF</td> <td>2</td> <td>—</td> </tr> <tr> <td>OFF</td> <td>OFF</td> <td>3–9</td> <td>—</td> </tr> </tbody> </table>	Function		ON	OFF	1	—	—	—	2	—	—	—	3	Pair No. of wireless remote controller	Depends on the combination of SW22-3 and 22-4		4	Pair No. of wireless remote controller			Indoor unit SW22		Pair No. of wireless remote controller		SW22-3	SW22-4			ON	ON	0	Initial setting	OFF	ON	1	—	ON	OFF	2	—	OFF	OFF	3–9	—	Under operation or suspension	<p><Initial setting></p>  <p>Fig. 1</p>  <p>Fig. 2</p> 
Function		ON	OFF																																													
1	—	—	—																																													
2	—	—	—																																													
3	Pair No. of wireless remote controller	Depends on the combination of SW22-3 and 22-4																																														
4	Pair No. of wireless remote controller																																															
Indoor unit SW22		Pair No. of wireless remote controller																																														
SW22-3	SW22-4																																															
ON	ON	0	Initial setting																																													
OFF	ON	1	—																																													
ON	OFF	2	—																																													
OFF	OFF	3–9	—																																													
SWE Test run for Drain pump	Connector	<p>Drain pump and fan are activated simultaneously after the connector SWE is set to ON and turn on the power.</p> <p>The connector SWE is set to OFF after test run.</p> 	Under operation	<p><Initial setting></p> 																																												


8-3. TEST POINT DIAGRAM

Indoor controller board

PLFY-P32VEM-A/-PA/-DA/-TH.TH
PLFY-P63VEM-A/-PA/-DA/-TH.TH
PLFY-P125VEM-A/-PA/-DA/-TH.TH

PLFY-P40VEM-A/-PA/-DA/-TH.TH
PLFY-P80VEM-A/-PA/-DA/-TH.TH

PLFY-P50VEM-A/-PA/-DA/-TH.TH
PLFY-P100VEM-A/-PA/-DA/-TH.TH



9-1. OPERATION (AUTOMATIC FILTER ELEVATION GRILLE: PLP-6EAJ/PLP-6EAJE)

(1) Normal operation

① UP/DOWN

Air intake grille is raised/lowered by commands of UP and DOWN.

Air intake grille does not move under the state of no-load detection or obstacle detection

Air intake grille stops automatically at the set lowering distance from the ceiling level.

② STOP

It stops in the cases below :

- When it reaches the set lowering distance from the ceiling level.
It automatically stops after a predetermined period of lowering.

- When it is stored in the panel.

The air intake grille is judged to be stored in the panel
in all test conditions, it is recommended for further testing.

- When receiving commands of STOP, DOWN while moving up or UP while moving down.
The STOP button is only available on the automatic filter elevation panel remote controller.
When the wired remote controller is used, there will be a slight delay in stopping due to transmission speed.
 - When both string 1b and 2b are not loaded

Only the string h in each UP/DOWN Machine has a tension detection switch.

(2) Special operation

① Re-storage operation

Case : Obstruction of the raising air intake grille before storage or malfunction of storage detection switch

Re-store operation will be performed when the intake grille has been raised the set distance but the storage detection switch is not engaged.

In this case, the operation below will be repeated up to 4 times.

In this case, the operation below will be repeated up to 7 times:

② No-load detection

Case : UP/DOWN commands with no grille suspended

Case : SPIDBWN commands with no grills suspended.

When both string 1b and string 2b are not loaded, the strings will not move

③ Obstacle detection

Case : Making contact with something while lowering

Should the loads on the string 1b and string 2b be removed due to the air intake grille making contact with something while lowering, the lowering operation will stop. The air intake grille will then be raised 10 cm and stop again.


[EMERGENCY OPERATION]

- [EMERGENCY OPERATION]

 1. If the wireless remote controller for ELEVATION PANEL is faulty or lost, operation will be possible using the emergency up/down switch at the wireless signal receiver or wired remote controller.
 - For the operation using the emergency up/down switch at the wireless signal receiver, refer to SW1 and SW2 on the [LEGEND] in the next page.
 2. When machine for ELEVATION PANEL breaks down, a intake grille is fixed for a while, and the operation of the unit can be done.
 - Refer to installation manual with the grille for the details such as an installation method.

9-2. ELECTRICAL CIRCUIT (Controller board and wiring diagram (Panel))

9-2-1 DIP SW




[LEGEND]	
SYMBOL	NAME
U.B	ELEVATION PANEL CONTROLLER BOARD
LED2	LED ORANGE (INTAKE GRILLE CONDITION (See table *1))
LED4	LED GREEN (COMMUNICATION WITH INDOOR UNIT)
U.K.1	ELEVATION MACHINE
M	MOTOR (ELEVATION)
LS21	DETECTION SWITCH (STRING TENSION)
I.B	INDOOR UNIT CONTROLLER BOARD
W.B	PCB OF SIGNAL RECEIVER
BZ	BUZZER
RU	RECEIVING UNIT
LED1	LED GREEN (OPERATION INDICATION)
LED2	LED ORANGE (PREPARATION FOR HEATING)
SW1	EMERGENCY HEATING (LONG PRESS FOR OVER 2 SECONDS)
SW2	INTAKE GRILLE/DOWN EMERGENCY COOLING (LONG PRESS FOR OVER 2 SECONDS)
SW2	INTAKE GRILLE/UP (SHORT PRESS)
LS1	DETECTION SWITCH (INTAKE GRILLE STORAGE)
P.B	WIRED REMOTE CONTROLLER

EMERGENCY OPERATION

- [EMERGENCY OPERATION]

 1. If the wireless remote controller for ELEVATION PANEL is faulty or lost, operation will be possible using the emergency up/down switch at the wireless signal receiver or wired remote controller.
 - For the operation using the emergency up/down switch at the wireless signal receiver, refer to SW1 and SW2 on the left [LEGEND].
 2. When machine for ELEVATION PANEL breaks down, a intake grille is fixed for a while, and the operation of the unit can be done.
 - Refer to installation manual with the grille for the details such as an installation method.

<1> LED2 on U.B	
LED2	INTAKE GRILLE CONDITION
LIGHTING	INTAKE GRILLE HOUSED AND STRING TENSIONED
1-TIME BLINKING	INTAKE GRILLE NOT HOUSED AND STRING TENSIONED
2-TIME BLINKING	STRING NOT TENSIONED



[Note]

- [NOTE]

 1. Symbols used in wiring diagram above are,  : Connector,  : Terminal (block).
 2. The black square () indicates a switch position.

Note: The actual lowering distance might be different from the distance in the table 2 since it can also be set using the wired remote controller.

9-2-2 Check point of trouble

<1 ED 2 Orange display>

- Turn OFF : No power supply
 - Blink : Storage detection switch ON (short)
 - One blink : Storage detection switch OFF (open)
 - Two blinks : Tension detection switch OFF (open)

<1 ED 4 Green display>

- Blink : Connecting

<controller board>

Check item	Check point	Normal	Remarks
Up/down controller P.C. board supply voltage	CN4A (between 1-2)	11-14 V AC	—
Up/down machine supply voltage	CN3B (between 1-2) CN3C (between 1-2)	10-13.5 V DC	Check when instructing up/down with LED blinking once.

<Up/down machine>

Check item	Check point	Normal	Check contents
Storage detection switch	CN2E	open or short	Check if it is short when pressing push switch.
Tension detection switch	CN2F, CN2G	open or short	Check if it is short when string b is tensioned.
Motor	CN3B, CN3C	5–20 Ω	Check if it is not open or short.
Entwining strings	Pull string	Retention: about 2 kgf	Check if string is drawn out by pulling with 4 kgf.





9-3. TROUBLESHOOTING

- Check the following points.



Problem	Possible Reason	Corrective Action
Intake grille does not function with operation of the remote controller.	Air-conditioner is running.	Stop running the air-conditioner and try again.
	Power failure.	After recovering from power failure, try again.
	Batteries are not inserted into the wireless remote controller. Or battery power is running low.	Install or replace the battery.
	There is something on the intake grille. Or something is stuck in the intake grille.	Remove the objects or obstacles from the intake grille. Or, remove the stuck object.
Intake grille cannot be placed in the correct position.	There is something on the intake grille.	Remove the objects or obstacles from the intake grille.
	Filter is not properly installed.	Lower the intake grille again and check whether the filter is installed in the correct position.
	Intake grille is not hung with all 4 hooks.	Lower the intake grille again and hang the hook on the intake grille.
Intake grille stops lowering in mid flow. (Intake grille would not lower any further.)	Because the intake grille has finished lowering to the auto-stop position.	This is normal. Note: If you want to change the setting for the lowering distance, contact your dealer.
Noises are made during up/down operation. (While intake grille is moving up/down.)	This is the noise made when the string is wound and unwound.	This is normal.
Noises are made while placing the intake grille in.	This is the operational noise for placing the intake grille in securely.	
Intake grille repeats rising and lowering several times while being placed in the correct position.	This is the operation for placing the intake grille in securely.	
Intake grille leans toward one side during the up/down operation.	The speeds of winding each string is slightly different.	





PLFY-P32VEM-A/-PA/-DA/-TH.TH PLFY-P40VEM-A/-PA/-DA/-TH.TH PLFY-P50VEM-A/-PA/-DA/-TH.TH
 PLFY-P63VEM-A/-PA/-DA/-TH.TH PLFY-P80VEM-A/-PA/-DA/-TH.TH PLFY-P100VEM-A/-PA/-DA/-TH.TH
 PLFY-P125VEM-A/-PA/-DA/-TH.TH


Be careful when removing heavy parts.




OPERATING PROCEDURE	PHOTOS & ILLUSTRATIONS
1. Removing the filter <ul style="list-style-type: none"> (1) Slide the knob of air intake grille toward the arrow to open the air intake grille. (See Figure 1) (2) Pull down the lever of the air intake grille to remove the filter. (See Figure 2) 	<p>Figure 1</p> 
2. Removing the air intake grille <ul style="list-style-type: none"> (1) Slide the knob of air intake grille toward the arrow to open the air intake grille. (See Figure 1) (2) Remove the hook of drop prevention strap from the panel. (3) Remove the air intake grille. 	<p>Figure 2</p> 
3. Removing the electrical box cover <ul style="list-style-type: none"> (1) Remove the air intake grille and the filter. (Refer to procedure 2) (2) Loosen the 2 electrical box cover fixing screws (M4×10) approximately 2 to 3 mm. (See Photo 1) (3) Slide the electrical box cover toward the arrow to remove. (See Photo 2) 	<p>Photo 1</p>  <p>Photo 2</p> 




OPERATING PROCEDURE	PHOTOS
<p>4. Removing the room temperature thermistor (TH21)</p> <p>(1) Remove the electrical box cover. (See Photo 1 and 2) (2) Disconnect the connector CN20 (Red) from the indoor controller board. (3) Remove the room temperature thermistor with its holder. (See Photo 4)</p>	<p>Photo 3</p> <p>Photo 4</p>
<p>5. Removing the indoor controller board (I.B)</p> <p>(1) Remove the electrical box cover. (See Photo 1 and 2) (2) Disconnect the connectors: CNMF (White) for fan motor CNV (White) for vane motor CN5Y (White) for motor for i-see Sensor (Option) CN4Z (White) for sensor for i-see Sensor (Option) CN90 (White) for signal receiver (Option) CNP (White) for drain pump CN4F (White) for float switch CN44 (White) for thermistor (TH22/TH23) CN60 (White) for LEV CN01 (Black) for Indoor/Outdoor connecting line CN3C (Blue) for Indoor/Outdoor transmission</p> <p>Disconnect the connectors for optional parts, if any.</p> <p>(3) Disconnect the lead wire connected to the TB5 on the indoor controller board. TB5: M-NET transmission connecting wire (4) For the unit controlled with the wireless remote controller, disconnect the lead wire connected to the TB15 on the indoor controller board. (5) Remove the indoor controller board (3 holders/4 hooks). (See Photo 5)</p>	<p>Photo 5</p>

OPERATING PROCEDURE	PHOTOS & ILLUSTRATIONS
6. Removing the electrical box <ol style="list-style-type: none"> (1) Remove the electrical box cover (See Photo 1 and 2) and the connectors (Refer to procedure 5). (2) Remove the electrical box fixing screws (M5×10: 2 screw). (See Photo 3) <p><Electrical parts in the electrical box></p> <ul style="list-style-type: none"> • Terminal block for earth and reactor • Indoor controller board • Thermistor (TH) (3) Remove the electrical box (2 hooks). 	Photo 6  <p>Bell mouth fixing screws Bell mouth Hooks Electrical box</p>
7. Removing the turbo fan <ol style="list-style-type: none"> (1) Remove the electrical box. (See Photo 3 and refer to procedure 6) (2) Remove the bell mouth (tapping screw 4×10: 2 screws). (See Photo 6) <p>< With nut and square washer ></p> <ol style="list-style-type: none"> (3) Remove the nut and square washer. (See Photo 6 and 7) (4) Remove the turbo fan. <p>< With nut and washer ></p> <ol style="list-style-type: none"> (3) Remove the nut (M8 × 1) and square washer. (See Photo 7 and 8.) (4) Remove the turbo fan. 	Photo 7  <p>Nut and square washer or nut and washer Turbo fan</p>
<p>Note 1: When assembling the turbo fan, attach it so that its tabs fit the holes of washer.</p> <p>Note 2: Nut tightening torque: 4.5 ± 0.5 Nm.</p>	<p>< Nut and square washer ></p>  <p>Turbo fan tabs Washer holes</p>
<p>Photo 8  </p>	<p>< Nut and washer ></p> 
	<p>Photo 9  </p>

OPERATING PROCEDURE	PHOTOS & ILLUSTRATIONS
<p>8. Removing the fan motor (MF)</p> <ol style="list-style-type: none"> (1) Remove the turbo fan. (See Photo 8 and refer to procedure 7) (2) Remove the lead cover (tapping screw 4×10: 2 screws). (See Photo 10) (3) Loosen the 2 clamps. (4) Remove the 3 nuts and washers (M5). (5) Remove the fan motor. (6) Remove the 3 rubber mounts. 	<p>Photo 10</p>  <p>Note: When re-attaching the motor mount, make sure that the thicker end faces the motor shaft.</p>
<p>9. Removing the panel</p> <ol style="list-style-type: none"> (1) Remove the electrical box fixing cover. (See Photo 1) (2) Disconnect the connector for vane motor (CNV: White). (Refer to procedure 5) (3) Loosen the 4 corner panel fixing screws (tapping screw 4×16). (See Figure 4) (4) Slide the corner panel to the direction of the arrow 1, and remove the corner panel. (See Figure 4) (5) Remove the 4 installation screws (M5×28). (See Photo 11) (6) Release the 2 temporary hanging hooks to remove the grille. (See Photo 12) 	<p>Figure 4</p>  <p>Photo 11</p>  <p>Photo 12</p> 

OPERATING PROCEDURE	PHOTOS/FIGURES
<p>10. Removing the drain pan</p> <ol style="list-style-type: none"> (1) Remove the electrical box. (See photo 3 and refer to procedure 6) (2) Remove the bell mouth (tapping screw 4×10 : 2 screws). (See Photo 6) (3) Remove the drain pan (screw M5×10: 4 screws). 	<p>Photo 13</p> 
<p>11. Removing the pipe temperature/liquid thermistor (TH22) and condenser/evaporator temperature thermistor (TH23)</p> <ol style="list-style-type: none"> (1) Remove the drain pan (Refer to procedure 10) and loosen the 2 clamps of the coil plate. (See Photo 10) (2) Remove the coil plate (tapping screw 4×10: 2 screws). (3) Disconnect the pipe temperature/liquid thermistor (TH22) and condenser/evaporator temperature thermistor (TH23) from the holder. 	<p>Photo 14</p> 

OPERATING PROCEDURE	PHOTOS/FIGURES
<p>12. Removing the drain pump (DP)</p> <p>(1) Remove the drain pan. (Refer to procedure 10) (2) Cut the hose band and remove the hose. (3) Loosen the clamp of the drain pump. (4) Remove the drain pump (tapping screw 4×10: 2 screws/2 hooks). (5) Cut the drain pump base and lead wire fixing band. (See Figure 5) (6) Remove the lead wire of the drain pump from the clamp of the drain pump base. (See Figure 5) (7) Remove the drain pump (tapping screw: 3 screws). (See Figure 6)</p>	<p>Photo 15</p> 
<p>Figure 6</p> 	<p>Figure 5</p> 

OPERATING PROCEDURE	PHOTOS/FIGURES
<p>13. Removing the float switch (FS)</p> <ol style="list-style-type: none"> (1) Remove the drain pan. (Refer to procedure 10) (2) Loosen the clamp of the drain pump. (See Photo 15) (3) Remove the float switch (tapping screw 4×10: 1 screw/1 hook). (See Photo 15) (4) Remove the float switch base and the lead wire fixing band. (See Photo 16) (5) Remove the lead wire from the U shaped portion of the float switch base. (See Photo 16) (6) Slide the float switch towards the arrow to remove from the float switch base. 	<p>Photo 16</p> 
<p>14. Removing the heat exchanger</p> <ol style="list-style-type: none"> (1) Remove the drain pan. (Refer to procedure 10) (2) Remove the piping cover (tapping screw 4×10: 3 screws). (3) Remove the coil plate (tapping screw 4×10: 2 screws). (4) Remove the heat exchanger fixing screws (tapping screw 4×10: 2 screws). (5) Remove the coil support (tapping screw 4×10: 1 screw each) <ul style="list-style-type: none"> ■ P32-80: 1 coil support (See photo 17) ■ P100, 125: 3 coil supports (See photo 18) (6) Remove the heat exchanger. <p>Photo 18</p> 	<p>Photo 17</p> 

CITY MULTI

IMITSUBISHI ELECTRIC CORPORATION

HEAD OFFICE : TOKYO BUILDING, 2-7-3, MARUNOUCHI, CHIYODA-KU, TOKYO 100-8310, JAPAN

MITSUBISHI ELECTRIC CONSUMER PRODUCTS (THAILAND) CO., LTD.
700/406 MOO 7, TAMBON DON HUA ROH,
AMPHUR MUANG, CHONBURI 20000 THAILAND
Made in Thailand

New publication, effective Dec. 2018
Specifications are subject to change without notice.