

Result of Air Tests on Sanitary Plumbing System




Project Reference : **A2105-00599-2022**

Project Title PROPOSED ADDITIONS OF 1 BLOCK OF 3-STOREY OFFICE BUILDING (BLK 2), 1 BLOCK OF 6-STOREY ACCOMMODATION BUILDING (BLK 3), 1 BLOCK OF 4-STOREY ACCOMMODATION BUILDING (BLK 4), 1 BLOCK OF 2-STOREY TRAINING MULTIPLEX (BLK 9), 1 BLOCK OF MSVS (BLK 10), AND ANCILLARY FACILITIES (BLK 5, 6 & 8), PARTIAL DEMOLITION OF BLKS 1 & 22 AND DEMOLITION OF BLKS 1A, 1B, 2, 3, 3A, 4, 4A, 5, 5A, 6, 6A, 6B, 7, 7A, 8, 9, 10, 14, 18, 18A, 19, 20, 23, 23B, 23C, 24, 25, 25A, 25B, 26, 26A, 26B, 26C, 26D, 27A, 31, 31B, 32, 33B, 33C, 33D, 33E, 33F, 33G, 33H, 37, 37A, 37B, 41, 44, 44A & 131 TO EXISTING DIEPPE BARRACK ON LOT Q5019M MK13 AT SEMBAWANG ROAD (MANDAI PLANNING AREA)

-Partial TOP for Phase 1 Involving Blocks 2,3,4,5 & 6 Only

Test Method : Air Test method as specified in Clause NG 3.1 of BS EN 12056-2-2000

Test Results: as tabulated below.

Block No:	Storey Level: (eg. 1 st Floor, 2nd Floor)	Unit No: (eg. #02-01, 03-01, etc)	Date of 1 st test of sanitary discharge pipes/ stacks, ventilating pipes/stacks, WCs, Floor traps, etc at the unit	1 st test Result (Leak / No Leak) (To specify the points of leak detected)	(if found leak at 1 st test) Date of final retest which shows no Leak in the sanitary discharge pipes/stacks, ventilating pipes/stacks, WCs, Floor traps, etc at the unit
Blk -2	1 st sty, 2 nd sty, 3 rd sty, roof	Stack -1 2 nd sty : Male Toilet T2-02 3 rd sty : Female Toilet T3-01	01/11/2024	No Leak	
		Stack -2 2 nd sty : Male Toilet T2-04 3 rd sty : Male Toilet T3-03 NCR Room, Office	24/10/2024	No Leak	
Tested/Checked by: (Name of plumbing contractor in charge of test)  Yiah Choon Yong WS 15262013			Signature: 	Company & Designation: Plumber Watertech Plumbing & Construction Pte Ltd	Date: 16/11/2024
Witnessed by: (Name of RTO's authorised representative) Moe Thauk Tun			Signature:  Moe Thauk Tun	Company & Designation: PDC Consultants Pte Ltd RTO	Date: 18/11/2024
Certified by: (Name of QP and QP's stamp)			Signature:		Date: