




SECO LED Pilot Lamp $\phi 22\text{mm}$ (Optional : with Build-in Anti-Interference)

TECHNICAL SPECIFICATION

Type	: AD1622/AD1622DSK
Operating Temperature Limits	: -22°C to $+55^{\circ}\text{C}$
Storage Temperature Limits	: -40°C to $+70^{\circ}\text{C}$
Insulation Resistance	: $\geq 2\text{M}\Omega$
Allowable Voltage Fluctuation	: $\pm 10\%$
Frequency	: AC 50~60Hz
Power Frequency Withstand Voltage	: 2.5kV/1 min (effective AC value)
Rated Insulation Voltage	: 600VAC
Lamp Ratings	: LEDs 24-30V AC/DC 20mA : LEDs 100-240V AC 20mA : LEDs 400-450V AC 7mA
Continuous Operating Life	: $\geq 30,000$ hrs
Brightness	: $\geq 100\text{cd/m}^2$
Degree of Protection	: IP65 (From Panel front) : IP20 (Terminal) : CE Approval
Range of colour available	: Red, Yellow, Green, Pure Blue and Pure White





C E R T I F I C A T E

ATTESTATION CERTIFICATE OF ELECTROMAGNETIC COMPATIBILITY AND LOW VOLTAGE DIRECTIVES

Technical file of the company mentioned below has been observed and audit has been completed successfully.

2014/30/EU Electromagnetic Compatibility Directive and
2014/35/EU Low Voltage Directives have been taken as references for these processes

Company Name : Jiangsu Shuangke Electrical Co., Ltd.

Company Address : Dafeng Industrial Park, Changzhou High-tech Zone, Dafeng District, Yancheng City, Jiangsu Province, China

Related Directives and Annex : 2014/35/EU Low Voltage Directive
2014/30/EU Electromagnetic Compatibility Directive

Related Standards : EN 60947-1:2007/A2:2014; EN 60947-5-1:2017
EN 61000-3-2:2014; EN 61000-3-3:2013

Product Name : Indicator Lamp

Report No and Date : MICEZ-1903-0104-LVD, MICEZ-1903-0104-EMC

Product Brand/Model/Type : AD56-22/AD56-16/AD56-BA/AD56-E

Certificate Number : M.2019.206.C1164
Initial Assessment Date : 20.05.2019
Registration Date : 21.05.2019
Reissue Date/No : -
Expiry Date : 20.05.2024


UDEM International Certification
Auditing Training Centre Industry
and Trade Inc. Co.

The validity of the certificate can be checked through www.udem.com.tr. The CE mark shown on the right can only be used under the responsibility of the manufacturer with the completion of EC Declaration of Conformity for all the relevant Directives. This certificate remains the property of UDEM International Certification Auditing Training Centre Industry and Trade Inc. Co. to whom it must be returned upon request. The above named firm must keep a copy of this certificate for 15 years from the registration of certificate. This certificate only covers the product(s) stated above and UDEM must be noticed in case of any changes on the product(s).

Address: Mutlukent Mahallesi 2073 Sokak (Eski 93 Sokak) No:10 Çankaya - Ankara - TURKEY
Phone: +90 0312 443 03 90 Fax: +90 0312 443 03 76
E-mail: info@udemltd.com.tr www.udem.com.tr





Monday, 14 May 2018

Amega Energy Pte Ltd
3018 Bedok North Street 5
Eastlink #06-40
Singapore 486132

Attn: Mr. Nio

Subject: SECO Pilot Light – Project references

Thank you for your continual support for our products.
Please see below project references of our SECO pilot light for your perusal.

Tuas Mega Yard
Sentosa Resort World Data Centre
Morgan Stanley Data Centre
Changi City Point
Katong Mall
Marina Bay Financial Centre
Seagates (Woodlands)
Singapore Powergrid (Transformer switchgear panels)
Defence Science Technologies Agency (DSTA)
HDB Hub
Cummins (Generator Syn Control panels)
Changi Naval Base
Kopi Tiam Food outlets
British American Tobacco

If you have any questions, please feel free to ask me. Thank you

Regards

Michael