

**FIRE SAFETY ACT
(CHAPTER 109A)
FIRE SAFETY (BUILDING AND PIPELINE FIRE SAFETY) REGULATIONS**

(Regulation 13)

REGULATED FIRE SAFETY PRODUCTS INSTALLATION CERTIFICATE

The Commissioner
Singapore Civil Defence Force
91 Ubi Avenue 4
Singapore 408827

Attn: Director, Fire Safety Department

Project Title:

PROPOSED AMENDMENT TO APPROVED ADDITIONS OF 1 BLOCK OF 3-STOREY OFFICE BUILDING (BLK 2), 1 BLOCK OF 6-STOREY ACCOMMODATION BUILDING (BLK 3), 1 BLOCK OF 4-STOREY ACCOMMODATION BUILDING (BLK 4), 1 BLOCK OF 2-STOREY TRAINING MULTIPLEX (BLK 9), 1 BLOCK OF MSVS (BLK 10), AND ANCILLARY FACILITIES (BLK 5, 6 & 8), PARTIAL DEMOLITION OF BLKS 1 & 22 AND DEMOLITION OF BLKS 1A, 1B, 2, 3, 3A, 4, 4A, 5, 5A, 6, 6A, 6B, 7, 7A, 8, 9, 10, 14, 18, 18A, 19, 20, 23, 23B, 23C, 24, 25, 25A, 25B, 26, 26A, 26B, 26C, 26D, 27A, 31, 31B, 32, 33B, 33C, 33D, 33E, 33F, 33G, 33H, 37, 37A, 37B, 41, 44, 44A & 131 TO EXISTING DIEPPE BARRACK ON LOT 05019M MK13 AT SEMBAWANG ROAD (MANDAI PLANNING AREA)

SCDF Approved Plan Number:

RBP/N01320/23, RBP/N01320/2301, RBP/N01320/2303, RBP/N01320/2304

Approved Date:

17-Mar-2023, 17-Jul-2024, 04-Oct-2024

*To attach floor plans indicating the locations of Regulated Fire Safety Product installed and endorsed by the same appointed Appropriate QP.

Updated as of 16 Oct 2020

**FIRE SAFETY ACT
(CHAPTER 109A)
FIRE SAFETY (BUILDING AND PIPELINE FIRE SAFETY) REGULATIONS**

(Regulation 13)

REGULATED FIRE SAFETY PRODUCTS INSTALLATION CERTIFICATE

Type of Regulated Fire Safety Products & Materials: Fire Stopping Material / Sureseal Firestop

*Storey	*Room type (Eg. Office, Classroom, etc.)	*Gridlines in SCDF approved plans	Installed size / area	**Fire resistance rating (hrs) / Thickness	Inspection Date
Blk 2 – L2 to 4, Blk 3 – L2 to 6, lower roof, Blk 4 – L2 to L4, Blk 5 – L1	Electrical, Telecom, OT, Ancillary, Comms Riser	-	168 nos.	2 / 40	25/10/2024
Inspected by Appropriate QP appointed by **Supplier/Contractor (Installer) of the Regulated Fire Safety Product					

*To attach floor plans indicating the locations of Regulated Fire Safety Product installed and endorsed by the same appointed Appropriate QP.

Updated as of 16 Oct 2020

**FIRE SAFETY ACT
(CHAPTER 109A)
FIRE SAFETY (BUILDING AND PIPELINE FIRE SAFETY) REGULATIONS**

(Regulation 13)

REGULATED FIRE SAFETY PRODUCTS INSTALLATION CERTIFICATE

Certificate of Conformity Number	FSP-2012-0104	
Validity Period	23/08/2023 – 13/09/2028	
Certification Body	SETSCO SERVICES PTE LTD	
Test Report(s) No	7191142457-MEC16/2-IHN	
	S08MEC00971/MW	
	S09MEC00553/MW	
Supplier	Full Name	Kelvin Ng Tiong Soon
	Designation	Manager
	Company Name	ACEMECH SERVICES PTE LTD
	Company UEN	200903646D
Installer	Full Name	Senthilnathan Balamurugan
	Designation	Senior Supervisor
	Company Name	ACEMECH SERVICES PTE LTD
	Company UEN	200903646D

I, GOH KHAI SIANG (full name of Appropriate QP, as per NRIC/FIN), being an appropriate qualified person have supervised the installation of the aforesaid regulated fire safety products and certify that all installation works have been carried out in accordance with the approved plans of fire safety works for the project, the provisions of prevailing Fire Code, the Fire Safety Act and any regulations made under this Act and any terms and conditions imposed by the Commissioner.

GOH KHAI SIANG
Full Name of Appropriate QP
appointed by Installer



GKS CONSULTANCY P L
Company Name

PE (CIVIL)
Designation

[Signature]
Signature

25/10/2024
Date

*To attach floor plans indicating the locations of Regulated Fire Safety Product installed and endorsed by the same appointed Appropriate QP.

Updated as of 16 Oct 2020