

## Series TY-B — 5.6 K-factor Conventional (Old Style) Sprinklers Standard Response

### General Description

The TYCO Series TY-B, 5.6 K-factor, Conventional Sprinklers (TY365) described in this data sheet are standard response -standard coverage, decorative 5 mm glass bulb type spray sprinklers. These sprinklers are intended to be installed either pendent or upright, and in either position, they produce a spherical water discharge pattern with approximately 50% of the discharge directed upwards and approximately 50% of the discharge directed downwards.

Conventional sprinklers are generally used with Ordinary and Extra High Hazard Class Systems, as defined by the automatic sprinkler system installation rules of the country and authority having jurisdiction. The NFPA permits the use of "Old Style Sprinklers" where special construction features require a unique water distribution; for the protection of fur vaults; or, the replacement of similar sprinklers that had been installed prior to 1955.

#### NOTICE

*The TYCO Series TY-B 5.6 K-factor Conventional Sprinklers described herein must be installed and maintained in compliance with this document, as well as with the applicable standards of the National Fire Protection Association, in addition to the standards of any other authorities having jurisdiction. Failure to do so may impair the performance of these devices.*

#### IMPORTANT

*Always refer to Technical Data Sheet TFP700 for the "INSTALLER WARNING" that provides cautions with respect to handling and installation of sprinkler systems and components. Improper handling and installation can permanently damage a sprinkler system or its components and cause the sprinkler to fail to operate in a fire situation or cause it to operate prematurely.*

*The owner is responsible for maintaining their fire protection system and devices in proper operating condition. The installing contractor or sprinkler manufacturer should be contacted with any questions.*

### Sprinkler Identification Number (SIN)

TY365

### Technical Data

**Approvals**  
UL Listed  
VdS Approved

**Maximum Working Pressure**  
175 psi (12,1 bar)

**Discharge Coefficient**  
K = 5.6 GPM/psi<sup>1/2</sup> (80,6 LPM/bar<sup>1/2</sup>)

#### Temperature Ratings

135°F (57°C)  
155°F (68°C)  
175°F (79°C)  
200°F (93°C)  
286°F (141°C)  
360°F (182°C)

#### Finishes

Sprinkler: Natural Brass, Chrome Plated, Pure White (RAL 9010) and Signal White (RAL 9003)

#### Physical Characteristics

Frame . . . . . Bronze  
Button . . . . . Brass/Copper  
Sealing Assembly . . . . . Stainless Steel w/TEFLON  
Bulb . . . . . Glass  
Compression Screw . . . . . Bronze  
Deflector . . . . . Bronze




### Operation

The glass bulb contains a fluid which expands when exposed to heat. When the rated temperature is reached, the fluid expands sufficiently to shatter the glass bulb, allowing the sprinkler to activate and water to flow.

### Design Criteria

The TYCO Series TY-B, 5.6 K-factor, Conventional Sprinklers (TY365) are intended for fire protection systems designed in accordance with the standard installation rules recognized by the applicable Listing or Approval agency (e.g., UL Listing is based on NFPA 13 requirements). The Series TY-B Conventional Sprinklers are only for non-recessed applications.



## Installation

The TYCO Series TY-B, 5.6 K-factor, Conventional Sprinklers (TY365) must be installed in accordance with this section:

### General Instructions:

Do not install any bulb type sprinkler if the bulb is cracked or there is a loss of liquid from the bulb. With the sprinkler held horizontally, a small air bubble should be present. The diameter of the air bubble is approximately 1/16 inch (1,6 mm) for the 135°F (57°C) to 3/32 inch (2,4 mm) for the 360°F (182°C) temperature ratings.

A leak tight 1/2 inch NPT sprinkler joint should be obtained with a torque of 7 to 14 ft.-lbs. (9,5 to 19,0 Nm). A maximum of 21 ft.-lbs. (28,5 Nm) of torque may be used to install sprinklers with 1/2 NPT connections.

**Step 1.** With pipe thread sealant applied to the pipe threads, hand tighten the sprinkler into the sprinkler fitting.

**Step 2.** Tighten the sprinkler into the sprinkler fitting using only the W-Type 6 Sprinkler Wrench (Figure 2), except that an 8 or 10 inch adjustable Crescent wrench is to be used for wax coated sprinklers. With reference to Figure 1, the W-Type 6 Sprinkler Wrench or the Crescent wrench, as applicable, is to be applied to the wrench flats.

## Care and Maintenance

The TYCO Series TY-B, 5.6 K-factor, Conventional Sprinklers (TY365) must be maintained and serviced in accordance with this section.


Before closing a fire protection system main control valve for maintenance work on the fire protection system that it controls, obtain permission to shut down the affected fire protection systems from the proper authorities and notify all personnel who may be affected by this action.

Sprinklers which are found to be leaking or exhibiting visible signs of corrosion must be replaced.

Automatic sprinklers must never be painted, plated, coated, or otherwise altered after leaving the factory. Modified sprinklers must be replaced. Sprinklers that have been exposed to corrosive products of combustion, but have not operated, should be replaced if they cannot be completely cleaned by wiping the sprinkler with a cloth or by brushing it with a soft bristle brush.

Care must be exercised to avoid damage to the sprinklers before, during, and after installation. Sprinklers damaged by dropping, striking, wrench twist/slippage, or the like, must be replaced. Also, replace any sprinkler that has a cracked bulb or that has lost liquid from its bulb. (Ref. Installation Section.)

The owner is responsible for the inspection, testing, and maintenance of their fire protection system and devices in compliance with this document, as well as with the applicable standards of the National Fire Protection Association (e.g., NFPA 25), in addition to the



standards of any other authorities having jurisdiction. Contact the installing contractor or sprinkler manufacturer regarding any questions.

It is recommended that automatic sprinkler systems be inspected, tested, and maintained by a qualified Inspection Service in accordance with local requirements and/or national codes.

## Series TY-B – 5.6 K-factor Horizontal and Vertical Sidewall Sprinklers Standard Response, Standard Coverage

### General Description

The TYCO Series TY-B, 5.6 K-factor, Horizontal and Vertical Sidewall Sprinklers described in this technical data sheet are standard response, standard coverage decorative 5 mm glass bulb type spray sprinklers designed for use in light and ordinary hazard, commercial occupancies such as banks, hotels, and shopping malls.

They are designed for installation along a wall or the side of a beam and just beneath a smooth ceiling. Sidewall sprinklers are commonly used instead of pendent or upright sprinklers due to aesthetics or building construction considerations, where piping across the ceiling is not desirable.

The recessed version of the Series TY-B Horizontal Sidewall Sprinkler is intended for use in areas with a finished wall. It uses a two-piece Style 10 Recessed Escutcheon. The Recessed Escutcheon provides 1/2 in. (12,7 mm) of recessed adjustment or up to 3/4 in. (19,1 mm) of total adjustment from the flush sidewall position. The adjustment provided by the Recessed Escutcheon reduces the accuracy to which the fixed pipe nipples to the sprinklers must be cut.

Corrosion-resistant coatings, where applicable, are utilized to extend the life of copper alloy sprinklers beyond that which would otherwise be obtained

when exposed to corrosive atmospheres. Although corrosion resistant coated sprinklers have passed the standard corrosion tests of the applicable approval agencies, the testing is not representative of all possible corrosive atmospheres. Consequently, it is recommended that the end user be consulted with respect to the suitability of these coatings for any given corrosive environment. The effects of ambient temperature, concentration of chemicals, and gas/chemical velocity, should be considered, as a minimum, along with the corrosive nature of the chemical to which the sprinklers will be exposed.

#### NOTICE

*The Series TY-B Sprinklers described herein must be installed and maintained in compliance with this document, as well as with the applicable standards of the National Fire Protection Association, in addition to the standards of any other authorities having jurisdiction. Failure to do so may impair the performance of these devices.*

*The owner is responsible for maintaining their fire protection system and devices in proper operating condition. Contact the installing contractor or product manufacturer with any questions.*

### Sprinkler Identification Numbers


TY3351. . . . . Horizontal Sidewall  
TY3451. . . . . Vertical Sidewall

### Technical Data

#### Approvals

UL and C-UL Listed  
FM Approved  
LPCB Certified  
NYC Approved

(See Table A for complete approval information, including corrosion-resistant status.)



#### Maximum Working Pressure

See Table B

#### Discharge Coefficient

K=5.6 gpm/psi<sup>1/2</sup> (80,6 Lpm/bar<sup>1/2</sup>)

#### Temperature Ratings

See Table A

#### Finishes

Sprinkler: See Table C

Recessed Escutcheon: Signal or Pure White, Grey Aluminum, Jet Black, Chrome Plated, or Natural Brass


#### Physical Characteristics

Frame . . . . .	Bronze
Button . . . . .	Brass/Copper
Sealing Assembly . . . . .	Beryllium Nickel w/TEFLON
Bulb . . . . .	Glass
Compression Screw . . . . .	Bronze
HSW Deflector . . . . .	Bronze
VSW Deflector . . . . .	Copper

#### IMPORTANT

Refer to Technical Data Sheet TFP2300 for warnings pertaining to regulatory and health information.

Always refer to Technical Data Sheet TFP700 for the "INSTALLER WARNING" that provides cautions with respect to handling and installation of sprinkler systems and components. Improper handling and installation can permanently damage a sprinkler system or its components and cause the sprinkler to fail to operate in a fire situation or cause it to operate prematurely.



### Poly-Stainless Physical Characteristics

Frame	Bronze
Button	L316 Stainless Steel*
Bulb	Glass
Compression Screw	L316 Stainless Steel*
HSW Deflector	Copper/Bronze
Sealing Assembly	Gold Plated Beryllium Nickel w/TEFLON

\*Type L316 stainless steel (UNS 31603) per ASTM A479/479M or BS EN 1008 WN1.4404.

## Operation

The glass bulb contains a fluid which expands when exposed to heat. When the rated temperature is reached, the fluid expands sufficiently to shatter the glass bulb, allowing the sprinkler to activate and water to flow.

## Design Criteria

The TYCO Series TY-B, 5.6 K-factor, Horizontal and Vertical Sidewall Sprinklers are intended for fire protection systems designed in accordance with the standard installation rules recognized by the applicable Listing or Approval agency (for example, UL Listing is based on the requirements of NFPA 13, and FM Approval is based on the requirements of the FM Loss Prevention Data Sheets). Only the Style 10 Recessed Escutcheon, as applicable, is to be used for recessed horizontal installations.





## Installation

The TYCO Series TY-B, 5.6 K-factor, Horizontal and Vertical Sidewall Sprinklers must be installed in accordance with this section.

### General Instructions

Do not install any bulb type sprinkler if the bulb is cracked or there is a loss of liquid from the bulb. With the sprinkler held horizontally, a small air bubble should be present. The diameter of the air bubble is approximately 1/16 in. (1,6 mm) for the 135°F (57°C) to 3/32 in. (2,4 mm) for the 360°F (182°C) temperature ratings.





#### Horizontal Sidewall Sprinkler Installation

The TYCO Series TY-B Recessed Horizontal Sidewall Sprinklers must be installed in accordance with the following instructions. Install recessed horizontal sidewall sprinklers in the horizontal position with the centerline of waterway perpendicular to the back wall and parallel to the ceiling. The word "TOP" on the Deflector is to face towards the ceiling.

**Step A.** After installing the Style 10 Mounting Plate over the sprinkler threads, hand-tighten the sprinkler into the sprinkler fitting.

**Step B.** Tighten the sprinkler into the sprinkler fitting using only the W-Type 7 Recessed Sprinkler Wrench, see Figure 5. Apply the W-Type 7 Recessed Sprinkler Wrench to the sprinkler wrench flats, see Figure 1.

**Step C.** After the ceiling is installed or the finish coat is applied, slide on the Style 10 Closure over the Series TY-B Sprinkler and push the Closure over the Mounting Plate until its flange comes in contact with the ceiling.

A leak-tight 1/2 in. NPT sprinkler joint should be obtained by applying a minimum-to-maximum torque of 7 to 14 lb-ft (9,5 to 19,0 N·m). Higher levels of torque may distort the sprinkler inlet and cause leakage or impairment of the sprinkler. Do not attempt to

make-up for insufficient adjustment in the escutcheon plate by under- or over-tightening the sprinkler. Readjust the position of the sprinkler fitting to suit.

K-Factor	Sprinkler Type	Temperature Rating	Bulb Liquid Color	Sprinkler Finish <sup>(10)</sup>						
				Natural Brass	Chrome Plated	Polyester <sup>c</sup>	Poly-Stainless <sup>c</sup>	Lead Coated	Wax Coated	Wax-Over-Lead Coated
5.6 1/2 in. NPT	Horizontal Sidewall (TY3351) Figure 1	135°F (57°C)	Orange	1, 2, 3, 4, 9	1, 2, 3, 9	1, 2	1, 2, 3, 9	1, 2, 3, 9		
		155°F (68°C)	Red							
		175°F (79°C)	Yellow							
		200°F (93°C)	Green							
		286°F (141°C)	Blue					1 <sup>b</sup> , 2 <sup>b</sup> , 3 <sup>b</sup> , 9 <sup>b</sup>		
		360°F (182°C)	Mauve							N/A
	Recessed Horizontal Sidewall (TY3351) <sup>a</sup> Figure 3	135°F (57°C)	Orange	1, 2, 3, 9		1, 2	N/A			
		155°F (68°C)	Red							
		175°F (79°C)	Yellow							
		200°F (93°C)	Green							
5.6 1/2 in. NPT	Vertical Sidewall (TY3451) Pendent or Upright Figure 2	135°F (57°C)	Orange	5, 6, 7, 9		N/A	5, 6, 7, 9	5, 6, 7, 9		
		155°F (68°C)	Red							
		175°F (79°C)	Yellow							
		200°F (93°C)	Green							
		286°F (141°C)	Blue					5 <sup>b</sup> , 6 <sup>b</sup> , 7 <sup>b</sup> , 9 <sup>b</sup>		
		360°F (182°C)	Mauve	N/A						
				5, 6, 9		N/A		N/A		
<b>Notes:</b> 1. UL Listed for use in Light and Ordinary Hazard Occupancies at a 4 to 12 in. (100 to 300 mm) top of deflector-to-ceiling distance 2. C-UL Listed for use in Light and Ordinary Hazard Occupancies at a 4 to 12 in. (100 to 300 mm) top of deflector-to-ceiling distance 3. FM Approved for use in Light Hazard Occupancies at a 4 to 12 in. (100 to 300 mm) top of deflector-to-ceiling distance 4. LPCB Approved (Ref. No. 094a & 007k) at a 4 to 6 in. (100 to 150 mm) deflector-to-ceiling distance 5. UL Listed for use in Light and Ordinary Hazard Occupancies 6. C-UL Listed for use in Light and Ordinary Hazard Occupancies 7. FM Approved for use in Light Hazard Occupancies 8. LPCB Approved (Ref. No. 094a & 007k) 9. Approved by the City of New York under MEA 354-01-E 10. Where Polyester Coated, Lead Coated, Wax Coated, and Wax-over-Lead Coated Sprinklers are noted to be UL and C-UL Listed, the sprinklers are UL and C-UL Listed as corrosion-resistant sprinklers. Where Lead Coated, Wax Coated, and Wax-over-Lead Coated Sprinklers are noted to be FM Approved, the sprinklers are FM Approved as corrosion-resistant sprinklers. a. Installed with Style 10 (1/2 in. NPT) or Style 40 (3/4 in. NPT) 3/4 in. Total Adjustment Recessed Escutcheon, as applicable b. 150°F (66°C) maximum ceiling temperature c. Frame and deflector only N/A – Not Applicable										
<div>TABLE A</div> <div>SERIES TY-B 5.6 K-FACTOR HORIZONTAL AND VERTICAL SPRINKLERS</div> <div>LABORATORY LISTINGS AND APPROVALS</div>										

K-Factor	Sprinkler Type	Sprinkler Finish				
		Natural Brass	Chrome Plated	Polyester <sup>1</sup>	Lead Coated	Wax Coated
5.6 1/2 in. NPT	Horizontal Sidewall (TY3351)	250 psi (17,2 bar) <sup>2</sup> OR 175 psi (12,1 bar)				
	Recessed Horizontal Sidewall (TY3351)					
	Vertical Sidewall (TY3451)	175 psi (12,1 bar)				

**Notes:**

1. Frame and deflector only

2. The maximum working pressure of 250 psi (17,2 bar) only applies to UL Listing, C-UL Listing and Approval by the City of New York

**TABLE B**

**SERIES TY-B 5.6 K-FACTOR HORIZONTAL AND VERTICAL SPRINKLERS**

**MAXIMUM WORKING PRESSURE**

## Model SW-20 and SW-24 — 11.2 K-factor Extended Coverage Ordinary Hazard Horizontal Sidewall Sprinklers (Standard Response)

### General Description

The TYCO Model SW-20 and SW-24, 11.2 K-factor, Extended Coverage Ordinary Hazard (ECOH) Horizontal Sidewall Sprinklers, Standard Response are decorative glass bulb sprinklers designed for use in ordinary hazard occupancies per NFPA 13.

The SW-20 provides protection of coverage areas up to 16 ft x 20 ft (320 ft<sup>2</sup>), whereas the SW-24 provides protection of coverage areas up to 16 ft x 24 ft (384 ft<sup>2</sup>), as compared to standard coverage horizontal sidewall sprinklers having a maximum coverage area of 10 ft x 10 ft (100 ft<sup>2</sup>) for ordinary hazard occupancies.

Horizontal sidewall sprinklers are designed for installation along a wall or the side of a beam and are commonly used instead of pendent or upright sprinklers due to aesthetics or building construction considerations, where piping across the ceiling is not desirable.

Corrosion resistant coatings, where applicable, are utilized to extend the life of copper alloy sprinklers beyond that which would otherwise be obtained when exposed to corrosive atmospheres. Although corrosion resistant coated sprinklers have passed the standard corrosion tests of the applicable approval agencies, the testing is

not representative of all possible corrosive atmospheres. Consequently, it is recommended that the end user be consulted with respect to the suitability of these corrosion resistant coatings for any given corrosive environment. The effects of ambient temperature, concentration of chemicals, and gas/chemical velocity, should be considered, as a minimum, along with the corrosive nature of the chemical to which the sprinklers will be exposed.

#### NOTICE

*The Model SW-20 and SW-24 Sprinklers described herein must be installed and maintained in compliance with this document and with the applicable standards of the National Fire Protection Association, in addition to the standards of any authorities having jurisdiction. Failure to do so may impair the performance of these devices.*

*The owner is responsible for maintaining their fire protection system and devices in proper operating condition. The installing contractor or sprinkler manufacturer should be contacted with any questions.*

### Sprinkler Identification Number (SIN)

TY5332 - SW-20

TY5337 - SW-24

TY5332 is a re-designation for C5332

TY5337 is a re-designation for C5337

### Technical Data


#### Approvals

UL and C-UL Listed


(Refer to the Design Criteria Section)

Polyester coated sprinklers are UL and C-UL Listed as Corrosion Resistant Sprinklers

NYC under MEA 177-03-E



SW-20



SW-24

#### Maximum Working Pressure

175 psi (12,1 bar)

#### Discharge Coefficient

K= 11.2 GPM/psi<sup>1/2</sup> (161,3 LPM/bar<sup>1/2</sup>)

#### Temperature Rating

SW-20: 155°F (68°C) & 200°F (93°C)

SW-24: 200°F (93°C)

#### Finishes

Refer to Table B

#### Physical Characteristics:

Frame .....	Bronze
Button .....	Bronze
Sealing Assembly .....	Beryllium Nickel w/ TEFLON
Bulb .....	Glass
Compression Screw .....	Brass
Deflector .....	Bronze

#### IMPORTANT

Refer to Technical Data Sheet TFP2300 for warnings pertaining to regulatory and health information.


Always refer to Technical Data Sheet TFP700 for the "INSTALLER WARNING" that provides cautions with respect to handling and installation of sprinkler systems and components. Improper handling and installation can permanently damage a sprinkler system or its components and cause the sprinkler to fail to operate in a fire situation or cause it to operate prematurely.

Components:

- 1 - Frame
- 2 - Button
- 3 - Bulb
- 4 - Compression Screw
- 5 - Sealing Assembly
- 6 - Deflector\*

\* Temperature rating is indicated on Deflector.

\*\* Pipe thread connections per ISO 7-1 can be provided on special request.




**FIGURE 1**  
**MODEL SW-20 (TY5332)**  
**EXTENDED COVERAGE ORDINARY HAZARD**  
**HORIZONTAL SIDEWALL SPRINKLER**  
**11.2 K-FACTOR, 3/4 INCH NPT**

Components:


- 1 - Frame
- 2 - Button
- 3 - Bulb
- 4 - Compression Screw
- 5 - Sealing Assembly
- 6 - Deflector\*

\* Temperature rating is indicated on Deflector.


\*\* Pipe thread connections per ISO 7-1 can be provided on special request.



**FIGURE 2**  
**MODEL SW-24 (TY5337)**  
**EXTENDED COVERAGE ORDINARY HAZARD**  
**HORIZONTAL SIDEWALL SPRINKLER**  
**11.2 K-FACTOR, 3/4 INCH NPT**



**FIGURE 3**  
**W-TYPE 3 SPRINKLER**  
**WRENCH**



**FIGURE 4**  
**SPRINKLER PLACEMENT**  
**UNDER SLOPED CEILINGS IN**  
**LOADING DOCKS**

## Operation

The glass bulb contains a fluid that expands when exposed to heat. When the rated temperature is reached, the fluid expands sufficiently to shatter the glass bulb, allowing the sprinkler to activate and water to flow.



MODEL SW-20 ECOH HORIZONTAL SIDEWALL SPRINKLER (TY5332) OH Group 1 (0.15 gpm/sq.-ft.)						
Response Rating	Coverage Area <sup>(1)</sup> , Ft x Ft (m x m)	Minimum Flow <sup>(2)</sup> , GPM (LPM)	Minimum Pressure <sup>(2)</sup> , PSI (BAR)	Deflector-To-Ceiling Distance <sup>(3)</sup> , In. (mm)	Sprinkler Temperature Rating, °F	Minimum Spacing <sup>(4)</sup> , Ft (m)
Standard	16 x 16 (4,9 x 4,9)	38 (144)	11.5 (0,79)	6 to 12 (150 to 300)	155, 200	8 (2,4)
Standard	16 x 18 (4,9 x 5,5)	43 (163)	14.7 (1,01)	6 to 12 (150 to 300)	155, 200	8 (2,4)
Standard	16 x 20 (4,9 x 6,1)	48 (182)	18.4 (1,27)	6 to 12 (150 to 300)	155, 200	8 (2,4)

MODEL SW-20 ECOH HORIZONTAL SIDEWALL SPRINKLER (TY5332) OH Group 2 (0.20 gpm/sq.-ft.)						
Response Rating	Coverage Area <sup>(1)</sup> , Ft x Ft (m x m)	Minimum Flow <sup>(2)</sup> , GPM (LPM)	Minimum Pressure <sup>(2)</sup> , PSI (BAR)	Deflector-To-Ceiling Distance <sup>(3)</sup> , In. (mm)	Sprinkler Temperature Rating, °F	Minimum Spacing <sup>(4)</sup> , Ft (m)
Standard	16 x 16 (4,9 x 4,9)	51 (193)	20.7 (1,43)	6 to 12 (150 to 300)	155, 200	8 (2,4)
Standard	16 x 18 (4,9 x 5,5)	58 (220)	26.8 (1,85)	6 to 12 (150 to 300)	155, 200	8 (2,4)
Standard	16 x 20 (4,9 x 6,1)	64 (242)	32.7 (2,25)	6 to 12 (150 to 300)	155, 200	8 (2,4)

MODEL SW-24 ECOH HORIZONTAL SIDEWALL SPRINKLER (TY5337) OH Group 1 (0.15 gpm/sq.-ft.)						
Response Rating	Coverage Area <sup>(1)</sup> , Ft x Ft (m x m)	Minimum Flow <sup>(2)</sup> , GPM (LPM)	Minimum Pressure <sup>(2)</sup> , PSI (BAR)	Deflector-To-Ceiling Distance <sup>(3)</sup> , In. (mm)	Sprinkler Temperature Rating, °F	Minimum Spacing <sup>(4)</sup> , Ft (m)
Standard	16 x 22 (4,9 x 6,7)	53 (200)	22.4 (1,54)	6 to 12 (150 to 300)	200	8 (2,4)
Standard	16 x 24 (4,9 x 7,3)	58 (220)	26.8 (1,85)	6 to 12 (150 to 300)	200	8 (2,4)

MODEL SW-24 ECOH HORIZONTAL SIDEWALL SPRINKLER (TY5337) OH Group 2 (0.20 gpm/sq.-ft.)						
Response Rating	Coverage Area <sup>(1)</sup> , Ft x Ft (m x m)	Minimum Flow <sup>(2)</sup> , GPM (LPM)	Minimum Pressure <sup>(2)</sup> , PSI (BAR)	Deflector-To-Ceiling Distance <sup>(3)</sup> , In. (mm)	Sprinkler Temperature Rating, °F	Minimum Spacing <sup>(4)</sup> , Ft (m)
Standard	16 x 22 (4,9 x 6,7)	71 (269)	40.2 (2,77)	6 to 12 (150 to 300)	200	8 (2,4)
Standard	16 x 24 (4,9 x 7,3)	77 (291)	47,3 (3,26)	6 to 12 (150 to 300)	200	8 (2,4)

**NOTES**

1. Backwall (where sprinkler is located) by sidewall (length of throw).
2. Requirement is based on minimum flow in GPM from each sprinkler. The indicated residual pressures are based on the nominal K-factor.
3. The centerline of the sprinkler waterway is located below the deflector as shown in Figures 1 and 2.
4. Minimum spacing is for lateral distance between sprinklers located along a single wall. Otherwise adjacent sprinklers (i.e., sidewall sprinklers on an adjacent wall, on an opposite wall, or pendent sprinklers) must be located outside of the maximum listed protection area of the extended coverage sidewall sprinkler being utilized.

**TABLE A**  
**UL AND C-UL LISTING COVERAGE AND FLOW RATE CRITERIA**

## **PROJECT REFERENCES (SINGAPORE ONLY) FIRE PROTECTION SYSTEM**

Since we established in 1972, our fire protection equipments have been installed in over few hundred thousand buildings worldwide. As a supplier for sprinkler products, we do not normally keep track of where our products were installed as they are all done by fire contractors. We have now compiled to the best of our knowledge the following project reference list in Singapore.

- |   |  |
|---|--|
| 1. Changi Terminal 3                                      | 32. Chartered Semi-Conductor FAB VI    |
| 2. Changi Terminal 2 Upgrading                            | 33. Chartered Semi-Conductor FAB VII   |
| 3. Budget Terminal @ Changi                               | 34. Wackers Wafer Fab Plant @ Tampines |
| 4. Republic Polytechnic @ Woodland                        | 35. Ikea @ Tampines Ave 10             |
| 5. Nanyang Polytechnic @ Ang Mo Kio                       | 36. Ang Mo Kio Hub, Retail mall        |
| 6. Vivo City Mall @ Keppel Road                           | 37. SOHO Central @ Bugis               |
| 7. One Raffles Quay (ORQ), Shenton Way                    | 38. Republic Plaza @ Raffles Place     |
| 8. National Library @ Brass Basah                         | 39. Marina Square (Upgrading A & A)    |
| 9. New Supreme Court                                      | 40. HDB @ Jln Bukit Merah (A & A)      |
| 10. Singapore North-East Line MRT                         | 41. Ciba Vision factory @ Tuas         |
| 11. Circle Line Stage 1 (Contract 833)                    | 42. Icon Condo @ Tanjong Pagar         |
| 12. Circle Line Stage 2 (Contract 833B)                   | 43. Singapore Immigration Building     |
| 13. Circle Line Stage 3 (C852A)                           | 44. Senoko Power Station               |
| 14. Circle Line Stage 4 & 5                               | 45. IBM @ Changi Business Park         |
| 15. Changi MRT Depot                                      | 46. Invensys @ Changi Business Park    |
| 16. Changi Water Reclamation (C2B)                        | 47. Schenker Pharmaceutical Plant      |
| 17. Changi Water Reclamation (C3D)                        | 48. NUS Data Storage                   |
| 18. Changi Water Reclamation (C4A)                        | 49. Pulau Seraya Power Station         |
| 19. Changi Water Reclamation (C4B)                        | 50. AIA Building @ Alexandra           |
| 20. Changi Water Reclamation (C4C)                        | 51. Burlington Square                  |
| 21. Capital Tower @ Robinson Road                         | 52. UOB Plaza @ Raffles Place          |
| 22. Esplanade Art Centre @ Marina                         | 53. Royal Holiday Inn Crown Plaza      |
| 23. Singapore Indoor Stadium                              | 54. YWCA Hotel @ Somerset Road         |
| 24. Tuas Custom Checkpoint                                | 55. Tampines Junction Shopping Complex |
| 25. Singapore Expo (Hall 7 to 10)                         | 56. JTC @ Ayer Rajah                   |
| 26. Biopolis phase 2 @ Buona Vista                        | 57. JTC @ Woodland                     |
| 27. Fusion Polis @ Buona Vista                            | 58. JTC @ Ubi                          |
| 28. Suntec City   | 59. JTC @ Kallang Avenue               |
| 29. New Parliament House                                  | 60. JTC @ Depot Road                   |
| 30. Singapore Arm Forces (SAFTI) Military<br>Camp, Jurong | 61. JTC @ Toa Payoh North              |
| 31. Chartered Semi-Conductor FAB II                       | 62. JTC @ Lower Delta Road             |

*Important Notice: This correspondence is based on information provided to the author. Any opinion expressed is based on the provided information and is not intended to represent an "Approval" by Tyco Fire & Building Products. All products sold by Tyco Fire & Building Products must be installed and maintained in compliance with our technical data sheets, as well as all applicable codes/standards. Tyco Fire Building Products is not an approving authority and final approval must still be obtained from the local Authority Having Jurisdiction. Tyco Fire & Building Products assumes no liability by providing these opinions to you.*