



Syracuse Division
Code Compliance Specialist

Joshua D. Stagnitti

290 Elwood Davis Road, Suite 250, Liverpool, New York 13088

Office: 315-438-2397

Fax: 315-461-0765

Cell: 315-374-8845

E-mail: joshua.stagnitti@thruway.ny.gov

Construction Permit Application

Date: 11/06/2025

Applicant: PHOENIX TOWER INTERNATIONAL
(TENANT)

Contact information: InfraServices, Project Manager Darrell Paulson. (315) 679-3145
dpaulson@infraservices.com

Project Description: Ground Scope of Work:

Install new WUC and 30KW Diesel Generator w/145 gallon belly tank on proposed steel platform at grade. Install new cable ice bridge from WUC to existing tower. Install New 200A 120/240v utility service from existing meter board to new WUC. Install new conduit from backhaul service to WUC from existing telco demarc. Install (3) new fiber management boxes.

Antenna Level Scope of Work:

Install (12) Panel antennas on new antenna mounts on existing tower. (12) Remote Radio Units (RRU's), (3) DC9 surge suppressor units, (3) Fiber, and (8) DC trunk cables from WUC to antennas. (1) SITEPRO 1 antenna quad frame.

Project Location: Exit 37, MP 283.95

List any Sub Contractors: AT&T

Applicant Signature: Jackie Donahue