

Bureau of Indian Standards

Manak Bhawan, 9, Bahadur Shah Zafar Marg
New Delhi - 110002

IS 10500:2012

2012

DRINKING WATER SPECIFICATIONS

SPECIFICATION

ICS 13.060
BIS 2012

Indian Standard

1 SCOPE

This standard specifies the requirements for drinking water. It covers physical, chemical, and bacteriological parameters.

2 PHYSICAL REQUIREMENTS

Parameter	Acceptable	Permissible
Color (TCU)	5	15
Odor	Absent	Absent
Taste	Absence of	Absence of
Turbidity (NTU)	1	5
pH Value	6.5-8.5	No relaxation
Total Dissolved Solids (mg/L)	500	2000

3 CHEMICAL REQUIREMENTS

Parameter	Acceptable (mg/L)	Permissible (mg/L)
Iron	0.3	No relaxation
Manganese	0.1	0.3
Chlorides	250	1000
Sulphates	200	400
Nitrate	45	No relaxation

Fluoride	1.0	1.5
Arsenic	0.01	No relaxation
Lead	0.01	No relaxation

4 BACTERIOLOGICAL REQUIREMENTS

Parameter	Requirement
Total Coliform (MPN/100mL)	Absent in 100mL
Fecal Coliform	Absent in 100mL
E. Coli	Absent in 100mL